

BOOTHVILLE, LA, USA

WMO: 722336

Lat: 29.333N

Lon: 89.408W

Elev: 1

StdP: 14.70

Time Zone: -6.00 (NAC)

Period: 00-19

WBAN: 12884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.9	36.8	19.3	14.5	41.5	25.0	19.0	43.9	23.5	54.0	20.5	53.7	5.5	0	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	93.0	77.1	91.0	77.4	90.0	77.6	81.2	87.0	80.4	86.2	80.0	85.8	6.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.7	83.6	79.0	150.7	83.6	78.4	147.3	83.5	44.6	87.3	43.9	86.4	43.2	85.4	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.5	17.3	15.6	30.4	94.3	5.1	3.5	26.7	96.9	23.7	98.9	20.8	100.9	17.1	103.4		
			27.5	82.4	4.8	1.0	24.1	83.1	21.3	83.6	18.6	84.2	15.1	84.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	70.1	54.1	56.6	62.8	69.2	75.8	81.7	83.3	80.7	73.2	63.6	56.9
		DBStd	12.22	8.99	8.20	7.06	5.44	4.39	3.12	2.35	2.57	3.24	6.87	8.66
		HDD50	131	61	28	5	0	0	0	0	0	0	3	34
		HDD65	1164	350	249	126	25	1	0	0	0	20	117	276
		CDD50	7481	188	215	401	577	801	950	1023	1031	920	718	410
		CDD65	3039	12	15	58	152	337	500	558	566	470	273	74
		CDH74	29451	25	35	201	772	2632	5573	6486	6645	4781	1995	257
		CDH80	10097	0	1	10	94	638	2103	2572	2699	1553	411	14
(14)	Wind	WSAvg	7.0	7.9	7.8	7.7	7.9	7.0	6.3	5.7	5.8	6.0	6.9	7.0
(15)	Precipitation	PrecAvg	58.0	4.7	3.9	5.1	4.5	3.9	5.3	7.0	6.4	6.3	3.6	4.3
		PrecMax	93.0	18.0	9.4	12.2	20.5	10.2	15.9	11.9	11.1	15.7	11.3	14.1
		PrecMin	34.3	0.0	0.6	0.4	0.1	0.4	1.2	2.6	2.6	1.7	0.3	0.6
		PrecStd	11.9	4.1	2.3	2.6	4.1	2.4	3.3	2.4	2.5	3.1	3.0	2.2
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.1	78.1	81.4	85.7	90.5	95.5	93.6	97.0	92.8	89.9	81.6
			MCWB	68.8	68.4	67.8	67.9	73.3	74.6	77.7	78.7	76.7	75.3	71.9
		2%	DB	73.3	74.5	78.7	82.1	88.0	92.5	91.4	92.9	90.4	86.4	79.4
			MCWB	66.7	67.6	68.6	70.5	73.6	75.5	78.4	78.3	76.0	75.6	71.8
		5%	DB	70.9	72.2	76.3	80.8	85.3	90.2	90.4	90.8	88.4	83.9	77.1
			MCWB	65.8	66.9	68.9	70.6	74.8	76.7	78.5	78.6	76.6	75.1	70.7
		10%	DB	67.7	69.8	73.5	78.8	83.4	88.3	88.8	89.3	87.0	82.0	74.6
			MCWB	63.9	66.0	67.6	70.8	74.5	77.1	78.5	78.7	76.9	74.0	69.1
		0.4%	WB	71.4	72.5	73.6	76.7	78.9	81.2	82.5	82.3	80.9	80.1	75.9
			MCDB	74.1	75.3	77.1	80.1	83.2	87.0	88.5	89.1	86.3	83.2	79.2
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.4	70.2	72.2	75.2	77.8	80.3	81.2	81.2	80.0	78.5	73.8
			MCDB	71.8	72.6	75.7	78.9	82.9	86.0	87.0	87.3	85.4	82.5	77.3
		2%	WB	67.0	68.3	70.7	74.0	76.9	79.6	80.3	80.4	79.1	77.4	72.2
			MCDB	69.6	70.6	74.2	77.9	82.1	85.3	86.3	86.5	84.7	82.4	75.7
		5%	WB	64.3	66.2	69.2	72.8	76.0	78.9	79.6	80.0	78.3	76.2	70.1
			MCDB	66.7	68.7	72.7	76.6	81.2	84.8	85.8	86.0	83.9	81.1	73.7
		10%	WB	64.3	66.2	69.2	72.8	76.0	78.9	79.6	80.0	78.3	76.2	70.1
			MCDB	66.7	68.7	72.7	76.6	81.2	84.8	85.8	86.0	83.9	81.1	73.7
		0.4%	WB	64.3	66.2	69.2	72.8	76.0	78.9	79.6	80.0	78.3	76.2	70.1
			MCDB	66.7	68.7	72.7	76.6	81.2	84.8	85.8	86.0	83.9	81.1	73.7
(35)	Mean Daily Temperature Range	MDBR	15.3	15.5	15.4	14.9	13.3	12.4	11.5	11.6	11.8	13.7	14.9	14.4
		5% DB	MCDBR	18.0	17.2	17.2	17.5	16.3	16.8	14.0	15.0	15.0	14.0	15.5
			MCWBR	12.8	12.0	10.0	8.7	6.5	5.8	5.4	5.5	6.0	6.8	9.6
		5% WB	MCDBR	15.7	14.4	14.0	12.3	11.0	10.7	10.9	11.2	10.7	10.6	12.5
			MCWBR	12.9	12.2	10.2	8.5	5.3	5.2	5.4	5.2	5.2	6.5	9.3
(40)	Clear-Sky Solar Irradiance	taub	0.348	0.364	0.378	0.416	0.440	0.458	0.489	0.488	0.445	0.393	0.366	0.355
		taud	2.536	2.506	2.449	2.338	2.312	2.309	2.246	2.250	2.331	2.474	2.491	2.527
		Ebn at Noon	282	287	289	279	272	265	257	256	264	273	273	274
		Edh at Noon	28	31	35	40	42	42	44	44	39	32	29	27
(44)	All-Sky Solar Radiation	RadAvg	968	1168	1576	1878	2074	1983	1819	1697	1626	1448	1106	873
		RadStd	76	141	132	170	94	135	127	128	115	131	101	70

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+252	+169

Nomenclature: See separate page