

JIM HOGG COUNTY AP, TX, USA

WMO: 722338

Lat: 27.349N

Lon: 98.737W

Elev: 663

StdP: 14.35

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12994

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.9	36.7	9.7	9.3	56.7	14.9	12.0	53.6	24.8	65.0	21.7	63.9	6.7	350	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.5	101.2	71.5	99.5	71.7	97.7	72.0	77.9	86.6	77.3	85.7	76.7	85.2	11.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.2	140.2	79.8	75.4	136.2	79.3	74.8	133.7	79.2	41.7	86.3	41.0	85.9	40.5	85.1	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.4	19.2	17.7	28.1	104.7	4.0	1.4	25.2	105.7	22.9	106.5	20.6	107.2	17.7	108.2		
			24.8	79.1	2.8	1.5	22.8	80.2	21.1	81.1	19.6	81.9	17.5	83.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.1	57.1	62.1	68.3	74.3	79.6	84.7	85.4	85.9	81.3	74.4	65.1	58.2
	DBStd	12.42	9.35	10.11	8.55	6.90	5.28	2.97	2.94	2.61	4.29	7.20	8.83	9.52
	HDD50	103	40	20	4	0	0	0	0	0	0	8	31	
	HDD65	894	277	159	68	12	0	0	0	0	16	106	256	
	CDD50	8528	259	359	573	730	918	1042	1096	1112	940	755	460	284
	CDD65	3846	31	78	172	292	453	592	631	647	491	306	109	44
	CDH74	41262	259	630	1378	2709	4552	7042	7680	8057	4895	2891	871	298
	CDH80	20669	46	206	492	1208	2174	3838	4281	4556	2375	1190	247	56
Wind	WSAvg	8.0	7.4	7.8	9.5	9.9	10.0	9.6	9.1	7.8	6.1	6.4	6.5	6.5
Precipitation	PrecAvg	24.2	1.1	1.3	0.7	1.7	2.6	3.1	1.5	2.2	4.1	2.0	1.2	0.9
	PrecMax	42.3	2.8	3.8	3.8	6.7	9.2	13.8	9.0	8.7	19.4	6.9	4.1	3.0
	PrecMin	13.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	8.0	0.8	1.1	0.8	1.7	2.1	2.9	1.9	2.3	4.7	1.7	1.2	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.4	91.0	93.9	99.3	99.7	102.6	102.5	103.2	100.2	94.8	89.9	85.6
		MCWB	61.8	64.1	62.3	68.9	71.3	72.0	71.5	71.2	70.6	72.2	68.6	64.2
	2%	DB	80.8	85.8	89.2	94.5	96.8	99.7	100.8	101.0	97.2	91.4	86.0	81.3
		MCWB	62.6	64.0	66.8	68.4	71.4	72.0	71.5	71.8	71.9	71.8	68.2	65.0
	5%	DB	76.8	81.8	85.6	90.4	93.6	97.4	99.0	99.2	94.6	89.7	82.6	77.3
		MCWB	61.7	64.1	66.1	68.6	71.7	71.9	72.0	72.3	72.0	71.4	67.2	63.2
	10%	DB	72.2	77.3	81.8	87.2	90.7	95.4	96.5	97.1	91.6	87.2	79.2	72.9
		MCWB	60.1	63.6	65.5	68.1	71.8	72.5	72.6	72.8	72.3	70.8	65.4	62.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.5	70.3	72.3	76.0	77.9	78.5	78.4	78.5	78.0	77.8	73.2	69.9
		MCDB	72.8	78.9	82.3	84.7	88.3	88.8	86.8	87.2	85.2	85.3	80.8	76.9
	2%	WB	67.2	69.1	71.1	74.3	76.6	77.4	77.4	77.7	77.1	76.3	71.7	68.9
		MCDB	74.2	77.1	79.6	83.9	86.2	86.7	86.0	86.2	84.1	83.4	79.1	75.1
	5%	WB	65.7	68.0	69.9	73.0	75.6	76.7	76.7	77.1	76.4	75.1	70.4	67.6
		MCDB	72.3	75.3	77.3	82.6	84.5	85.8	85.3	85.7	83.6	82.2	77.2	73.2
	10%	WB	63.5	66.8	68.9	71.8	74.8	75.9	76.1	76.4	75.7	74.0	69.0	66.0
		MCDB	69.0	73.5	76.0	80.7	83.5	85.0	84.6	85.1	83.2	81.1	75.5	71.4
Mean Daily Temperature Range	5% DB	MDBR	21.2	21.6	22.1	23.1	20.8	21.8	21.8	22.5	19.5	21.9	21.6	20.3
		MCDBR	25.5	26.9	24.9	26.0	24.2	24.3	25.1	25.5	23.5	21.9	23.9	24.7
		MCWBR	12.4	10.7	8.4	8.3	5.6	4.7	5.0	5.0	5.4	6.6	9.4	11.7
	5% WB	MCDBR	20.0	20.2	20.3	21.2	18.8	20.3	20.9	21.4	18.7	18.2	20.0	18.7
		MCWBR	11.9	9.6	8.6	7.6	5.5	4.8	4.8	4.7	4.9	6.8	9.4	10.7
Clear-Sky Solar Irradiance	taub		0.335	0.352	0.371	0.400	0.424	0.414	0.411	0.410	0.403	0.365	0.354	0.331
	taud		2.492	2.442	2.396	2.335	2.309	2.394	2.402	2.424	2.403	2.500	2.469	2.515
	Ebn at Noon		290	293	292	285	276	277	278	279	278	285	280	286
	Edh at Noon		30	34	37	41	42	38	38	37	36	31	30	28
All-Sky Solar Radiation	RadAvg		1001	1210	1498	1768	1898	2141	2124	2055	1678	1446	1106	902
	RadStd		118	207	190	178	179	96	165	106	151	169	128	141

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	+245	+218

Nomenclature: See separate page