

MERIDIAN, MS, USA

WMO: 722340

Lat: 32.335N

Lon: 88.744W

Elev: 294

StdP: 14.54

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13865

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.4	25.9	9.8	9.2	32.2	14.4	11.6	34.7	21.0	57.2	19.1	53.6	4.7	0	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	96.3	76.0	94.1	76.1	92.2	75.9	79.9	89.7	78.9	88.6	78.1	87.6	6.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.3	143.5	83.8	76.3	138.8	82.9	75.4	134.7	82.1	43.4	89.8	42.5	88.6	41.6	88.0	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	16.5	14.5	15.8	99.8	4.6	3.8	12.5	102.5	9.8	104.7	7.2	106.8	3.9	109.5
			14.5	81.9	4.5	1.5	11.3	83.0	8.7	83.9	6.2	84.7	3.0	85.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.8	46.4	50.5	57.3	64.4	72.1	78.8	81.1	80.9	76.0	65.4	54.9	48.8
	DBStd	14.53	10.41	10.02	9.00	7.15	5.76	3.68	2.92	3.44	5.51	8.15	8.60	9.91
	HDD50	539	197	107	36	2	0	0	0	0	0	2	46	149
	HDD65	2307	582	417	267	97	14	0	0	0	4	98	318	510
	CDD50	5936	85	120	262	433	686	864	966	958	780	479	193	110
	CDD65	2230	4	10	28	78	235	414	501	493	334	110	16	7
	CDH74	21611	11	57	259	774	2244	4093	4966	4911	3102	1058	117	19
	CDH80	9566	0	4	33	162	828	1939	2453	2443	1370	320	14	0
Wind	WSAvg	5.7	6.7	7.2	7.2	6.8	5.5	4.8	4.3	4.1	4.7	5.0	5.4	6.2
Precipitation	PrecAvg	56.4	5.3	5.3	6.3	5.4	4.3	4.0	5.1	4.1	3.5	3.3	4.3	5.7
	PrecMax	79.1	13.2	15.9	16.5	16.8	9.8	11.0	11.7	10.3	10.8	10.6	10.7	14.8
	PrecMin	35.4	1.2	1.5	0.5	0.9	0.3	0.3	1.1	0.7	0.1	0.0	0.6	1.1
	PrecStd	11.1	2.8	2.9	3.3	3.4	2.4	2.4	2.8	2.4	2.5	2.6	2.5	2.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.6	80.0	83.4	86.7	92.5	97.3	98.3	99.9	97.1	90.6	82.2	76.7
		MCWB	64.4	67.6	67.0	69.8	73.6	75.2	75.8	75.6	74.7	71.5	67.5	67.9
	2%	DB	71.3	75.1	80.1	84.2	89.8	94.3	95.5	96.1	93.2	86.7	77.3	72.6
		MCWB	63.6	64.8	64.9	68.5	72.8	75.1	76.8	76.5	74.5	71.1	66.1	66.0
	5%	DB	67.6	71.2	77.0	81.8	87.4	92.0	93.3	93.6	90.7	83.4	73.8	69.2
		MCWB	61.7	62.0	63.6	67.1	71.8	75.1	77.0	76.5	73.9	69.4	63.9	63.7
	10%	DB	63.9	67.7	73.2	78.9	85.0	89.8	91.3	91.3	88.1	80.4	70.6	65.6
		MCWB	58.9	59.8	61.9	65.5	70.5	74.9	76.9	76.6	73.3	67.8	63.0	60.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.3	69.7	70.9	73.8	77.2	79.6	81.3	81.3	78.8	77.0	72.3	70.3
		MCDB	72.0	75.3	77.0	81.1	86.6	89.5	90.5	91.4	87.9	83.5	76.4	73.9
	2%	WB	65.8	67.4	68.5	71.6	75.4	78.3	80.0	79.9	77.4	74.8	69.6	67.7
		MCDB	69.3	73.4	74.7	79.2	84.1	88.2	89.7	89.9	86.5	82.0	73.6	71.1
	5%	WB	63.2	65.2	66.4	70.2	74.1	77.5	79.0	78.8	76.4	72.9	67.3	65.2
		MCDB	66.4	69.9	73.1	77.4	82.9	87.2	88.9	88.5	85.1	79.3	71.9	68.3
	10%	WB	59.9	61.9	64.4	68.6	73.0	76.5	78.1	77.9	75.4	70.9	64.5	61.9
		MCDB	63.4	66.3	71.1	75.5	81.5	85.8	87.8	87.2	83.6	76.7	69.1	64.9
Mean Daily Temperature Range	5% DB	MDBR	21.9	22.8	24.0	24.4	22.8	20.9	20.1	20.6	22.2	24.5	24.6	21.4
		MCDBR	23.6	25.2	26.5	25.6	24.8	23.8	23.1	24.0	24.9	26.3	26.7	22.8
		MCWBR	16.2	14.8	13.1	11.8	10.1	8.3	7.9	7.8	8.9	12.1	15.7	16.0
	5% WB	MCDBR	18.9	20.9	21.0	20.4	20.3	20.1	19.9	19.9	19.7	19.4	20.5	18.7
		MCWBR	15.1	14.3	12.5	10.9	9.1	8.1	8.0	7.8	8.0	10.5	14.4	14.9
Clear-Sky Solar Irradiance	taub	0.327	0.330	0.362	0.396	0.430	0.467	0.514	0.511	0.435	0.371	0.343	0.325	
	taud	2.516	2.510	2.431	2.333	2.277	2.208	2.103	2.108	2.303	2.456	2.481	2.536	
	Ebn at Noon	284	294	291	284	273	262	249	248	264	276	275	279	
	Edh at Noon	27	30	35	40	43	46	51	50	39	31	28	25	
All-Sky Solar Radiation	RadAvg	869	1039	1398	1755	1930	1986	1897	1770	1586	1328	988	752	
	RadStd	75	145	119	141	127	150	106	122	117	171	97	75	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+241	+151

Nomenclature: See separate page