

MERIDIAN NAS, MS, USA

WMO: 722345

Lat: 32.550N

Lon: 88.567W

Elev: 83

StdP: 100.34

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03866

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.6	-3.3	-13.4	1.2	-0.7	-10.9	1.5	0.6	9.4	6.8	8.5	6.3	1.7	0	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	35.6	24.3	34.5	24.3	33.5	24.3	26.5	32.2	25.9	31.6	25.4	31.1	2.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.2	29.2	24.3	19.4	28.4	23.9	18.9	28.0	82.6	32.3	80.2	31.9	78.0	31.2	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.5	5.4	-9.3	37.1	2.5	1.3	-11.1	38.0	-12.6	38.8	-14.0	39.5	-15.8	40.5		
(5)			-10.1	27.7	2.5	1.4	-11.9	28.7	-13.3	29.5	-14.7	30.3	-16.5	31.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	7.6	10.3	14.2	17.7	22.5	26.3	27.3	27.1	24.6	18.6	12.2	9.6
	DBStd	8.21	5.82	5.98	5.38	4.06	3.28	2.30	1.81	1.98	2.98	4.44	4.76	5.54
	HDD10.0	317	118	64	23	2	0	0	0	0	0	1	31	78
	HDD18.3	1302	334	233	146	59	8	0	0	0	1	52	192	275
	CDD10.0	3315	43	72	154	233	387	488	538	531	438	268	97	66
	CDD18.3	1259	2	7	19	41	137	238	279	273	189	62	7	4
	CDH23.3	12091	4	38	161	406	1260	2433	2765	2658	1741	571	45	11
	CDH26.7	5331	0	3	26	82	479	1170	1338	1280	773	174	6	0
Wind	WSAvg	2.0	2.4	2.5	2.5	2.3	1.8	1.7	1.6	1.5	1.6	1.9	2.0	2.2
Precipitation	PrecAvg	1431	142	133	157	152	115	98	129	94	75	79	105	143
	PrecMax	2002	308	286	382	387	342	314	290	219	258	249	287	307
	PrecMin	924	26	36	46	16	12	5	25	9	6	0	17	29
	PrecStd	310	69	70	84	101	82	67	70	50	57	70	67	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.8	27.0	29.0	30.1	33.9	36.6	36.3	37.2	35.7	32.4	27.3	24.7
		MCWB	17.2	19.6	18.5	20.2	23.3	23.6	24.3	24.6	23.1	21.7	19.9	19.9
	2%	DB	21.4	24.3	27.2	28.9	32.3	35.1	35.1	35.5	34.1	30.5	24.4	22.6
		MCWB	17.0	17.9	18.2	19.8	22.6	24.1	24.9	24.5	23.1	21.3	18.4	18.8
	5%	DB	19.1	22.1	25.2	27.6	31.0	33.8	34.0	34.1	32.8	28.6	22.6	20.7
		MCWB	15.3	17.0	17.2	19.1	22.0	24.0	24.9	24.8	23.3	20.5	17.2	17.5
	10%	DB	17.2	20.0	23.1	26.0	29.5	32.5	32.9	32.7	31.3	26.7	20.7	18.7
		MCWB	14.3	15.7	16.2	18.3	21.4	24.0	24.7	24.7	23.1	19.8	16.5	15.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.9	21.0	22.7	25.3	26.7	27.7	27.0	25.9	24.8	22.1	21.2
		MCDB	21.9	24.5	24.6	27.2	30.7	32.4	32.6	32.6	31.4	28.2	24.7	23.4
	2%	WB	17.9	19.7	19.7	21.6	24.1	25.8	26.6	26.4	25.2	23.7	20.3	19.5
		MCDB	20.1	23.0	24.0	26.2	29.4	31.7	32.1	32.4	30.6	27.9	22.5	21.8
	5%	WB	16.6	18.3	18.7	20.7	23.4	25.3	25.9	25.8	24.6	22.6	18.9	18.1
		MCDB	18.9	21.3	23.3	25.2	28.5	31.1	31.5	31.5	29.6	26.3	21.2	20.1
	10%	WB	14.8	16.5	17.7	19.8	22.6	24.7	25.4	25.3	24.0	21.5	17.2	16.6
		MCDB	17.0	19.6	21.8	24.3	27.6	30.4	31.1	30.8	28.7	24.7	20.0	18.2
Mean Daily Temperature Range	5% DB	MDBR	11.5	12.2	13.0	13.4	12.4	11.6	10.8	11.1	12.1	13.1	13.0	11.0
		MCDBR	12.7	13.6	14.1	14.4	13.7	13.1	12.1	12.8	13.6	14.2	13.9	11.9
		MCWBR	8.9	8.0	7.0	6.6	5.4	4.5	4.2	4.1	4.8	6.2	8.4	8.3
	5% WB	MCDBR	10.4	11.2	11.7	11.6	11.4	11.4	10.9	11.0	10.8	10.8	11.1	9.8
		MCWBR	8.4	7.7	6.9	6.4	5.2	4.7	4.5	4.2	4.3	5.7	8.3	7.6
Clear-Sky Solar Irradiance	taub	0.326	0.329	0.362	0.396	0.429	0.472	0.516	0.513	0.434	0.371	0.343	0.323	
	taud	2.517	2.510	2.431	2.331	2.279	2.190	2.093	2.098	2.304	2.456	2.480	2.538	
	Ebn at Noon	896	928	917	894	863	822	783	780	833	869	866	879	
	Edh at Noon	85	95	110	127	135	147	161	159	124	99	88	80	
All-Sky Solar Radiation	RadAvg	2.72	3.26	4.39	5.52	6.08	6.29	6.00	5.57	4.99	4.16	3.08	2.34	
	RadStd	0.23	0.45	0.38	0.44	0.41	0.47	0.34	0.39	0.38	0.53	0.31	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.60	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+132	+87

Nomenclature: See separate page