

HATTIESBURG-LAUREL, MS, USAWMO: **722348**Lat: **31.467N**Lon: **89.333W**Elev: **293**StdP: **14.54**Time Zone: **-6.00 (NAC)**Period: **94-19**WBAN: **53808****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.0	27.8	9.8	9.2	32.3	15.6	12.2	35.5	18.5	55.3	16.8	51.9	3.7	0	0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	96.5	75.9	93.2	75.4	91.2	75.3	79.3	89.7	78.3	88.7	77.4	87.8	5.3	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	140.1	83.9	75.3	133.9	82.8	74.5	130.4	82.1	42.9	89.6	41.7	89.0	40.9	87.7	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.1	12.1	DB	17.5	99.2	4.6	2.7	14.2	101.1	11.5	102.6	9.0	104.1	5.6	106.1	(4)
(5)			WB	15.7	80.6	4.0	1.7	12.8	81.8	10.5	82.7	8.3	83.7	5.4	84.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.8	48.2	52.4	58.7	65.4	73.0	79.0	81.1	80.9	76.7	66.8	56.4	50.5
	DBStd	13.83	10.22	9.82	8.72	6.82	5.38	3.44	3.03	3.23	4.63	7.59	8.33	9.73
	HDD50	413	158	80	26	1	0	0	0	0	0	1	31	116
	HDD65	2018	524	366	230	78	10	0	0	0	1	73	278	458
	CDD50	6192	104	147	295	462	713	870	964	959	802	520	223	133
	CDD65	2323	5	14	34	89	258	420	499	494	353	127	20	10
	CDH74	20910	9	60	243	751	2341	3912	4729	4681	2966	1077	120	21
	CDH80	9050	0	3	26	135	872	1812	2295	2304	1280	312	11	0
Wind	WSAvg	4.6	5.4	5.8	5.8	5.7	4.5	3.6	3.3	3.2	4.1	4.4	4.7	5.0
Precipitation	PrecAvg	59.3	6.1	5.4	6.1	5.0	4.4	5.0	5.6	4.7	4.4	3.2	4.0	5.3
	PrecMax	71.5	12.2	10.7	13.3	10.8	11.0	11.7	9.8	14.6	11.1	7.6	9.2	16.9
	PrecMin	42.3	1.0	1.1	1.0	0.8	0.7	0.6	1.7	1.4	0.2	0.1	1.5	1.5
	PrecStd	8.1	2.8	2.6	3.0	2.5	2.9	2.8	2.0	2.7	3.0	2.5	1.9	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.9	80.3	82.3	85.9	92.3	97.4	99.4	99.2	95.4	90.2	81.5	77.1
		MCWB	64.4	66.8	66.4	70.0	73.0	74.6	75.9	75.3	74.9	71.8	67.2	66.8
	2%	DB	72.2	75.1	80.6	83.6	90.1	93.2	95.2	96.2	92.5	87.4	77.4	72.8
		MCWB	63.4	63.9	65.1	68.2	72.2	74.6	76.2	76.3	74.0	71.4	65.4	65.3
	5%	DB	68.5	72.2	76.7	81.5	88.0	91.1	92.8	92.9	90.3	83.6	73.6	70.2
		MCWB	61.3	62.7	63.5	66.9	71.8	74.7	75.9	76.2	73.8	69.5	63.8	64.0
	10%	DB	64.3	68.8	72.9	79.1	84.6	89.8	90.7	90.8	88.1	81.1	71.8	66.1
		MCWB	58.9	61.2	61.7	65.0	70.4	74.5	76.0	76.1	73.3	67.4	63.2	61.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.8	70.1	70.2	73.0	76.5	79.6	80.3	81.2	79.0	76.8	71.5	70.2
		MCDB	72.6	75.1	77.5	81.0	86.6	88.7	90.3	90.6	89.7	86.0	75.8	74.1
	2%	WB	65.4	67.3	68.1	71.1	75.1	77.9	79.1	79.4	77.5	74.9	69.2	67.3
		MCDB	70.0	72.8	75.0	79.4	84.7	87.9	90.0	89.6	86.9	82.3	74.2	71.7
	5%	WB	63.1	64.9	66.4	69.6	73.7	76.9	78.1	78.3	76.4	72.9	66.8	65.0
		MCDB	66.5	70.3	73.4	77.1	83.2	87.0	89.0	88.7	85.5	79.3	72.3	69.0
	10%	WB	60.1	62.3	64.4	68.1	72.4	75.9	77.2	77.3	75.1	70.9	64.3	62.3
		MCDB	64.4	67.1	71.2	75.7	81.8	85.8	87.8	87.8	83.7	76.7	69.5	65.6
Mean Daily Temperature Range	5% DB	MDBR	21.5	21.8	22.9	23.2	22.1	20.1	19.6	20.0	20.9	23.2	23.4	20.3
		MCDBR	22.0	22.7	24.3	23.4	24.2	22.6	22.6	23.0	23.6	24.6	25.0	21.1
		MCWBR	15.5	14.0	12.7	11.7	10.1	8.9	8.5	8.7	9.3	11.5	15.5	15.2
	5% WB	MCDBR	17.9	19.3	19.8	18.9	20.1	19.4	19.8	20.1	19.2	18.5	19.9	18.4
		MCWBR	14.4	13.3	12.1	11.0	9.3	8.8	8.6	8.7	8.3	10.3	14.2	14.6
Clear-Sky Solar Irradiance	taub	0.326	0.339	0.365	0.398	0.431	0.454	0.514	0.502	0.445	0.375	0.346	0.329	
	taud	2.526	2.486	2.422	2.336	2.277	2.258	2.111	2.143	2.275	2.444	2.472	2.528	
	Ebn at Noon	286	292	291	284	274	266	250	251	262	276	275	279	
	Edh at Noon	27	31	36	40	43	44	50	48	41	32	29	26	
All-Sky Solar Radiation	RadAvg	891	1069	1420	1774	1939	1947	1864	1776	1605	1366	1026	786	
	RadStd	78	152	115	142	118	146	109	120	115	169	95	81	