

JACKSON INTL, MS, USA

WMO: 722350

Lat: 32.321N

Lon: 90.078W

Elev: 330

StdP: 14.52

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03940

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.3	26.8	10.8	9.7	30.8	15.2	12.0	33.6	20.8	53.2	19.0	52.1	4.6	340	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	96.4	75.9	94.3	75.9	92.3	75.7	79.4	90.1	78.4	88.7	77.8	87.7	6.7	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.7	140.7	83.6	75.9	136.8	82.6	75.1	133.2	81.9	43.0	90.3	42.1	89.1	41.3	87.9	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	16.2	13.9	17.6	99.0	4.0	3.3	14.7	101.4	12.4	103.4	10.1	105.3	7.2	107.7
			15.9	80.9	3.8	1.2	13.1	81.7	10.9	82.4	8.7	83.1	6.0	83.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	47.0	50.9	57.8	65.0	73.0	79.5	81.8	81.7	76.8	66.3	55.7	49.2
	DBStd	14.68	10.79	10.32	9.20	7.32	5.76	3.77	3.07	3.48	5.35	7.95	8.76	10.17
	HDD50	519	190	104	36	2	0	0	0	0	0	1	43	143
	HDD65	2210	565	405	255	89	12	0	0	0	3	83	299	499
	CDD50	6164	95	130	278	453	713	884	986	983	804	507	212	119
	CDD65	2381	5	12	32	90	260	434	521	518	357	124	19	9
	CDH74	22850	10	63	234	755	2269	4312	5349	5335	3266	1102	122	33
	CDH80	9911	0	4	26	145	799	1983	2564	2624	1423	329	13	1
Wind	WSAvg	5.6	6.9	7.1	7.1	6.8	5.4	4.6	4.1	4.1	4.8	5.1	5.5	6.4
Precipitation	PrecAvg	56.1	5.1	4.8	5.8	5.7	4.8	3.7	4.7	4.2	3.6	3.3	4.6	5.4
	PrecMax	92.8	14.1	10.5	15.1	15.9	10.8	8.5	13.3	11.5	12.7	9.8	10.0	17.7
	PrecMin	34.8	0.7	1.3	0.9	1.2	0.3	0.1	1.0	0.3	0.0	0.0	0.5	0.9
	PrecStd	10.6	2.8	2.5	2.9	3.9	2.8	2.1	2.6	2.6	2.5	2.7	2.4	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.3	80.4	82.9	86.3	91.9	97.2	98.3	100.5	96.3	90.5	82.0	78.2
		MCWB	64.4	66.8	66.2	70.9	73.1	75.1	76.2	75.2	74.0	71.1	68.7	68.0
	2%	DB	71.8	75.5	79.8	83.8	89.0	94.2	95.6	96.7	93.4	86.7	77.5	73.4
		MCWB	63.2	63.9	65.0	68.6	72.9	75.3	76.9	76.1	74.1	70.8	66.2	65.8
	5%	DB	68.2	71.6	76.6	81.6	87.1	91.9	93.3	94.2	90.8	83.7	74.1	69.8
		MCWB	61.5	62.1	63.3	67.4	71.8	75.0	76.8	76.2	73.7	69.2	64.4	64.0
	10%	DB	64.4	67.9	73.1	78.7	85.0	89.8	91.4	91.8	88.2	80.6	70.9	66.1
		MCWB	59.3	60.7	62.0	65.8	70.8	74.8	76.6	76.3	73.0	67.6	62.9	61.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.8	69.2	70.0	74.1	76.9	79.2	80.8	80.5	78.4	76.4	71.7	70.0
		MCDB	72.0	75.0	76.2	81.8	86.4	90.4	91.6	91.6	87.9	83.4	77.2	75.0
	2%	WB	65.4	67.0	68.0	71.6	75.3	78.1	79.4	79.5	77.2	74.5	69.2	67.5
		MCDB	69.8	72.8	74.5	79.4	84.2	88.8	90.0	90.4	86.3	81.4	74.1	72.3
	5%	WB	63.3	64.9	66.3	70.1	74.0	77.3	78.4	78.5	76.2	72.8	67.2	65.1
		MCDB	67.0	70.3	73.1	77.4	82.7	87.5	88.8	88.6	84.9	79.7	72.2	69.1
	10%	WB	60.2	62.1	64.5	68.7	72.9	76.4	77.8	77.7	75.2	71.0	64.5	62.1
		MCDB	64.2	67.3	71.2	75.6	81.3	85.9	87.9	87.2	83.4	77.1	69.2	65.4
Mean Daily Temperature Range	5% DB	MDBR	20.1	20.9	21.8	22.1	20.4	19.4	18.9	19.6	20.8	22.8	22.5	20.0
		MCDBR	21.8	23.3	24.0	22.9	21.8	21.7	21.2	23.0	23.4	24.5	24.5	21.9
		MCWBR	14.4	13.4	11.9	10.2	8.1	6.9	6.5	6.7	7.8	10.5	14.2	14.7
	5% WB	MCDBR	17.7	20.0	19.5	18.8	18.3	18.8	19.0	18.9	18.4	18.4	20.0	18.9
		MCWBR	13.8	13.3	11.3	10.1	7.7	7.2	6.9	6.8	6.9	9.3	13.9	14.2
Clear-Sky Solar Irradiance	taub	0.325	0.332	0.365	0.397	0.430	0.453	0.500	0.501	0.434	0.371	0.345	0.326	
	taud	2.515	2.495	2.410	2.317	2.275	2.244	2.145	2.138	2.307	2.449	2.472	2.523	
	Ebn at Noon	285	293	290	284	273	266	253	251	264	276	274	278	
	Edh at Noon	27	30	36	41	43	44	49	48	39	32	28	26	
All-Sky Solar Radiation	RadAvg	862	1020	1398	1752	1931	2020	1930	1805	1600	1335	987	756	
	RadStd	77	155	105	134	114	143	104	137	119	180	96	77	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+259	+184
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+126

Nomenclature: See separate page