

HAWKINS FIELD, MS, USAWMO: **722354**Lat: **32.337N**Lon: **90.221W**Elev: **342**StdP: **14.52**Time Zone: **-6.00 (NAC)**Period: **01-19**WBAN: **13927****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	28.2	10.2	9.4	33.3	15.1	11.9	36.0	20.6	61.5	18.7	60.6	4.5	330	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	96.0	76.1	94.0	76.0	92.1	75.9	79.5	89.8	78.6	88.6	77.9	87.7	6.2	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.0	142.5	83.3	76.1	137.8	82.6	75.2	134.0	82.0	43.1	89.6	42.2	89.0	41.4	88.1	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	18.5	16.3	13.8	DB	19.1	98.8	4.2	2.8	16.1	100.9	13.6	102.5	11.3	104.1	8.2	106.1
(5)				WB	17.0	81.2	4.1	1.3	14.0	82.1	11.7	82.8	9.4	83.5	6.4	84.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	47.5	51.1	59.2	66.0	73.6	80.4	82.2	82.2	77.7	67.2	56.6	50.3
	DBStd	14.57	10.61	10.23	8.99	7.07	5.99	3.69	3.11	3.48	5.16	8.12	8.78	9.82
	HDD50	463	176	100	26	2	0	0	0	0	0	1	38	120
	HDD65	2070	547	401	220	73	13	0	0	0	2	75	273	466
	CDD50	6389	99	132	312	481	730	911	997	997	830	534	236	130
	CDD65	2519	5	13	41	101	278	461	532	532	381	143	21	11
	CDH74	24347	7	68	277	817	2373	4752	5585	5598	3506	1198	130	36
	CDH80	10286	0	6	30	160	832	2184	2596	2629	1467	369	12	1
Wind	WSAvg	5.8	6.6	7.1	7.0	7.1	6.0	5.0	4.6	4.4	4.6	5.1	5.6	6.5
Precipitation	PrecAvg	54.3	5.2	5.0	5.4	5.2	4.3	4.1	4.6	4.2	3.5	3.3	4.3	5.2
	PrecMax	67.0	11.6	9.0	12.1	16.9	9.1	7.1	9.6	11.0	11.5	10.2	8.5	9.0
	PrecMin	34.2	1.5	1.3	0.7	1.5	0.9	0.5	1.6	0.3	0.2	0.0	0.7	2.8
	PrecStd	8.1	2.4	2.2	2.4	3.6	2.3	1.8	2.0	2.7	2.5	2.6	2.0	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.0	80.6	83.0	86.5	91.5	97.5	97.8	99.2	95.7	90.7	81.6	78.2
		MCWB	63.2	67.2	66.1	70.5	73.4	75.4	75.9	76.8	74.3	71.6	68.0	68.2
	2%	DB	71.9	75.6	80.3	84.1	89.1	94.8	95.2	95.8	93.4	87.2	77.8	73.7
		MCWB	62.6	64.3	65.1	68.9	73.1	75.6	76.6	76.8	74.2	71.4	66.0	66.4
	5%	DB	68.0	71.5	77.3	81.8	87.2	92.2	93.0	93.5	90.9	84.2	74.4	70.3
		MCWB	60.9	62.0	63.6	67.4	72.1	75.4	76.7	76.6	74.4	69.3	63.9	64.5
	10%	DB	64.3	67.7	73.8	79.1	85.1	90.2	91.0	91.2	88.2	81.1	71.4	66.7
		MCWB	58.7	60.7	62.1	65.7	71.1	75.0	76.6	76.4	73.7	68.2	63.0	61.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.2	69.5	69.4	74.5	77.0	79.4	80.7	81.0	78.8	77.0	71.6	70.5
		MCDB	71.7	75.5	76.9	81.9	85.9	90.1	90.7	91.7	88.6	84.5	76.5	74.7
	2%	WB	64.9	67.3	67.6	71.5	75.5	78.3	79.4	79.7	77.5	75.0	69.3	67.8
		MCDB	69.4	72.7	74.7	80.2	84.5	88.8	89.8	90.0	86.8	82.0	73.7	72.4
	5%	WB	63.0	64.7	66.3	70.0	74.3	77.4	78.5	78.7	76.5	73.3	67.1	65.7
		MCDB	66.8	69.9	73.6	77.7	83.1	87.8	88.5	88.6	85.1	80.2	72.3	70.0
	10%	WB	59.7	61.5	64.7	68.6	73.1	76.6	77.8	77.9	75.5	71.6	64.7	62.6
		MCDB	64.1	67.1	71.9	75.9	81.7	86.5	87.5	87.4	83.3	77.6	69.3	66.0
Mean Daily Temperature Range	5% DB	MDBR	19.0	19.4	20.6	20.9	19.1	18.2	17.6	18.0	18.9	21.4	21.7	18.9
		MCDBR	20.9	22.7	23.0	22.6	20.4	20.5	19.8	20.4	21.3	23.0	23.8	21.0
		MCWBR	13.9	13.2	10.9	9.5	7.4	6.3	5.9	6.1	6.4	9.2	13.0	14.1
	5% WB	MCDBR	17.6	19.3	19.2	18.6	17.8	17.8	17.6	17.7	17.0	17.7	19.9	18.3
		MCWBR	13.8	13.5	10.5	9.8	7.5	6.7	6.3	6.4	6.1	8.8	13.8	13.9
Clear-Sky Solar Irradiance	taub	0.323	0.333	0.366	0.396	0.430	0.453	0.498	0.499	0.434	0.370	0.344	0.326	
	taud	2.520	2.495	2.408	2.316	2.273	2.243	2.150	2.143	2.307	2.451	2.475	2.522	
	Ebn at Noon	285	293	290	284	273	266	253	251	265	276	275	278	
	Edh at Noon	27	30	36	41	43	44	48	48	39	31	28	26	
All-Sky Solar Radiation	RadAvg	861	1017	1399	1753	1933	2027	1938	1812	1603	1336	987	756	
	RadStd	76	157	104	133	112	143	106	140	120	180	97	77	