

HAWKINS FIELD, MS, USA

WMO: 722354

Lat: 32.337N

Lon: 90.221W

Elev: 104

StdP: 100.08

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 13927

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.0	(c) -2.1	(d) -12.1	(e) 1.3	(f) 0.7	(g) -9.4	(h) 1.7	(i) 2.2	(j) 9.2	(k) 16.4	(l) 8.4	(m) 15.9	(n) 2.0	(o) 330	(p) 0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	35.6	24.5	34.4	24.4	33.4	24.4	26.4	32.1	25.9	31.4	25.5	30.9	2.8	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 25.0	(b) 20.4	(c) 28.5	(d) 24.5	(e) 19.7	(f) 28.1	(g) 24.0	(h) 19.1	(i) 27.8	(j) 82.4	(k) 32.0	(l) 80.4	(m) 31.7	(n) 78.5	(o) 31.1	(p) 28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.3	7.3	6.2	DB	-7.2	37.1	2.3	1.6	-8.9	38.3	-10.2	39.2	-11.5	40.1	-13.2	41.2
			WB	-8.3	27.3	2.3	0.7	-10.0	27.8	-11.3	28.2	-12.6	28.6	-14.2	29.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	8.6	10.6	15.1	18.9	23.1	26.9	27.9	27.9	25.4	19.6	13.7	10.2		
	DBStd	8.10	5.89	5.68	4.99	3.93	3.33	2.05	1.73	1.94	2.87	4.51	4.88	5.46		
	HDD10.0	257	98	56	14	1	0	0	0	0	0	1	21	67		
	HDD18.3	1150	304	223	122	41	7	0	0	0	1	42	152	259		
	CDD10.0	3549	55	73	173	267	406	506	554	554	461	297	131	72		
	CDD18.3	1399	3	7	23	56	154	256	296	296	212	79	12	6		
	CDH23.3	13526	4	38	154	454	1318	2640	3103	3110	1948	666	72	20		
	CDH26.7	5714	0	3	17	89	462	1213	1442	1461	815	205	7	1		
(14) Wind	WSAvg	2.6	3.0	3.2	3.1	3.2	2.7	2.2	2.1	2.0	2.1	2.3	2.5	2.9		
(15) Precipitation	PrecAvg	1379	131	128	137	133	109	103	116	106	88	85	110	132		
	PrecMax	1702	294	228	307	428	230	180	245	279	293	259	216	229		
	PrecMin	869	37	33	19	38	24	12	41	8	4	0	17	70		
	PrecStd	206	60	57	61	91	59	46	52	68	64	65	52	42		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	27.0	28.3	30.3	33.1	36.4	36.6	37.3	35.4	32.6	27.6	25.7		
		MCWB	17.3	19.6	18.9	21.4	23.0	24.1	24.4	24.9	23.5	22.0	20.0	20.1		
	2%	DB	22.1	24.2	26.8	28.9	31.7	34.9	35.1	35.4	34.1	30.7	25.4	23.2		
		MCWB	17.0	17.9	18.4	20.5	22.8	24.2	24.8	24.9	23.4	21.9	18.9	19.1		
	5%	DB	20.0	21.9	25.1	27.7	30.7	33.4	33.9	34.1	32.7	29.0	23.6	21.3		
		MCWB	16.0	16.7	17.5	19.6	22.3	24.1	24.8	24.8	23.6	20.7	17.7	18.0		
	10%	DB	17.9	19.8	23.2	26.2	29.5	32.3	32.8	32.9	31.2	27.3	21.9	19.3		
		MCWB	14.8	15.9	16.7	18.7	21.7	23.9	24.8	24.6	23.2	20.1	17.2	16.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.8	20.8	23.6	25.0	26.3	27.0	27.2	26.0	25.0	22.0	21.4		
		MCDB	22.1	24.1	24.9	27.7	29.9	32.3	32.6	33.2	31.4	29.2	24.7	23.7		
	2%	WB	18.3	19.6	19.8	21.9	24.1	25.7	26.4	26.5	25.3	23.9	20.7	19.9		
		MCDB	20.8	22.6	23.7	26.8	29.2	31.6	32.1	32.2	30.5	27.8	23.2	22.4		
	5%	WB	17.2	18.2	19.0	21.1	23.5	25.2	25.8	25.9	24.7	23.0	19.5	18.7		
		MCDB	19.3	21.1	23.1	25.4	28.4	31.0	31.4	31.4	29.5	26.8	22.4	21.1		
	10%	WB	15.4	16.4	18.2	20.3	22.9	24.8	25.4	25.5	24.2	22.0	18.1	17.0		
		MCDB	17.8	19.5	22.1	24.4	27.6	30.3	30.8	30.8	28.5	25.3	20.7	18.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	10.8	11.4	11.6	10.6	10.1	9.8	10.0	10.5	11.9	12.1	10.5		
		MCDBR	11.6	12.6	12.8	12.5	11.3	11.4	11.0	11.3	11.8	12.8	13.2	11.7		
	5% WB	MCWBR	7.7	7.3	6.0	5.3	4.1	3.5	3.3	3.4	3.6	5.1	7.2	7.9		
		MCWBR	9.8	10.7	10.7	10.3	9.9	9.8	9.8	9.8	9.4	9.8	11.0	10.2		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.333	0.366	0.396	0.430	0.453	0.498	0.499	0.434	0.370	0.344	0.326		
	taud		2.520	2.495	2.408	2.316	2.273	2.243	2.150	2.143	2.307	2.451	2.475	2.522		
	Ebn at Noon		900	925	914	894	862	838	799	792	834	870	866	876		
	Edh at Noon		85	96	113	129	136	140	152	152	124	99	89	81		
(44) All-Sky Solar Radiation	RadAvg		2.71	3.21	4.41	5.53	6.09	6.39	6.11	5.71	5.05	4.21	3.11	2.38		
	RadStd		0.24	0.49	0.33	0.42	0.35	0.45	0.33	0.44	0.38	0.57	0.30	0.24		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.59	+0.64	N/A	N/A	+201	N/A
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+70

Nomenclature: See separate page