

MCCOMB PIKE COUNTY AP, MS, USA

WMO: 722358

Lat: 31.183N

Lon: 90.471W

Elev: 126

StdP: 99.82

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93919

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.4	-1.6	-11.0	1.5	1.3	-8.3	1.9	3.5	9.2	11.4	8.4	11.3	2.0	350	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.5	35.1	24.5	33.9	24.3	32.9	24.3	26.4	31.6	25.8	30.9	25.5	30.4	2.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.5	28.3	24.6	19.9	27.9	24.1	19.3	27.5	82.5	31.5	80.4	30.9	78.5	30.3	33.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.0	5.8	DB	-7.0	36.8	2.2	1.7	-8.5	38.1	-9.8	39.1	-11.0	40.0	-12.5	41.3	(4)
(5)			WB	-7.9	27.7	2.1	1.7	-9.4	28.9	-10.7	29.9	-11.8	30.8	-13.3	32.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	9.7	11.9	15.4	18.9	23.1	26.4	27.3	27.4	25.2	19.9	14.2	10.9
	DBStd	7.54	5.69	5.57	4.83	3.78	2.99	1.90	1.45	1.68	2.53	4.24	4.63	5.46
	HDD10.0	199	77	40	12	1	0	0	0	0	0	1	14	55
	HDD18.3	1029	273	189	114	38	4	0	0	0	1	33	138	238
	CDD10.0	3569	67	93	179	267	407	492	537	540	456	308	140	83
	CDD18.3	1357	4	9	23	56	153	242	279	282	206	82	14	7
	CDH23.3	11954	7	39	142	416	1317	2260	2595	2697	1742	649	74	17
	CDH26.7	4968	0	3	12	68	473	1031	1199	1276	715	184	6	1
Wind	WSAvg	2.4	2.9	3.1	3.0	2.9	2.4	1.9	1.6	1.6	1.9	2.1	2.4	2.7
Precipitation	PrecAvg	1575	148	147	153	138	133	123	140	134	119	90	120	149
	PrecMax	2099	322	345	403	407	285	403	324	338	296	324	313	366
	PrecMin	936	21	26	39	5	14	16	41	38	23	0	10	78
	PrecStd	307	80	79	76	98	76	90	76	75	66	78	68	73
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	27.0	28.1	29.9	33.5	36.7	36.2	37.0	34.9	32.2	27.5	25.3
		MCWB	18.5	19.8	19.6	21.7	23.2	23.1	24.8	24.4	23.7	21.7	20.9	20.5
	2%	DB	22.4	24.4	26.6	28.5	31.9	34.2	34.6	35.0	33.2	30.4	25.4	23.3
		MCWB	17.9	18.4	18.9	20.7	22.7	23.6	24.8	24.7	23.4	21.8	19.4	19.9
	5%	DB	20.8	22.5	25.0	27.3	30.8	32.9	33.4	33.8	32.1	28.8	23.8	21.6
		MCWB	17.3	17.7	18.3	20.0	22.4	23.7	24.8	24.8	23.2	21.2	18.6	18.6
	10%	DB	18.8	20.8	23.2	26.0	29.5	31.9	32.4	32.6	30.8	27.2	22.2	19.9
		MCWB	16.2	17.1	17.6	19.2	21.9	23.8	24.8	24.8	23.1	20.4	18.1	17.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	21.2	22.2	23.6	25.5	26.3	27.3	27.2	26.0	25.0	22.8	22.4
		MCDB	22.4	23.8	25.1	27.5	30.9	31.4	32.7	32.3	30.3	28.7	24.9	23.7
	2%	WB	19.5	20.2	20.8	22.6	24.4	25.6	26.4	26.4	25.3	24.0	21.5	20.5
		MCDB	21.1	22.9	23.4	26.0	29.0	30.6	31.8	31.6	29.7	27.2	23.6	22.5
	5%	WB	18.2	19.1	20.0	21.8	23.7	25.2	25.8	25.9	24.7	23.1	20.4	19.4
		MCDB	19.8	21.7	23.0	25.0	28.0	30.0	31.0	30.9	29.1	26.3	22.7	21.0
	10%	WB	16.8	17.8	19.1	21.0	23.0	24.7	25.5	25.4	24.2	22.3	19.0	18.0
		MCDB	18.5	20.0	22.2	24.0	27.2	29.4	30.4	30.4	28.4	25.4	21.3	19.4
Mean Daily Temperature Range	5% DB	MDBR	11.5	11.7	12.2	12.2	11.6	10.8	10.3	10.5	10.8	12.2	12.3	11.1
		MCDBR	11.6	12.0	12.5	12.2	12.2	12.2	11.8	12.1	12.1	12.5	12.7	11.4
		MCWBR	7.9	6.9	6.4	5.6	4.6	4.0	4.0	4.0	4.3	5.4	7.4	7.9
	5% WB	MCDBR	9.5	10.2	10.0	9.7	10.5	10.3	10.4	10.5	9.9	9.6	10.5	9.6
		MCWBR	7.6	7.0	6.3	5.5	4.6	4.2	4.2	4.1	4.0	5.0	7.4	7.6
Clear-Sky Solar Irradiance	taub	0.324	0.343	0.363	0.399	0.428	0.455	0.499	0.497	0.440	0.372	0.346	0.331	
	taud	2.529	2.475	2.420	2.323	2.283	2.256	2.157	2.164	2.295	2.450	2.475	2.521	
	Ebn at Noon	906	918	920	893	865	837	799	797	831	873	871	878	
	Edh at Noon	86	99	112	129	135	138	152	149	126	101	90	83	
All-Sky Solar Radiation	RadAvg	2.81	3.35	4.49	5.60	6.10	6.09	5.87	5.57	5.05	4.34	3.25	2.49	
	RadStd	0.25	0.48	0.38	0.42	0.37	0.48	0.35	0.42	0.38	0.54	0.32	0.26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+136	+89

Nomenclature: See separate page