

POLK AAF, LA, USA

WMO: 722390

Lat: 31.050N

Lon: 93.183W

Elev: 101

StdP: 100.12

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03931

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	-0.9	-10.0	1.6	1.5	-7.5	2.0	4.2	9.3	12.6	8.4	12.4	2.9	10	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.3	36.1	24.0	34.8	24.3	33.7	24.3	26.3	31.1	25.9	30.6	25.6	30.3	3.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.6	27.7	24.9	20.2	27.5	24.4	19.6	27.2	82.2	31.1	80.4	30.7	78.9	30.3	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.4	6.5	DB	-5.7	37.7	2.1	2.2	-7.3	39.3	-8.5	40.6	-9.7	41.8	-11.3	43.4	(4)
			WB	-6.8	27.3	1.9	0.9	-8.2	27.9	-9.3	28.5	-10.4	28.9	-11.8	29.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	10.2	12.4	15.8	19.5	23.7	26.9	28.1	28.4	25.7	20.2	14.8	11.1
	DBStd	7.70	5.67	5.71	5.04	3.96	2.98	2.02	1.69	1.92	2.71	4.21	4.85	5.48
	HDD10.0	183	68	36	12	1	0	0	0	0	0	1	13	53
	HDD18.3	970	257	177	109	34	3	0	0	0	1	31	126	234
	CDD10.0	3751	75	104	191	286	424	508	562	569	471	317	156	87
	CDD18.3	1496	6	12	29	69	169	258	304	311	222	88	19	9
	CDH23.3	14003	8	38	151	481	1393	2541	3237	3336	1998	703	96	22
	CDH26.7	5949	0	1	14	89	484	1143	1523	1623	861	202	8	0
Wind	WSAvg	3.0	3.3	3.4	3.5	3.6	3.2	2.7	2.4	2.2	2.4	2.7	2.9	3.2
Precipitation	PrecAvg	1404	140	118	123	130	116	96	117	88	109	100	131	131
	PrecMax	2073	368	290	313	280	328	323	234	152	242	378	327	251
	PrecMin	774	18	22	18	28	2	5	25	15	24	0	16	46
	PrecStd	298	84	73	67	63	82	72	53	34	50	110	83	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.3	26.4	28.2	30.7	33.4	37.0	37.4	38.3	36.0	32.2	27.9	25.7
		MCWB	18.9	19.2	19.9	21.8	22.6	23.3	24.2	23.8	23.0	22.3	21.2	21.1
	2%	DB	22.6	24.5	26.7	28.9	32.0	34.8	35.6	36.2	34.1	30.6	25.9	23.6
		MCWB	18.1	18.4	19.4	20.8	22.7	24.0	24.5	24.2	23.3	22.0	20.0	20.2
	5%	DB	21.1	22.7	25.1	27.6	30.8	33.1	34.1	34.9	32.7	29.0	24.1	22.0
		MCWB	17.9	18.2	18.8	20.0	22.9	24.1	24.6	24.5	23.5	21.4	19.3	19.5
	10%	DB	19.4	21.1	23.3	26.3	29.6	32.2	33.0	33.6	31.4	27.4	22.6	20.2
		MCWB	16.5	17.8	18.2	19.4	22.4	24.0	24.7	24.6	23.2	20.7	18.9	18.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.3	22.6	23.8	25.3	26.5	26.8	26.9	26.2	25.2	23.0	22.3
		MCDB	22.7	23.6	24.8	27.1	29.9	30.4	31.5	31.8	30.3	28.5	25.3	24.0
	2%	WB	19.8	20.5	21.3	22.8	24.6	25.8	26.3	26.4	25.6	24.4	21.9	21.0
		MCDB	21.5	22.7	23.9	26.2	28.8	30.0	31.3	31.3	29.8	27.7	24.0	22.7
	5%	WB	18.7	19.6	20.5	22.1	24.0	25.5	25.8	25.9	25.1	23.7	20.9	20.2
		MCDB	20.6	21.7	23.2	25.5	27.9	29.8	30.7	30.8	29.2	26.8	23.2	21.8
	10%	WB	17.2	18.6	19.6	21.4	23.4	25.1	25.5	25.6	24.5	22.6	19.6	18.5
		MCDB	18.7	20.8	22.4	24.5	27.3	29.4	30.3	30.4	28.6	25.5	21.9	19.9
Mean Daily Temperature Range	5% DB	MDBR	10.7	11.0	11.2	11.3	10.5	10.0	9.9	10.3	10.6	11.6	11.1	10.2
		MCDBR	11.2	10.9	11.2	11.2	10.9	11.3	11.2	11.9	12.0	12.1	11.8	10.4
		MCWBR	7.5	6.2	5.7	4.7	3.6	3.1	2.9	3.0	3.7	5.0	6.8	7.1
	5% WB	MCDBR	9.4	9.3	9.6	9.1	9.4	9.4	9.7	10.0	9.6	9.5	9.9	9.3
		MCWBR	7.7	6.7	6.2	4.9	4.0	3.4	3.3	3.2	3.6	5.2	7.1	7.1
Clear-Sky Solar Irradiance	taub	0.329	0.347	0.369	0.407	0.439	0.485	0.488	0.484	0.440	0.369	0.356	0.341	
	taud	2.527	2.481	2.416	2.316	2.265	2.176	2.207	2.217	2.306	2.481	2.468	2.493	
	Ebn at Noon	901	914	914	886	855	813	808	808	832	878	860	865	
	Edh at Noon	86	99	113	130	137	150	144	141	125	98	91	86	
All-Sky Solar Radiation	RadAvg	2.78	3.14	4.38	5.36	5.94	6.02	5.97	5.66	4.99	4.25	3.18	2.44	
	RadStd	0.26	0.54	0.37	0.39	0.41	0.47	0.47	0.52	0.47	0.58	0.32	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)		+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+108	+76

Nomenclature: See separate page