

TYLER POUNDS, TX, USA

WMO: 722448

Lat: 32.354N

Lon: 95.403W

Elev: 544

StdP: 14.41

Time Zone: -6.00 (NAC)

Period: 98-19

WBAN: 13972

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.5	28.7	10.9	9.8	33.5	15.0	12.0	37.4	24.3	59.3	21.8	55.5	6.7	0	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.8	99.7	74.8	97.5	74.9	95.1	74.8	78.5	89.0	78.0	88.6	77.3	87.9	8.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.3	140.0	81.5	75.3	135.4	81.3	74.6	131.9	81.2	42.4	89.8	41.6	88.5	40.9	87.7	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.6	18.6	16.9	19.0	102.4	3.5	3.1	16.5	104.6	14.4	106.4	12.5	108.2	10.0	110.4		
			16.9	80.5	3.2	2.8	14.6	82.5	12.7	84.1	10.9	85.6	8.6	87.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.0	47.9	51.7	59.2	66.5	74.0	80.8	84.1	84.6	78.6	68.0	57.7	49.4
	DBStd	15.09	10.15	10.36	9.02	7.39	5.93	4.01	3.82	4.23	5.65	7.91	9.12	9.61
	HDD50	450	162	96	27	2	0	0	0	0	0	1	32	130
	HDD65	2024	535	384	221	69	9	0	0	0	1	62	250	493
	CDD50	6639	98	144	311	497	743	925	1058	1074	857	558	262	112
	CDD65	2738	6	12	40	114	287	475	593	609	408	154	31	9
	CDH74	29020	14	50	230	851	2468	5068	7161	7581	4156	1272	144	25
	CDH80	13525	0	3	27	176	854	2335	3693	4103	1919	401	14	0
Wind	WSAvg	8.1	8.7	9.2	9.4	9.7	8.7	7.8	7.2	6.7	6.3	7.2	7.9	8.3
Precipitation	PrecAvg	45.2	4.0	3.7	3.9	3.9	4.6	4.1	2.6	2.8	3.0	4.0	3.9	4.0
	PrecMax	61.5	9.6	8.8	8.1	8.4	9.9	9.4	11.3	8.5	8.3	13.2	12.1	9.0
	PrecMin	25.0	0.4	0.1	0.4	1.1	0.4	0.6	0.2	0.4	0.4	0.0	0.6	0.7
	PrecStd	9.6	2.4	2.2	1.9	2.0	2.5	2.7	2.4	1.7	2.0	3.1	2.5	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.4	79.2	83.0	88.5	93.4	99.7	102.0	104.1	99.5	91.4	82.1	77.3
		MCWB	62.5	63.3	65.4	70.7	73.2	74.5	74.5	74.3	72.0	70.6	68.2	66.4
	2%	DB	72.4	75.0	79.7	84.3	90.0	96.1	99.3	100.1	95.5	87.5	78.2	73.1
		MCWB	61.3	62.1	65.3	69.1	72.9	74.4	74.8	75.3	72.9	70.5	66.4	64.3
	5%	DB	68.7	71.8	76.4	81.7	87.4	92.9	96.6	98.0	92.7	84.6	74.8	69.8
		MCWB	60.4	61.9	63.0	67.8	72.6	74.9	75.4	75.3	73.2	69.0	64.6	62.9
	10%	DB	65.1	68.3	73.1	79.2	85.0	90.6	93.9	95.5	90.1	81.4	72.1	66.2
		MCWB	57.6	60.4	61.9	66.8	71.6	74.8	75.7	75.0	72.5	67.6	64.2	59.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.9	68.7	69.3	76.2	77.3	79.7	79.4	80.5	78.2	76.0	71.5	69.2
		MCDB	72.4	73.8	76.7	81.7	85.9	86.9	90.9	92.8	87.9	82.8	76.9	73.1
	2%	WB	64.6	66.5	67.8	72.7	75.7	78.2	78.4	78.4	77.0	74.3	69.4	66.7
		MCDB	69.4	71.4	74.7	80.0	84.4	87.6	89.6	89.6	86.3	81.6	74.5	71.7
	5%	WB	62.6	64.5	66.4	70.9	74.6	77.3	77.8	77.7	76.1	72.9	67.8	64.1
		MCDB	67.3	69.4	73.1	78.3	83.4	87.6	88.9	88.9	85.0	80.2	72.7	68.7
	10%	WB	59.1	62.1	64.6	69.3	73.4	76.4	77.2	77.0	75.2	71.3	65.6	60.8
		MCDB	63.9	67.5	71.4	76.4	82.1	86.2	88.0	88.3	83.8	77.9	71.0	65.4
Mean Daily Temperature Range	5% DB	MDBR	19.3	19.0	19.9	20.5	18.7	17.8	18.4	19.8	20.1	20.9	19.7	18.9
		MCDBR	23.2	21.6	21.7	21.5	20.3	20.7	21.3	22.8	22.3	22.4	20.8	21.6
		MCWBR	14.4	13.2	11.0	10.1	7.3	5.6	4.9	5.6	6.3	8.7	11.4	14.4
	5% WB	MCDBR	18.0	17.8	18.2	17.8	17.8	17.0	18.1	19.3	17.7	18.1	17.3	18.7
		MCWBR	14.1	13.8	11.6	10.5	8.4	6.1	5.6	5.7	5.7	8.8	12.4	15.0
Clear-Sky Solar Irradiance	taub		0.319	0.337	0.360	0.397	0.428	0.444	0.455	0.453	0.408	0.359	0.346	0.326
	taud		2.504	2.460	2.413	2.317	2.287	2.282	2.289	2.284	2.363	2.478	2.464	2.495
	Ebn at Noon		287	292	292	283	274	268	265	264	272	280	274	277
	Edh at Noon		27	31	36	41	43	43	42	42	37	31	28	26
All-Sky Solar Radiation	RadAvg		879	991	1372	1703	1842	2022	2056	1917	1617	1297	943	772
	RadStd		81	164	124	107	136	175	147	141	144	181	120	100

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page