

TYLER POUNDS, TX, USA

WMO: 722448

Lat: 32.354N

Lon: 95.403W

Elev: 166

StdP: 99.35

Time Zone: -6.00 (NAC)

Period: 98-19

WBAN: 13972

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.6	-1.8	-11.7	1.4	0.8	-9.5	1.7	3.0	10.9	15.2	9.7	13.0	3.0	0	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.0	37.6	23.8	36.4	23.8	35.0	23.8	25.8	31.6	25.5	31.4	25.2	31.1	3.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.6	20.0	27.5	24.1	19.3	27.4	23.6	18.8	27.3	80.8	32.1	78.9	31.4	77.4	31.0	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	8.3	7.5	-7.2	39.1	1.9	1.7	-8.6	40.4	-9.8	41.4	-10.8	42.3	-12.2	43.6		
			-8.4	26.9	1.8	1.5	-9.7	28.0	-10.7	28.9	-11.7	29.8	-13.0	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	8.9	11.0	15.1	19.2	23.3	27.1	29.0	29.2	25.9	20.0	14.3	9.7
	DBStd	8.39	5.64	5.75	5.01	4.10	3.29	2.23	2.12	2.35	3.14	4.40	5.07	5.34
	HDD10.0	250	90	53	15	1	0	0	0	0	0	1	18	72
	HDD18.3	1124	297	213	123	38	5	0	0	0	1	34	139	274
	CDD10.0	3688	54	80	173	276	413	514	588	597	476	310	146	62
	CDD18.3	1521	3	7	22	63	159	264	329	338	227	86	17	5
	CDH23.3	16122	8	28	128	473	1371	2816	3978	4212	2309	707	80	14
CDH26.7	7514	0	2	15	98	474	1297	2052	2279	1066	223	8	0	
Wind	WSAvg	3.6	3.9	4.1	4.2	4.3	3.9	3.5	3.2	3.0	2.8	3.2	3.5	3.7
Precipitation	PrecAvg	1148	101	95	100	100	116	103	67	70	75	101	98	101
	PrecMax	1563	245	223	205	213	252	239	286	216	210	336	307	229
	PrecMin	634	11	2	11	29	10	16	6	10	11	0	15	18
	PrecStd	244	62	57	48	50	64	69	60	44	51	78	64	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.6	26.2	28.3	31.4	34.1	37.6	38.9	40.1	37.5	33.0	27.8	25.2
		MCWB	16.9	17.4	18.5	21.5	22.9	23.6	23.6	23.5	22.2	21.4	20.1	19.1
	2%	DB	22.4	23.9	26.5	29.0	32.2	35.6	37.4	37.8	35.3	30.9	25.7	22.8
		MCWB	16.3	16.7	18.5	20.6	22.7	23.6	23.8	24.0	22.7	21.4	19.1	17.9
	5%	DB	20.4	22.1	24.6	27.6	30.8	33.8	35.9	36.6	33.7	29.2	23.8	21.0
		MCWB	15.8	16.6	17.2	19.9	22.5	23.8	24.1	24.1	22.9	20.5	18.1	17.2
	10%	DB	18.4	20.1	22.9	26.2	29.4	32.5	34.4	35.3	32.3	27.5	22.3	19.0
		MCWB	14.2	15.8	16.6	19.3	22.0	23.8	24.3	23.9	22.5	19.8	17.9	15.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	20.4	20.7	24.6	25.2	26.5	26.3	26.9	25.7	24.5	21.9	20.7
		MCDB	22.5	23.2	24.8	27.6	30.0	30.5	32.7	33.8	31.1	28.2	25.0	22.8
	2%	WB	18.1	19.2	19.9	22.6	24.3	25.7	25.8	25.8	25.0	23.5	20.8	19.3
		MCDB	20.8	21.9	23.7	26.6	29.1	30.9	32.0	32.0	30.2	27.5	23.6	22.0
	5%	WB	17.0	18.0	19.1	21.6	23.7	25.2	25.5	25.4	24.5	22.7	19.9	17.9
		MCDB	19.6	20.8	22.8	25.7	28.6	30.9	31.6	31.6	29.4	26.8	22.6	20.4
	10%	WB	15.0	16.7	18.1	20.7	23.0	24.7	25.1	25.0	24.0	21.8	18.6	16.0
		MCDB	17.7	19.7	21.9	24.7	27.8	30.1	31.1	31.3	28.8	25.5	21.7	18.5
Mean Daily Temperature Range	5% DB	MDBR	10.7	10.5	11.1	11.4	10.4	9.9	10.2	11.0	11.2	11.6	10.9	10.5
		MCDBR	12.9	12.0	12.1	11.9	11.3	11.5	11.8	12.7	12.4	12.4	11.5	12.0
		MCWBR	8.0	7.3	6.1	5.6	4.1	3.1	2.7	3.1	3.5	4.9	6.3	8.0
	5% WB	MCDBR	10.0	9.9	10.1	9.9	9.9	9.4	10.0	10.7	9.8	10.1	9.6	10.4
		MCWBR	7.8	7.6	6.5	5.8	4.6	3.4	3.1	3.1	3.2	4.9	6.9	8.4
Clear-Sky Solar Irradiance	taub	0.319	0.337	0.360	0.397	0.428	0.444	0.455	0.453	0.408	0.359	0.346	0.326	
	taud	2.504	2.460	2.413	2.317	2.287	2.282	2.289	2.284	2.363	2.478	2.464	2.495	
	Ebn at Noon	904	919	919	893	864	846	835	832	858	883	863	874	
	Edh at Noon	86	99	112	129	134	134	133	132	117	97	89	83	
All-Sky Solar Radiation	RadAvg	2.77	3.12	4.33	5.37	5.81	6.37	6.48	6.04	5.10	4.09	2.97	2.43	
	RadStd	0.26	0.52	0.39	0.34	0.43	0.55	0.46	0.44	0.45	0.57	0.38	0.32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	
Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page