

SHREVEPORT REGIONAL, LA, USA

WMO: 722480

Lat: 32.4511N

Lon: 93.8414W

Elev: 85

StdP: 100.30

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13957

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.4	-1.7	-11.7	1.4	0.2	-9.2	1.7	2.7	11.0	12.1	9.5	13.4	2.8	10	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.0	37.4	24.2	36.1	24.4	34.8	24.4	26.5	32.7	26.0	32.1	25.7	31.6	3.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.3	28.6	24.5	19.7	28.4	24.1	19.2	28.1	82.6	32.6	80.8	32.3	79.1	31.7	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.0	8.0	7.2	-6.8	39.0	1.8	1.8	-8.1	40.3	-9.2	41.3	-10.2	42.3	-11.6	43.6		
			-7.9	27.0	1.8	0.6	-9.2	27.5	-10.3	27.8	-11.3	28.1	-12.6	28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	9.0	11.0	15.0	18.9	23.4	27.2	28.8	28.9	25.8	19.8	13.9	9.7
	DBStd	8.32	5.69	5.68	5.07	4.04	3.21	2.13	1.89	2.31	3.14	4.32	4.94	5.35
	HDD10.0	248	89	51	16	1	0	0	0	0	0	1	18	72
	HDD18.3	1135	294	212	127	41	4	0	0	0	1	36	147	272
	CDD10.0	3651	57	79	169	269	416	514	582	587	474	303	136	64
	CDD18.3	1497	4	7	22	59	162	264	323	328	225	81	15	5
	CDH23.3	15841	12	38	157	470	1442	2822	3845	3974	2286	692	84	19
CDH26.7	7361	0	4	23	96	518	1325	1974	2117	1072	221	11	1	
Wind	WSAvg	3.2	3.6	3.7	3.8	3.8	3.4	2.9	2.7	2.5	2.7	2.8	3.1	3.3
Precipitation	PrecAvg	1234	103	104	108	110	121	110	91	70	85	105	110	116
	PrecMax	2082	329	234	326	555	299	435	270	234	244	517	275	286
	PrecMin	761	7	11	14	11	4	3	4	0	0	0	13	10
	PrecStd	295	67	52	58	89	81	87	62	51	64	87	63	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	27.1	29.0	30.9	33.9	37.2	38.7	40.0	37.8	33.0	28.2	25.6
		MCWB	17.6	17.9	19.7	21.9	23.1	24.2	24.0	23.8	23.0	22.4	20.9	19.9
	2%	DB	22.7	24.4	27.0	29.0	32.2	35.5	36.9	37.8	35.5	31.1	25.7	23.1
		MCWB	17.0	17.7	18.9	20.7	23.2	24.2	24.5	24.4	23.3	21.8	19.5	18.3
	5%	DB	20.6	22.2	25.1	27.7	31.0	33.9	35.5	36.3	33.9	29.3	23.8	21.0
		MCWB	16.3	17.1	17.7	20.0	22.9	24.3	24.9	24.6	23.3	21.0	18.5	17.7
	10%	DB	18.5	20.2	23.1	26.3	29.8	32.7	34.1	34.8	32.3	27.3	22.1	19.1
		MCWB	14.6	16.0	17.2	19.3	22.4	24.3	24.9	24.5	23.1	20.4	18.2	16.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.0	20.7	21.3	23.7	25.6	26.7	26.9	27.1	26.3	25.0	22.5	21.1
		MCDB	22.8	23.5	25.5	27.9	30.9	32.3	33.2	33.7	31.8	29.6	25.8	23.6
	2%	WB	18.7	19.5	20.4	22.5	24.6	26.0	26.4	26.5	25.4	24.0	21.2	19.8
		MCDB	21.4	22.7	24.5	26.7	29.7	31.6	32.8	32.9	30.9	28.1	24.1	22.2
	5%	WB	17.5	18.4	19.6	21.7	24.0	25.6	26.0	25.9	24.9	23.0	20.2	18.5
		MCDB	20.0	21.1	23.3	25.7	28.8	31.1	32.3	32.2	30.1	26.7	22.8	20.7
	10%	WB	15.6	16.9	18.4	20.8	23.3	25.1	25.6	25.5	24.3	22.1	18.7	16.5
		MCDB	17.7	19.6	22.4	24.7	28.2	30.5	31.7	31.6	29.3	25.4	21.4	18.9
Mean Daily Temperature Range	5% DB	MDBR	10.8	10.8	11.4	11.8	10.6	10.3	10.5	11.0	11.4	12.0	11.3	10.6
		MCDBR	13.3	12.8	13.1	12.3	11.4	11.7	12.0	12.8	13.0	13.2	12.7	12.5
		MCWBR	8.5	7.8	6.4	5.7	4.3	3.4	3.0	3.2	3.9	5.6	7.5	8.6
	5% WB	MCDBR	10.7	10.7	10.8	10.0	10.0	10.0	10.3	10.7	10.4	10.1	10.6	10.7
		MCWBR	8.3	7.8	6.9	5.6	4.4	3.7	3.5	3.4	3.7	5.4	7.7	8.4
Clear-Sky Solar Irradiance	taub	0.328	0.341	0.364	0.397	0.427	0.459	0.473	0.472	0.419	0.363	0.350	0.333	
	taud	2.505	2.473	2.416	2.323	2.296	2.248	2.240	2.236	2.350	2.482	2.469	2.498	
	Ebn at Noon	893	915	915	894	865	833	819	815	847	879	858	865	
	Edh at Noon	87	98	112	128	133	139	139	138	118	96	89	83	
All-Sky Solar Radiation	RadAvg	2.71	3.04	4.29	5.34	5.89	6.25	6.26	5.88	5.04	4.07	2.95	2.35	
	RadStd	0.26	0.51	0.38	0.34	0.43	0.47	0.47	0.50	0.45	0.56	0.33	0.30	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+117	+94
Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page