

SHREVEPORT DOWNTOWN, LA, USA

WMO: 722484

Lat: 32.543N

Lon: 93.745W

Elev: 179

StdP: 14.60

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 53905

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	29.6	11.7	10.0	34.0	16.2	12.6	37.2	21.4	60.3	19.4	60.0	4.4	20	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.7	99.2	76.3	96.8	76.3	94.5	76.2	79.6	91.4	78.8	90.2	78.1	89.1	6.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.7	140.1	83.7	75.8	136.0	83.2	75.2	133.0	82.9	43.1	91.5	42.3	90.4	41.6	89.5	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.8	16.7	14.8	20.3	101.9	2.7	3.1	18.4	104.1	16.8	106.0	15.3	107.7	13.4	110.0		
(5)			18.7	81.4	3.4	1.3	16.3	82.4	14.3	83.1	12.4	83.9	10.0	84.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.7	48.2	51.0	58.4	66.1	74.4	81.4	84.2	84.4	78.3	67.3	56.7	49.1
	DBStd	15.21	9.88	9.91	8.94	7.19	5.93	4.10	3.89	4.36	5.71	7.97	9.08	9.44
	HDD50	459	157	98	28	2	0	0	0	0	0	1	37	136
	HDD65	2097	526	402	239	72	8	0	0	0	1	70	277	502
	CDD50	6557	101	126	290	486	758	941	1059	1067	848	538	236	107
	CDD65	2723	6	10	36	106	301	491	594	602	400	142	27	8
	CDH74	29072	13	38	206	774	2699	5382	7213	7360	4013	1202	144	28
	CDH80	13395	0	2	21	138	966	2524	3671	3871	1817	367	17	1
(14) Wind	WSAvg	6.4	6.9	7.4	7.8	8.0	7.2	6.3	5.8	5.2	4.7	5.2	6.0	6.5
(15) Precipitation	PrecAvg	48.6	4.1	4.1	4.3	4.3	4.8	4.3	3.6	2.8	3.3	4.1	4.3	4.6
	PrecMax	82.0	13.0	9.2	12.8	21.9	11.8	17.1	10.6	9.2	9.6	20.4	10.8	11.3
	PrecMin	30.0	0.3	0.4	0.6	0.4	0.2	0.1	0.2	0.0	0.0	0.0	0.5	0.4
	PrecStd	11.6	2.6	2.0	2.3	3.5	3.2	3.4	2.4	2.0	2.5	3.4	2.5	2.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.8	78.6	82.6	87.4	93.2	99.3	101.8	104.3	99.0	90.7	82.4	77.7
		MCWB	63.6	64.1	66.9	71.8	74.1	76.2	75.9	75.1	73.9	71.6	69.9	67.9
	2%	DB	72.4	74.5	79.3	83.6	90.2	96.3	98.8	99.7	95.1	87.5	78.2	73.1
		MCWB	62.4	64.1	66.4	69.7	73.6	75.9	76.8	76.4	74.5	71.9	67.4	65.2
	5%	DB	68.8	70.9	75.9	81.3	88.0	93.3	95.8	97.0	92.3	84.2	74.5	69.7
		MCWB	61.3	61.6	64.1	68.3	73.0	75.9	76.9	76.6	74.5	70.1	65.5	63.6
	10%	DB	65.0	67.4	72.8	79.0	85.7	91.0	93.3	94.5	89.7	81.1	71.6	65.7
		MCWB	58.5	60.1	63.1	66.7	72.0	75.7	76.9	76.4	74.0	69.0	64.4	60.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.3	68.4	70.0	74.8	77.6	80.0	80.7	80.7	79.0	77.1	72.1	69.4
		MCDB	72.9	74.7	77.8	82.7	87.8	91.1	91.7	93.2	89.4	84.8	78.7	74.6
	2%	WB	65.2	66.3	68.5	72.4	76.2	78.6	79.5	79.6	77.8	75.2	69.9	67.5
		MCDB	70.2	71.8	75.7	79.8	85.8	89.5	91.5	91.7	87.6	82.9	75.6	71.8
	5%	WB	63.3	64.2	66.9	70.9	75.0	77.9	78.7	78.7	76.9	73.5	68.0	65.0
		MCDB	67.4	69.2	73.5	78.0	84.3	88.7	90.2	90.2	86.3	79.9	73.1	69.0
	10%	WB	59.7	61.6	64.9	69.4	73.8	77.1	78.1	78.0	76.0	71.8	65.4	60.8
		MCDB	64.2	66.3	71.6	76.3	82.9	87.5	89.2	89.0	84.7	78.0	70.4	65.1
(35) Mean Daily Temperature Range	5% DB	MDBR	18.8	18.7	19.2	19.9	18.6	17.5	17.6	18.7	20.0	21.1	19.7	18.6
		MCDBR	22.9	21.8	20.6	20.8	19.9	20.0	20.1	21.5	22.2	22.8	22.0	22.4
		MCWBR	15.0	13.9	10.8	9.8	7.4	5.6	4.9	5.6	6.6	9.5	12.8	15.7
	5% WB	MCDBR	18.5	18.2	17.7	16.8	17.2	17.1	17.5	18.2	17.7	17.4	18.5	19.5
		MCWBR	14.4	13.6	11.4	10.0	7.5	6.2	5.8	5.8	6.1	9.4	13.1	15.8
(40) Clear-Sky Solar Irradiance	taub		0.330	0.342	0.366	0.398	0.428	0.462	0.476	0.475	0.421	0.364	0.351	0.334
	taud		2.500	2.470	2.409	2.321	2.296	2.244	2.233	2.229	2.349	2.479	2.467	2.493
	Ebn at Noon		282	290	289	283	274	264	259	258	268	278	272	274
	Edh at Noon		28	31	36	41	42	44	44	44	37	31	28	26
(44) All-Sky Solar Radiation	RadAvg		855	962	1360	1693	1867	1984	1985	1864	1596	1288	933	743
	RadStd		83	161	120	107	136	150	148	159	143	176	104	95

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page