

SHREVEPORT DOWNTOWN, LA, USA

WMO: 722484

Lat: 32.543N

Lon: 93.745W

Elev: 55

StdP: 100.67

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 53905

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.9	-1.3	-11.3	1.4	1.1	-8.8	1.8	2.9	9.6	15.7	8.7	15.5	2.0	20	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.4	37.4	24.6	36.0	24.6	34.7	24.6	26.4	33.0	26.0	32.3	25.6	31.7	2.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.0	28.7	24.4	19.4	28.4	24.0	19.0	28.3	82.3	33.0	80.5	32.4	78.9	32.0	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.5	6.6	-6.5	38.8	1.5	1.7	-7.6	40.1	-8.4	41.1	-9.3	42.1	-10.3	43.3		
(5)			-7.4	27.5	1.9	0.7	-8.7	28.0	-9.8	28.4	-10.9	28.8	-12.2	29.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	9.0	10.6	14.7	19.0	23.6	27.4	29.0	29.1	25.7	19.6	13.7	9.5
	DBStd	8.45	5.49	5.51	4.97	3.99	3.29	2.28	2.16	2.42	3.17	4.43	5.04	5.24
	HDD10.0	255	87	54	16	1	0	0	0	0	0	1	21	76
	HDD18.3	1165	292	223	133	40	4	0	0	0	1	39	154	279
	CDD10.0	3643	56	70	161	270	421	523	588	593	471	299	131	59
	CDD18.3	1513	3	6	20	59	167	273	330	334	222	79	15	4
	CDH23.3	16151	7	21	114	430	1499	2990	4007	4089	2229	668	80	16
	CDH26.7	7442	0	1	12	77	537	1402	2039	2151	1009	204	9	1
Wind	WSAvg	2.9	3.1	3.3	3.5	3.6	3.2	2.8	2.6	2.3	2.1	2.3	2.7	2.9
Precipitation	PrecAvg	1234	103	104	108	110	121	110	91	70	85	105	110	116
	PrecMax	2082	329	234	326	555	299	435	270	234	244	517	275	286
	PrecMin	761	7	11	14	11	4	3	4	0	0	0	13	10
	PrecStd	295	67	52	58	89	81	87	62	51	64	87	63	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	25.9	28.1	30.8	34.0	37.4	38.8	40.2	37.2	32.6	28.0	25.4
		MCWB	17.6	17.8	19.4	22.1	23.4	24.6	24.4	23.9	23.3	22.0	21.1	20.0
	2%	DB	22.4	23.6	26.3	28.7	32.3	35.7	37.1	37.6	35.1	30.8	25.7	22.8
		MCWB	16.9	17.8	19.1	21.0	23.1	24.4	24.9	24.7	23.6	22.2	19.7	18.4
	5%	DB	20.4	21.6	24.4	27.4	31.1	34.0	35.4	36.1	33.5	29.0	23.6	20.9
		MCWB	16.3	16.4	17.8	20.2	22.8	24.4	25.0	24.8	23.6	21.2	18.6	17.5
	10%	DB	18.3	19.7	22.7	26.1	29.8	32.8	34.1	34.7	32.1	27.3	22.0	18.7
		MCWB	14.7	15.6	17.3	19.3	22.2	24.3	24.9	24.7	23.3	20.6	18.0	15.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.2	21.1	23.8	25.3	26.7	27.0	27.1	26.1	25.0	22.3	20.8
		MCDB	22.7	23.7	25.5	28.2	31.0	32.8	33.2	34.0	31.9	29.3	26.0	23.7
	2%	WB	18.4	19.0	20.3	22.5	24.5	25.9	26.4	26.4	25.4	24.0	21.0	19.7
		MCDB	21.2	22.1	24.3	26.6	29.9	32.0	33.0	33.2	30.9	28.3	24.2	22.1
	5%	WB	17.4	17.9	19.4	21.6	23.9	25.5	26.0	25.9	25.0	23.1	20.0	18.3
		MCDB	19.7	20.7	23.0	25.6	29.0	31.5	32.4	32.4	30.2	26.6	22.8	20.6
	10%	WB	15.4	16.4	18.3	20.8	23.2	25.0	25.6	25.6	24.4	22.1	18.6	16.0
		MCDB	17.9	19.1	22.0	24.6	28.3	30.8	31.8	31.7	29.3	25.6	21.3	18.4
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.4	10.7	11.1	10.3	9.7	9.8	10.4	11.1	11.7	10.9	10.3
		MCDBR	12.7	12.1	11.5	11.6	11.1	11.1	11.1	11.9	12.3	12.6	12.2	12.4
		MCWBR	8.3	7.7	6.0	5.4	4.1	3.1	2.7	3.1	3.7	5.3	7.1	8.7
	5% WB	MCDBR	10.3	10.1	9.8	9.3	9.6	9.5	9.7	10.1	9.8	9.7	10.3	10.9
		MCWBR	8.0	7.6	6.4	5.6	4.2	3.4	3.2	3.2	3.4	5.2	7.3	8.8
Clear-Sky Solar Irradiance	taub	0.330	0.342	0.366	0.398	0.428	0.462	0.476	0.475	0.421	0.364	0.351	0.334	
	taud	2.500	2.470	2.409	2.321	2.296	2.244	2.233	2.229	2.349	2.479	2.467	2.493	
	Ebn at Noon	890	913	912	892	864	831	817	813	846	877	856	863	
	Edh at Noon	87	98	113	128	133	139	140	139	118	97	89	83	
All-Sky Solar Radiation	RadAvg	2.69	3.03	4.29	5.34	5.89	6.25	6.26	5.88	5.03	4.06	2.94	2.34	
	RadStd	0.26	0.51	0.38	0.34	0.43	0.47	0.47	0.50	0.45	0.56	0.33	0.30	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page