

MONROE, LA, USA

WMO: 722486

Lat: 32.516N

Lon: 92.041W

Elev: 79

StdP: 14.65

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13942

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.9	28.1	12.1	10.2	30.5	17.4	13.3	34.7	23.1	53.5	20.1	51.7	5.4	10	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	98.3	77.7	95.8	77.4	93.7	77.1	80.9	91.6	80.1	90.8	79.2	89.7	5.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.3	147.4	85.3	77.3	142.3	84.5	76.5	138.4	83.8	44.4	91.7	43.4	90.8	42.6	89.5	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.9	16.8	14.8	DB	19.5	100.8	3.5	3.1	17.0	103.0	14.9	104.9	13.0	106.6	10.4	108.9	
			WB	17.7	82.5	3.4	2.0	15.2	83.9	13.2	85.1	11.3	86.2	8.8	87.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	47.3	51.0	58.3	66.1	74.2	80.5	82.9	82.9	77.5	66.7	56.2	49.2	
	DBStd	14.96	10.52	10.34	9.16	7.27	5.87	3.92	3.36	3.84	5.46	7.83	8.80	9.95	
	HDD50	497	181	104	32	1	0	0	0	0	0	1	38	140	
	HDD65	2146	554	404	243	73	8	0	0	0	2	77	285	500	
	CDD50	6388	97	132	289	485	749	914	1019	1019	824	520	225	115	
	CDD65	2561	5	12	36	107	292	464	554	554	376	130	22	9	
	CDH74	26172	13	66	256	893	2682	4858	6198	6180	3633	1201	156	36	
	CDH80	11996	0	5	34	190	1013	2319	3105	3231	1686	391	21	1	
Wind	WSAvg	6.0	7.2	7.6	7.5	7.3	6.3	5.2	4.6	4.5	4.9	5.1	5.8	6.6	
Precipitation	PrecAvg	53.0	4.8	5.0	5.1	4.6	5.6	4.4	3.7	2.8	3.5	3.7	4.4	5.2	
	PrecMax	78.6	12.4	10.3	12.5	18.5	16.3	11.5	10.8	7.7	12.2	10.8	10.2	16.1	
	PrecMin	32.8	0.5	1.2	0.7	0.2	0.3	0.6	0.5	0.2	0.7	0.0	1.0	0.7	
	PrecStd	12.2	3.2	2.3	2.5	3.4	3.8	2.8	2.4	1.8	2.5	2.9	2.6	3.0	
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.9	80.2	83.8	87.9	93.0	99.4	99.9	102.2	98.5	91.0	82.8	78.5
MCWB			65.1	66.4	67.6	72.5	75.0	77.6	77.8	78.4	75.4	72.1	69.4	68.1	
2%		DB	72.4	75.7	80.2	84.4	90.4	95.5	97.1	98.7	94.9	87.6	78.6	73.5	
		MCWB	63.1	65.1	66.7	70.2	74.1	77.4	78.5	77.9	75.1	71.4	66.9	66.7	
5%		DB	68.5	71.9	76.9	82.1	88.4	92.9	94.9	95.8	92.3	84.5	74.7	70.1	
		MCWB	61.7	63.3	64.7	68.5	73.4	76.9	78.3	77.4	75.0	70.0	65.1	64.3	
10%		DB	64.4	68.1	73.4	79.5	86.0	90.8	92.8	93.4	89.5	81.2	71.5	66.1	
		MCWB	58.9	61.3	63.6	67.2	72.7	76.3	78.1	77.3	74.3	68.6	64.0	61.2	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures		0.4%	WB	68.5	69.6	71.1	75.3	78.4	81.3	82.3	82.2	79.9	77.3	72.4	70.5
			MCDB	73.3	75.7	78.6	83.1	88.2	91.6	92.6	92.4	89.3	85.5	77.8	75.0
	2%	WB	65.7	67.6	69.1	73.1	76.8	79.8	81.0	80.9	78.3	75.3	70.0	67.8	
		MCDB	70.3	73.4	76.5	80.4	85.7	90.1	91.3	92.1	88.4	82.8	75.1	72.3	
	5%	WB	63.4	65.3	67.4	71.5	75.6	78.8	80.1	80.0	77.3	73.5	67.8	65.6	
		MCDB	67.1	70.3	74.6	79.1	84.5	88.7	90.7	91.0	87.1	79.8	73.4	69.6	
	10%	WB	60.0	62.5	65.3	69.9	74.5	77.9	79.2	78.9	76.2	71.7	65.1	61.9	
		MCDB	63.9	67.6	72.0	76.6	83.0	87.5	89.8	89.6	85.0	77.5	69.9	65.9	
	Mean Daily Temperature Range	5% DB	MDBR	19.1	19.4	20.5	21.3	19.8	18.9	19.0	20.5	21.6	23.3	21.7	18.9
			MCDBR	22.9	22.9	23.4	22.5	21.4	21.4	21.4	23.7	24.6	25.7	25.1	21.8
MCWBR			15.2	14.2	12.2	10.3	7.8	7.0	6.8	7.1	8.4	11.5	14.6	15.3	
5% WB		MCDBR	18.7	19.6	19.8	18.8	18.2	18.6	19.1	20.2	20.1	19.4	20.8	19.0	
		MCWBR	14.4	13.8	12.4	10.2	7.8	7.2	7.2	7.3	7.6	10.6	14.5	14.5	
Clear-Sky Solar Irradiance	taub	0.327	0.342	0.371	0.408	0.440	0.488	0.496	0.495	0.436	0.368	0.348	0.329		
	taud	2.512	2.469	2.394	2.283	2.251	2.154	2.159	2.159	2.301	2.462	2.470	2.512		
	Ebn at Noon	284	290	288	280	271	257	254	252	264	277	272	276		
	Edh at Noon	27	31	36	42	44	49	48	47	39	31	28	26		
All-Sky Solar Radiation	RadAvg	849	976	1376	1719	1902	2024	1980	1840	1591	1311	958	744		
	RadStd	79	167	110	122	121	143	126	153	142	181	102	88		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page