

MONROE, LA, USA

WMO: 722486

Lat: 32.516N

Lon: 92.041W

Elev: 24

StdP: 101.04

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13942

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.2	-11.0	1.5	-0.8	-8.1	1.9	1.5	10.3	11.9	9.0	11.0	2.4	10	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	36.8	25.4	35.5	25.2	34.3	25.1	27.2	33.1	26.7	32.6	26.2	32.1	2.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.1	29.6	25.1	20.3	29.2	24.7	19.8	28.8	85.3	33.1	83.1	32.7	81.2	31.9	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.5	6.6	-7.0	38.2	1.9	1.7	-8.4	39.5	-9.5	40.5	-10.6	41.5	-12.0	42.7		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-7.9	28.1	1.9	1.1	-9.3	28.9	-10.4	29.5	-11.5	30.1	-12.9	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	8.5	10.6	14.6	19.0	23.4	26.9	28.3	28.3	25.3	19.3	13.5	9.5
	DBStd	8.31	5.84	5.74	5.09	4.04	3.26	2.18	1.87	2.14	3.03	4.35	4.89	5.53
	HDD10.0	276	101	58	18	1	0	0	0	0	0	1	21	78
	HDD18.3	1192	308	224	135	41	4	0	0	0	1	43	158	278
	CDD10.0	3549	54	73	161	269	416	508	566	458	289	125	64	
	CDD18.3	1423	3	7	20	59	162	258	308	308	209	72	12	5
	CDH23.3	14540	7	37	142	496	1490	2699	3443	3433	2018	667	87	20
	CDH26.7	6664	0	3	19	106	563	1288	1725	1795	937	217	12	1
Wind	WSAvg	2.7	3.2	3.4	3.4	3.3	2.8	2.3	2.1	2.0	2.2	2.3	2.6	2.9
Precipitation	PrecAvg	1347	123	126	130	118	141	111	93	70	89	95	111	133
	PrecMax	1997	316	261	318	470	414	291	274	196	310	275	260	408
	PrecMin	834	13	30	18	6	7	15	12	5	17	0	25	19
	PrecStd	310	81	58	64	86	96	71	61	45	63	74	66	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	26.8	28.8	31.0	33.9	37.5	37.7	39.0	36.9	32.8	28.2	25.8
		MCWB	18.4	19.1	19.8	22.5	23.9	25.3	25.4	25.8	24.1	22.3	20.8	20.1
	2%	DB	22.4	24.3	26.8	29.1	32.4	35.3	36.2	37.1	35.0	30.9	25.9	23.1
		MCWB	17.3	18.4	19.3	21.2	23.4	25.2	25.8	25.5	24.0	21.9	19.4	19.3
	5%	DB	20.3	22.2	25.0	27.8	31.3	33.8	35.0	35.5	33.5	29.2	23.7	21.2
		MCWB	16.5	17.4	18.1	20.3	23.0	24.9	25.7	25.2	23.9	21.1	18.4	18.0
	10%	DB	18.0	20.1	23.0	26.4	30.0	32.6	33.8	34.1	32.0	27.3	21.9	19.0
		MCWB	14.9	16.3	17.6	19.5	22.6	24.6	25.6	25.2	23.5	20.3	17.8	16.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	20.9	21.7	24.1	25.8	27.4	27.9	27.9	26.6	25.2	22.4	21.4
		MCDB	22.9	24.3	25.9	28.4	31.2	33.1	33.7	33.6	31.9	29.7	25.4	23.9
	2%	WB	18.7	19.8	20.6	22.8	24.9	26.6	27.2	27.1	25.7	24.0	21.1	19.9
		MCDB	21.3	23.0	24.7	26.9	29.9	32.3	33.0	33.4	31.3	28.2	23.9	22.4
	5%	WB	17.4	18.5	19.6	21.9	24.2	26.0	26.7	26.6	25.2	23.1	19.9	18.6
		MCDB	19.5	21.3	23.7	26.1	29.2	31.5	32.6	32.8	30.6	26.6	23.0	20.9
	10%	WB	15.5	16.9	18.5	21.0	23.6	25.5	26.2	26.1	24.5	22.0	18.4	16.6
		MCDB	17.7	19.8	22.2	24.8	28.3	30.8	32.1	32.0	29.5	25.3	21.0	18.9
Mean Daily Temperature Range	5% DB	MDBR	10.6	10.8	11.4	11.8	11.0	10.5	10.6	11.4	12.0	12.9	12.0	10.5
		MCDBR	12.7	12.7	13.0	12.5	11.9	11.9	11.9	13.2	13.7	14.3	13.9	12.1
		MCWBR	8.5	7.9	6.8	5.7	4.4	3.9	3.8	4.0	4.6	6.4	8.1	8.5
	5% WB	MCDBR	10.4	10.9	11.0	10.5	10.1	10.3	10.6	11.2	11.2	10.8	11.6	10.5
		MCWBR	8.0	7.7	6.9	5.7	4.4	4.0	4.0	4.1	4.2	5.9	8.0	8.1
Clear-Sky Solar Irradiance	taub	0.327	0.342	0.371	0.408	0.440	0.488	0.496	0.495	0.436	0.368	0.348	0.329	
	taud	2.512	2.469	2.394	2.283	2.251	2.154	2.159	2.159	2.301	2.462	2.470	2.512	
	Ebn at Noon	894	913	908	883	854	809	800	796	831	872	859	870	
	Edh at Noon	86	99	114	133	139	153	151	149	124	98	89	82	
All-Sky Solar Radiation	RadAvg	2.67	3.08	4.34	5.42	6.00	6.38	6.24	5.80	5.02	4.13	3.02	2.34	
	RadStd	0.25	0.53	0.35	0.39	0.38	0.45	0.40	0.48	0.45	0.57	0.32	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page