

TERRELL, TX, USA

WMO: 722489

Lat: 32.710N

Lon: 96.267W

Elev: 145

StdP: 99.60

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53911

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.5	-2.5	-12.5	1.3	0.1	-9.9	1.6	2.4	10.9	11.8	9.7	13.4	2.8	0	0.462

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.5	38.0	23.6	37.0	23.8	35.7	23.7	25.8	32.7	25.4	32.3	25.1	31.8	3.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.3	28.0	23.7	18.8	27.8	23.1	18.2	27.4	80.0	32.8	78.3	32.3	76.7	31.7	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.5	7.7	-8.0	40.1	2.1	1.8	-9.5	41.4	-10.7	42.4	-11.9	43.4	-13.4	44.7		
			-9.1	26.5	1.9	0.7	-10.5	27.0	-11.6	27.4	-12.7	27.8	-14.1	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	8.1	10.2	14.7	18.8	23.3	27.5	29.2	29.6	25.8	19.8	13.9	9.0
	DBStd	8.72	5.47	5.76	5.04	4.09	3.45	2.20	1.95	2.39	3.25	4.50	5.25	5.28
	HDD10.0	291	102	63	17	1	0	0	0	0	1	23	83	
	HDD18.3	1214	319	233	133	44	6	0	0	0	1	37	149	293
	CDD10.0	3644	43	68	162	264	411	524	596	606	475	304	138	53
	CDD18.3	1526	2	4	19	57	159	274	338	348	226	82	16	3
	CDH23.3	17129	8	25	109	408	1436	3082	4285	4523	2420	730	88	14
	CDH26.7	8376	0	2	11	78	511	1485	2331	2549	1158	240	11	1
(14) Wind	WSAvg	3.6	3.7	3.9	4.2	4.2	3.9	3.6	3.2	2.9	2.9	3.2	3.5	3.6
(15) Precipitation	PrecAvg	992	76	73	97	87	121	86	46	59	73	117	88	87
	PrecMax	1391	214	169	211	217	336	259	119	164	236	333	242	220
	PrecMin	587	7	4	9	14	18	16	0	0	6	7	10	8
	PrecStd	228	45	43	51	50	70	62	35	42	47	90	57	56
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.5	26.2	28.1	31.0	34.5	37.4	39.0	40.2	38.1	33.1	28.1	25.2
		MCWB	16.0	17.6	18.3	21.2	22.9	23.5	23.3	22.7	22.1	22.3	19.5	17.9
	2%	DB	22.2	23.6	26.1	28.7	32.5	35.8	37.5	38.6	35.6	31.3	25.9	22.4
		MCWB	15.9	16.2	18.3	20.6	23.0	23.5	23.9	23.5	23.0	21.5	18.8	17.0
	5%	DB	19.9	21.7	24.3	27.3	31.1	34.3	36.4	37.4	34.0	29.4	23.9	20.3
		MCWB	14.8	16.2	17.4	20.0	22.6	23.6	24.0	23.9	22.8	20.4	17.9	16.1
	10%	DB	17.7	19.5	22.6	25.9	29.5	33.0	35.1	36.1	32.6	27.5	22.2	18.0
		MCWB	13.5	15.1	16.8	19.2	22.1	23.8	24.1	23.7	22.5	19.9	17.3	14.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.2	19.9	21.0	23.8	25.4	26.4	26.3	26.2	25.5	24.4	21.9	20.2
		MCDB	21.6	23.7	25.2	28.2	30.4	32.1	33.8	33.8	31.7	29.0	25.2	22.7
	2%	WB	18.0	18.7	19.8	22.4	24.5	25.6	25.7	25.6	24.9	23.6	20.5	18.7
		MCDB	20.2	21.8	23.4	26.6	29.5	31.6	33.1	33.1	31.2	28.2	23.3	21.4
	5%	WB	16.4	17.7	19.0	21.5	23.9	25.1	25.3	25.2	24.4	22.8	19.5	17.1
		MCDB	19.3	19.9	22.7	25.3	28.8	31.1	32.6	32.6	30.4	27.0	22.7	19.4
	10%	WB	13.7	15.9	18.0	20.6	23.2	24.7	25.0	24.8	23.9	21.8	18.2	15.1
		MCDB	16.7	19.2	21.6	24.1	28.1	30.5	32.0	32.0	29.6	25.4	21.4	17.8
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	10.9	11.2	11.3	10.6	10.2	11.1	11.5	11.6	12.0	11.3	11.0
		MCDBR	14.3	13.3	12.1	12.0	11.7	11.6	12.5	13.3	12.8	13.3	12.5	13.2
	5% WB	MCWBR	9.0	8.4	6.6	6.1	4.6	3.3	3.0	3.0	3.8	5.5	6.9	8.8
		MCWBR	11.6	11.1	10.2	9.7	9.8	9.6	10.7	11.3	10.6	10.2	9.9	11.2
(40) Clear-Sky Solar Irradiance	taub		0.317	0.334	0.359	0.396	0.428	0.440	0.444	0.446	0.400	0.359	0.340	0.322
		taud	2.496	2.458	2.406	2.323	2.291	2.289	2.317	2.298	2.376	2.474	2.470	2.486
	Ebn at Noon		904	921	919	894	864	849	843	838	865	881	867	876
		Edh at Noon	87	99	113	128	133	133	129	130	115	97	88	83
(44) All-Sky Solar Radiation	RadAvg		2.81	3.23	4.36	5.33	5.76	6.46	6.60	6.09	5.13	4.04	2.99	2.48
	RadStd		0.27	0.51	0.36	0.37	0.47	0.60	0.45	0.41	0.45	0.59	0.38	0.32

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page