

CORPUS CHRISTI INTL, TX, USA

WMO: 722510

Lat: 27.774N

Lon: 97.512W

Elev: 13

StdP: 101.16

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12924

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	3.4	-7.4	2.0	8.8	-4.9	2.5	9.1	14.1	21.3	12.7	19.9	4.9	0	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.2	36.1	25.5	35.2	25.5	34.4	25.5	27.4	32.0	26.9	31.4	26.7	31.1	6.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	28.5	26.0	21.4	28.4	25.6	20.9	28.3	86.3	32.0	84.7	31.6	83.3	30.9	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.4	11.3	10.3	-1.6	38.4	1.9	1.7	-3.0	39.6	-4.1	40.6	-5.2	41.5	-6.6	42.8		
			-3.4	28.2	1.8	0.5	-4.7	28.5	-5.8	28.8	-6.8	29.1	-8.1	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	14.4	16.5	19.4	22.9	26.1	28.4	29.1	29.6	27.6	23.9	19.1	15.2
	DBStd	6.51	5.18	5.23	4.42	3.41	2.37	1.45	1.25	1.31	2.24	3.74	4.71	5.18
	HDD10.0	46	19	9	2	0	0	0	0	0	0	0	3	13
	HDD18.3	456	142	87	42	7	0	0	0	0	0	6	48	124
	CDD10.0	4686	156	192	293	386	498	552	592	607	528	432	275	176
	CDD18.3	2054	20	36	75	143	239	302	333	349	278	180	70	29
	CDH23.3	21126	103	184	364	985	2269	3526	4066	4379	2994	1639	472	146
	CDH26.7	8936	13	32	68	265	774	1594	1988	2230	1293	558	102	18
Wind	WSAvg	5.1	5.3	5.7	6.0	6.3	5.8	4.8	4.7	4.5	4.0	4.6	5.0	5.0
Precipitation	PrecAvg	800	38	45	37	50	84	88	51	86	137	92	47	44
	PrecMax	1221	150	206	124	234	238	339	303	376	516	306	189	249
	PrecMin	372	0	0	0	0	0	1	0	5	12	1	2	2
	PrecStd	218	32	42	36	52	61	80	61	76	103	83	41	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.3	29.8	31.1	33.5	33.9	36.2	36.6	37.3	37.2	33.8	31.1	28.6
		MCWB	19.5	20.6	21.1	21.6	24.8	25.8	25.7	25.2	24.8	25.1	23.1	21.5
	2%	DB	25.9	27.5	28.4	31.1	32.6	34.6	35.5	36.2	34.8	32.4	29.2	26.6
		MCWB	19.6	20.4	21.2	22.4	24.7	25.6	25.6	25.7	25.1	24.8	22.7	20.7
	5%	DB	24.2	25.7	26.9	29.4	31.5	33.6	34.7	35.4	33.6	31.2	27.8	24.9
		MCWB	18.8	20.0	20.8	22.2	24.7	25.6	25.6	25.7	25.1	24.2	22.0	20.4
	10%	DB	22.3	23.7	25.4	28.0	30.5	32.7	33.9	34.6	32.4	29.9	26.2	23.2
		MCWB	18.5	19.0	20.1	21.9	24.4	25.6	25.6	25.6	25.1	23.6	21.2	20.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	22.9	23.6	25.5	27.1	27.9	27.9	27.6	27.5	26.9	25.1	23.6
		MCDB	25.1	27.0	27.6	30.0	31.4	32.5	32.5	32.9	31.8	30.2	28.7	26.0
	2%	WB	21.4	22.0	22.8	24.6	26.3	27.2	27.2	27.1	26.9	26.3	24.1	22.7
		MCDB	23.9	25.3	26.3	28.2	30.1	31.6	31.9	32.1	31.0	29.7	27.0	24.9
	5%	WB	20.6	21.3	22.2	24.0	25.7	26.8	26.8	26.8	26.5	25.6	23.3	21.8
		MCDB	23.0	24.0	25.1	27.3	29.4	30.9	31.4	31.6	30.6	29.1	26.1	23.8
	10%	WB	19.5	20.6	21.6	23.4	25.3	26.4	26.4	26.4	26.1	25.1	22.5	20.7
		MCDB	21.7	22.8	24.1	26.4	28.9	30.3	30.9	31.1	30.1	28.5	25.2	22.8
Mean Daily Temperature Range	5% DB	MDBR	10.8	10.5	9.7	9.6	8.7	9.0	9.6	10.2	9.3	10.2	10.4	10.5
		MCDBR	12.8	12.1	10.3	10.4	9.7	10.1	10.9	11.3	10.8	10.2	11.2	11.9
		MCWBR	7.7	6.5	5.0	4.6	3.6	3.1	3.0	2.9	3.6	4.2	5.8	7.4
	5% WB	MCDBR	9.9	9.5	8.4	8.1	7.9	8.3	9.3	9.8	8.7	8.5	9.3	9.7
		MCWBR	6.7	5.7	4.5	3.9	3.4	3.1	3.2	2.9	3.3	4.3	5.8	7.0
Clear-Sky Solar Irradiance	taub	0.358	0.365	0.385	0.430	0.470	0.447	0.459	0.449	0.439	0.392	0.377	0.349	
	taud	2.464	2.448	2.389	2.272	2.190	2.315	2.301	2.326	2.320	2.446	2.438	2.504	
	Ebn at Noon	884	907	906	871	831	846	834	842	842	867	855	877	
	Edh at Noon	96	105	118	137	149	130	132	128	125	104	98	89	
All-Sky Solar Radiation	RadAvg	3.01	3.55	4.50	5.36	5.97	6.63	6.56	6.27	5.19	4.51	3.39	2.70	
	RadStd	0.32	0.60	0.49	0.51	0.44	0.33	0.54	0.35	0.45	0.48	0.35	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+101	
Regional (30 neighbors)	N/A	N/A	N/A	+0.35	N/A	N/A	N/A	N/A	N/A	+125	+109

Nomenclature: See separate page