

ALICE, TX, USA

WMO: 722517

Lat: 27.741N

Lon: 98.025W

Elev: 53

StdP: 100.69

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12932

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.2	2.9	-9.2	1.7	9.4	-6.4	2.2	11.1	11.8	18.2	10.9	18.1	3.7	0	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	38.2	24.7	37.2	24.8	36.1	24.7	27.0	32.9	26.6	32.2	26.2	31.6	5.6	140

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.6	28.2	25.4	20.7	27.9	25.1	20.3	27.8	85.2	33.3	83.2	32.0	81.6	31.3	34.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.7	9.3	8.5	-1.9	40.5	1.9	1.7	-3.3	41.8	-4.4	42.8	-5.5	43.7	-6.9	45.0
			-3.5	28.7	1.6	1.7	-4.7	29.9	-5.7	30.9	-6.6	31.9	-7.8	33.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.0	14.5	16.6	19.7	23.3	26.7	29.1	29.8	30.1	27.7	23.9	19.0	15.1
	DBStd	6.80	5.32	5.50	4.74	3.71	2.75	1.67	1.64	1.56	2.28	3.84	4.77	5.27
	HDD10.0	48	20	10	2	0	0	0	0	0	0	0	2	13
	HDD18.3	465	142	90	42	6	0	0	0	0	0	7	49	129
	CDD10.0	4792	158	194	303	399	518	573	615	624	532	431	272	173
	CDD18.3	2168	23	41	84	156	260	323	357	366	282	179	68	30
	CDH23.3	22832	169	309	589	1299	2594	3768	4314	4448	2910	1690	543	198
	CDH26.7	10958	33	93	182	508	1153	1944	2333	2432	1396	689	153	41
Wind	WSAvg	4.3	4.2	4.5	4.8	5.0	5.0	4.5	4.4	4.0	3.4	3.7	3.9	3.9
Precipitation	PrecAvg	689	30	39	31	38	77	83	49	71	127	80	43	32
	PrecMax	1085	102	115	121	182	243	320	158	353	477	277	210	164
	PrecMin	330	0	0	0	0	0	0	0	0	7	0	0	0
	PrecStd	184	24	31	29	41	55	72	43	70	107	78	40	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.8	32.3	33.6	36.3	37.1	38.9	39.7	39.8	38.4	35.0	32.2	30.1
		MCWB	19.3	19.5	20.4	22.2	24.2	24.9	24.6	24.6	23.7	23.9	22.5	20.9
	2%	DB	27.4	29.4	30.6	33.2	35.0	37.0	37.8	38.3	36.2	33.4	30.2	27.6
		MCWB	18.7	19.7	20.6	22.0	24.6	25.1	24.7	24.8	24.3	23.9	21.8	20.0
	5%	DB	25.1	27.3	28.6	31.4	33.5	35.7	36.8	37.2	34.8	32.2	28.4	25.7
		MCWB	17.8	19.1	20.5	22.1	24.4	24.9	24.9	24.9	24.3	23.5	21.2	19.3
	10%	DB	22.8	24.9	26.9	29.7	32.3	34.4	35.6	36.0	33.2	30.8	26.7	23.3
		MCWB	17.3	18.4	19.7	21.3	24.1	24.9	24.9	24.9	24.3	22.8	20.3	19.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	22.3	23.4	25.6	27.4	27.9	27.4	27.3	27.1	26.5	24.5	22.9
		MCDB	25.7	27.9	28.9	31.8	33.0	33.9	34.4	34.2	32.2	30.7	28.2	26.0
	2%	WB	20.9	21.5	22.5	24.5	26.3	27.0	26.7	26.7	26.4	25.7	23.6	21.9
		MCDB	24.0	26.1	27.3	30.0	32.1	32.6	33.1	32.9	30.9	29.8	27.1	25.3
	5%	WB	20.1	20.8	21.8	23.8	25.6	26.5	26.3	26.2	26.0	25.2	22.8	21.2
		MCDB	23.1	24.4	25.8	28.5	30.9	31.5	32.2	32.1	30.5	29.3	26.1	24.1
	10%	WB	18.9	20.2	21.3	23.1	25.1	26.0	25.8	25.8	25.6	24.6	21.9	20.1
		MCDB	22.1	23.2	24.8	27.1	29.9	30.8	31.3	31.4	30.1	28.4	25.4	22.7
Mean Daily Temperature Range	5% DB	MDBR	12.2	12.3	11.7	12.1	11.0	11.4	11.9	12.3	11.1	12.1	12.0	11.6
		MCDBR	14.5	14.7	13.2	13.3	12.2	12.9	13.6	13.9	13.1	12.6	13.1	13.6
		MCWBR	7.7	6.8	5.6	5.2	4.0	3.4	3.1	3.1	3.7	4.7	6.0	7.4
	5% WB	MCDBR	11.1	11.5	10.7	10.9	10.3	10.5	11.6	12.0	10.4	10.5	10.6	11.4
		MCWBR	6.7	6.1	5.2	4.6	3.9	3.5	3.3	3.1	3.5	4.7	5.6	7.3
Clear-Sky Solar Irradiance	taub	0.351	0.359	0.379	0.423	0.458	0.438	0.443	0.439	0.429	0.383	0.369	0.343	
	taud	2.458	2.439	2.387	2.280	2.217	2.332	2.333	2.345	2.336	2.452	2.437	2.496	
	Ebn at Noon	891	913	912	877	842	853	848	851	851	876	863	884	
	Edh at Noon	97	106	118	136	145	128	128	126	123	104	98	89	
All-Sky Solar Radiation	RadAvg	3.06	3.64	4.57	5.43	5.96	6.65	6.60	6.35	5.22	4.52	3.41	2.75	
	RadStd	0.34	0.63	0.54	0.54	0.51	0.32	0.54	0.34	0.47	0.51	0.37	0.40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	+0.34	N/A	N/A	N/A	N/A	+119	+105

Nomenclature: See separate page