

KERRVILLE, TX, USA

WMO: 722537

Lat: 29.983N

Lon: 99.083W

Elev: 493

StdP: 95.54

Time Zone: -6.00 (NAC)

Period: 02-19

WBAN: 12961

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.2	(c) -2.3	(d) -14.9	(e) 1.1	(f) 9.3	(g) -11.9	(h) 1.4	(i) 9.2	(j) 11.0	(k) 10.9	(l) 9.4	(m) 10.8	(n) 2.3	(o) 350	(p) 0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 12.4	(c) 37.0	(d) 21.4	(e) 36.1	(f) 21.7	(g) 34.5	(h) 22.0	(i) 25.0	(j) 31.2	(k) 24.5	(l) 30.3	(m) 24.0	(n) 29.6	(o) 4.1	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.5	19.5	27.1	23.0	18.8	26.5	22.6	18.4	26.3	78.8	31.3	76.6	30.5	74.7	29.6	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.2	(b) 8.2	(c) 7.5	(e) -7.5	(f) 38.8	(g) 2.1	(h) 1.3	(i) -9.0	(j) 39.8	(k) -10.2	(l) 40.5	(m) -11.4	(n) 41.2	(o) -12.9	(p) 42.1		
(a) 9.2	(b) 8.2	(c) 7.5	(e) -8.5	(f) 25.8	(g) 1.7	(h) 1.0	(i) -9.8	(j) 26.6	(k) -10.8	(l) 27.1	(m) -11.7	(n) 27.7	(o) -13.0	(p) 28.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	9.0	11.5	15.6	19.2	23.1	26.7	27.8	28.2	24.8	19.9	14.2	10.1		
	DBStd	7.82	4.92	5.64	4.70	3.87	3.52	2.17	1.88	1.86	2.89	4.37	5.02	4.72		
	HDD10.0	209	78	44	10	1	0	0	0	0	1	18	57			
	HDD18.3	1072	292	197	108	35	6	0	0	0	1	35	141	258		
	CDD10.0	3576	46	87	184	277	405	501	552	564	445	308	144	61		
	CDD18.3	1394	2	6	24	62	153	251	294	306	195	83	17	3		
	CDH23.3	14023	21	73	189	537	1319	2582	3150	3469	1843	706	109	24		
(14) Wind	WSAvg	3.1	2.7	3.2	3.6	3.8	3.7	3.6	3.1	2.7	2.3	2.6	2.8	2.7		
	PrecAvg	843	45	48	75	64	96	92	89	62	94	92	60	47		
	PrecMax	1363	95	143	240	195	231	290	483	260	246	256	174	333		
	PrecMin	411	1	1	16	3	20	0	2	2	16	8	0	4		
	PrecStd	256	35	39	50	47	50	77	112	59	57	64	54	70		
	DB	26.0	28.8	29.4	33.0	36.0	37.4	38.0	37.7	36.4	33.1	28.4	26.1			
	MCWB	14.2	15.5	15.6	17.8	20.7	22.0	21.5	21.3	20.6	20.7	18.6	15.7			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	22.7	25.9	27.4	30.0	33.0	36.0	36.3	37.0	34.4	30.3	26.2	23.2			
	2% MCWB	13.9	14.6	16.2	18.1	21.3	21.7	21.7	21.5	21.3	20.5	18.0	15.2			
	5% DB	20.4	22.8	25.5	27.9	31.6	34.0	35.6	36.1	33.3	28.7	24.8	22.0			
	5% MCWB	13.8	14.5	16.6	18.1	21.3	22.1	21.9	21.9	21.4	20.5	17.2	15.2			
	10% DB	17.8	20.7	23.2	26.3	29.2	32.8	33.7	34.5	31.5	27.5	22.4	18.8			
	10% MCWB	13.1	14.8	16.0	17.8	20.9	22.2	22.5	22.2	21.4	19.4	16.9	14.4			
	WB	19.1	20.0	21.1	23.2	25.2	25.8	25.5	25.4	24.7	24.1	22.3	20.5			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	21.6	23.7	24.1	27.1	30.5	32.4	32.2	32.0	30.5	28.5	25.2	23.3			
	2% WB	17.6	18.7	20.0	21.9	23.9	24.8	24.8	24.6	24.1	23.2	20.9	18.9			
	2% MCDB	19.6	22.1	23.5	25.4	28.6	30.8	31.1	30.8	29.4	27.2	22.8	21.3			
	5% WB	16.0	17.4	19.2	21.1	23.1	24.1	24.2	24.1	23.5	22.5	19.8	17.1			
	5% MCDB	18.4	19.9	22.8	24.7	27.9	29.7	30.2	30.0	28.5	26.1	22.6	19.2			
	10% WB	13.9	16.0	18.2	20.3	22.5	23.5	23.8	23.7	23.0	21.7	18.7	15.6			
	10% MCDB	16.7	18.8	21.5	24.0	27.0	28.8	29.4	29.5	27.7	25.0	21.8	17.9			
(35) Mean Daily Temperature Range	MDBR	13.4	13.4	13.0	13.0	11.5	11.6	11.4	12.4	12.0	13.0	13.1	13.7			
	5% DB MCDBR	17.5	16.4	14.7	15.0	14.0	13.5	13.8	14.1	14.2	13.1	14.4	17.3			
	5% WB MCWBR	9.9	9.0	7.6	7.0	5.2	3.7	3.6	3.5	4.4	5.6	8.1	10.5			
	5% DB MCDBR	12.0	11.5	10.4	10.3	10.3	10.6	11.1	11.7	10.5	9.8	10.2	12.1			
	5% WB MCWBR	8.8	8.2	6.7	6.0	4.8	3.8	3.5	3.5	3.7	5.3	6.9	9.7			
(40) Clear-Sky Solar Irradiance	taub	0.311	0.319	0.340	0.380	0.413	0.410	0.420	0.407	0.394	0.360	0.338	0.310			
	taud	2.532	2.510	2.466	2.369	2.329	2.388	2.401	2.417	2.399	2.481	2.479	2.538			
	Ebn at Noon	928	950	947	913	879	876	867	877	879	891	887	911			
	Edh at Noon	87	97	108	123	129	121	119	116	114	98	91	82			
(44) All-Sky Solar Radiation	RadAvg	3.13	3.73	4.67	5.55	5.84	6.72	6.71	6.37	5.22	4.30	3.29	2.79			
	RadStd	0.35	0.59	0.45	0.53	0.64	0.50	0.58	0.36	0.51	0.61	0.41	0.37			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page