

GEORGETOWN, TX, USA

WMO: 722547

Lat: 30.679N

Lon: 97.679W

Elev: 787

StdP: 14.28

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 53942

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.3	28.3	10.4	9.7	35.6	15.7	12.5	39.2	25.0	57.7	23.0	58.6	6.0	0	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.2	99.2	73.2	97.2	73.5	95.1	74.0	77.4	89.5	76.7	88.5	76.0	87.4	8.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.5	132.8	80.9	73.4	128.1	80.1	73.0	126.0	80.0	41.2	89.6	40.5	88.4	39.9	87.4	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.9	18.8	17.0	DB	19.7	103.7	3.0	3.6	17.5	106.3	15.7	108.3	14.0	110.4	11.8	113.0
			WB	17.3	78.6	2.7	1.5	15.4	79.7	13.9	80.6	12.4	81.4	10.4	82.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	49.5	52.7	58.9	66.8	75.1	80.4	83.5	84.4	78.6	69.3	58.5	50.2
	DBStd	14.66	9.69	10.18	9.31	7.61	5.92	3.93	3.31	3.25	5.84	8.41	9.21	9.28
	HDD50	382	129	81	30	2	0	0	0	0	0	2	26	112
	HDD65	1918	487	361	232	70	6	0	0	0	3	56	236	467
	CDD50	6730	113	155	305	506	779	911	1038	1066	858	599	281	119
	CDD65	2790	6	15	42	124	320	461	573	601	411	188	41	8
	CDH74	30052	32	112	284	1002	2914	4903	6926	7562	4359	1660	262	36
	CDH80	14260	5	28	42	269	1138	2240	3671	4157	2100	570	38	2
Wind	WSAvg	7.6	8.0	8.1	8.5	9.1	8.4	7.7	7.5	6.8	6.0	6.7	7.4	7.4
Precipitation	PrecAvg	36.3	2.6	2.4	2.9	3.0	4.1	3.9	2.0	2.4	3.5	3.8	3.0	2.8
	PrecMax	52.8	6.9	7.9	6.9	9.2	7.8	9.6	7.8	6.7	10.6	9.8	9.6	11.8
	PrecMin	19.4	0.0	0.1	0.0	0.4	0.4	0.5	0.0	0.1	0.5	0.0	0.0	0.3
	PrecStd	8.8	1.8	1.9	1.5	2.0	2.0	2.4	1.8	2.0	2.6	3.0	2.6	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	82.5	84.1	91.4	96.0	97.2	101.6	100.7	102.1	91.4	84.0	78.7
		MCWB	58.7	62.2	64.8	70.5	72.8	75.3	72.3	73.4	71.9	71.5	68.5	63.4
	2%	DB	73.1	77.0	80.8	86.1	92.0	94.2	98.9	99.3	96.8	89.8	80.8	73.4
		MCWB	60.3	61.7	64.5	67.1	72.0	74.7	73.1	73.6	72.6	70.9	66.1	61.2
	5%	DB	70.2	72.8	77.3	82.3	89.7	91.9	96.8	97.4	93.1	86.3	76.9	70.4
		MCWB	59.7	61.3	63.4	66.9	72.2	74.1	73.5	73.8	72.7	70.5	65.5	60.8
	10%	DB	66.2	69.8	73.1	80.5	86.5	90.5	93.6	95.5	90.6	82.4	73.3	66.3
		MCWB	58.4	61.1	61.7	65.9	71.7	74.0	73.4	74.6	72.4	68.5	64.6	59.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.9	68.4	69.6	73.6	77.4	78.9	77.9	78.1	77.3	76.2	72.4	68.1
		MCDB	70.8	74.1	78.3	83.7	87.1	90.3	91.3	91.9	87.5	84.3	78.7	72.6
	2%	WB	64.5	66.9	68.0	71.6	75.6	77.4	76.9	77.1	76.3	74.8	70.5	66.0
		MCDB	69.4	72.0	75.3	80.4	85.2	88.8	89.6	90.4	86.2	82.6	76.3	70.8
	5%	WB	62.6	65.1	66.6	70.1	74.5	76.5	76.1	76.3	75.4	73.5	68.3	63.4
		MCDB	67.6	69.7	73.3	78.4	83.9	87.3	88.2	89.2	85.2	80.9	74.4	68.8
	10%	WB	59.5	62.6	64.8	68.6	73.3	75.4	75.3	75.6	74.6	72.1	66.5	60.1
		MCDB	65.8	68.3	71.1	76.4	82.4	85.4	87.0	88.1	84.4	79.7	72.4	65.4
Mean Daily Temperature Range	5% DB	MDBR	21.7	20.9	21.1	22.0	19.3	18.6	20.1	21.2	21.3	21.2	21.2	21.6
		MCDBR	26.3	25.3	24.1	23.9	21.8	20.3	23.3	23.6	23.6	22.4	23.4	25.1
		MCWBR	16.6	15.1	13.1	11.3	7.6	6.2	5.3	5.5	6.8	9.2	13.1	16.2
	5% WB	MCDBR	19.6	18.7	19.3	17.9	18.0	17.6	19.2	20.2	18.8	17.9	17.6	19.7
		MCWBR	15.0	13.8	12.6	10.1	8.2	6.4	5.6	5.4	6.3	8.5	11.7	15.1
Clear-Sky Solar Irradiance	taub	0.318	0.331	0.356	0.398	0.438	0.425	0.438	0.427	0.402	0.371	0.350	0.318	
	taud	2.515	2.483	2.423	2.328	2.264	2.345	2.343	2.359	2.379	2.449	2.448	2.522	
	Ebn at Noon	291	296	294	284	272	274	270	272	276	278	275	285	
	Edh at Noon	28	31	36	41	43	40	40	39	37	32	30	26	
All-Sky Solar Radiation	RadAvg	957	1109	1438	1727	1834	2099	2122	1997	1650	1344	1011	844	
	RadStd	101	193	131	154	165	153	168	107	147	194	120	112	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+131

Nomenclature: See separate page