

KILLEEN SKYLARK, TX, USA

WMO: 722575

Lat: 31.083N

Lon: 97.683W

Elev: 256

StdP: 98.28

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03972

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.6	-1.8	-12.8	1.3	0.6	-10.1	1.6	2.9	11.3	13.6	10.3	13.6	3.8	0	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	37.9	23.4	37.2	23.5	36.1	23.6	25.6	33.3	25.2	32.8	24.8	32.2	4.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.6	19.0	28.1	23.0	18.3	27.8	22.7	18.0	27.7	79.6	33.4	77.8	32.9	76.3	31.8	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.8	8.8	8.1	DB	-6.3	39.5	1.8	1.3	-7.5	40.4	-8.6	41.2	-9.6	41.9	-10.9	42.8	(4)
			WB	-7.8	26.4	1.8	0.7	-9.1	26.9	-10.2	27.3	-11.2	27.7	-12.5	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	9.8	11.8	15.5	19.7	24.1	27.6	29.3	29.4	26.0	20.7	14.8	10.2
	DBStd	8.25	5.44	5.87	5.19	4.06	3.31	2.14	1.88	2.04	3.31	4.34	5.17	5.35
	HDD10.0	209	71	43	14	1	0	0	0	0	0	1	16	63
	HDD18.3	1026	269	192	116	32	3	0	0	2	27	128	257	
	CDD10.0	3841	64	94	185	293	437	528	597	602	479	331	160	69
	CDD18.3	1616	3	9	28	74	182	278	339	344	231	99	22	6
	CDH23.3	18028	28	71	204	609	1688	3185	4353	4444	2453	825	138	29
	CDH26.7	8944	3	16	38	178	686	1594	2439	2503	1184	276	23	2
Wind	WSAvg	3.9	3.8	4.1	4.4	4.7	4.5	4.1	3.7	3.4	3.1	3.5	3.7	3.6
Precipitation	PrecAvg	891	60	63	78	71	112	92	54	58	81	94	73	65
	PrecMax	1211	143	189	232	150	273	246	156	204	214	280	256	225
	PrecMin	550	7	2	0	12	27	13	0	2	9	11	7	5
	PrecStd	201	39	46	47	40	58	57	41	59	54	69	63	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.9	28.9	29.8	33.0	35.9	37.8	39.1	39.2	38.7	33.0	29.0	26.8
		MCWB	16.0	16.4	18.4	20.5	22.6	23.7	23.2	23.4	22.2	22.2	20.0	17.7
	2%	DB	23.2	25.7	27.6	31.0	33.7	36.3	37.8	37.9	36.1	32.0	27.1	23.6
		MCWB	15.4	16.4	18.2	20.3	23.0	23.9	23.4	23.6	23.0	22.1	19.0	16.7
	5%	DB	21.2	22.9	26.0	28.7	32.3	34.8	37.1	37.3	34.0	29.8	24.8	21.4
		MCWB	15.0	16.0	17.7	19.9	22.7	23.9	23.5	23.7	22.8	20.8	18.3	16.0
	10%	DB	18.8	21.1	23.6	27.2	30.9	33.2	35.9	36.1	32.6	27.7	22.7	19.0
		MCWB	14.2	15.9	16.9	19.2	22.5	23.7	23.7	23.8	22.6	20.0	17.6	14.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.3	20.3	21.3	23.6	25.5	26.2	26.0	25.8	25.6	24.5	22.5	20.5
		MCDB	22.9	23.9	26.3	29.8	32.1	33.6	33.8	34.3	32.5	30.0	26.3	23.6
	2%	WB	18.0	19.1	20.2	22.4	24.6	25.5	25.3	25.3	24.9	23.5	21.0	19.0
		MCDB	21.0	22.2	24.6	28.2	30.7	32.8	33.3	33.7	31.7	28.5	24.6	21.9
	5%	WB	16.6	18.0	19.4	21.5	23.9	25.0	25.0	25.0	24.3	22.8	19.8	17.5
		MCDB	19.8	21.0	23.5	26.8	29.5	32.0	32.8	33.2	30.6	27.4	23.4	20.5
	10%	WB	14.7	16.6	18.4	20.5	23.1	24.4	24.5	24.5	23.7	21.8	18.7	15.4
		MCDB	18.4	20.4	22.0	25.0	28.6	31.1	32.2	32.5	29.8	26.0	22.1	18.4
Mean Daily Temperature Range	5% DB	MDBR	11.8	11.4	11.8	11.9	10.8	10.9	11.8	11.9	11.5	11.5	11.3	11.4
		MCDBR	15.2	13.9	13.5	13.8	12.4	12.6	13.6	13.6	13.1	12.8	12.9	13.7
		MCWBR	9.3	8.4	7.2	6.9	4.9	3.8	3.6	3.8	4.3	5.8	7.3	9.0
	5% WB	MCDBR	11.6	11.2	10.9	10.6	10.5	10.7	11.5	11.7	10.9	10.3	10.3	11.6
	MCWBR	8.8	8.3	6.9	6.1	5.0	3.9	3.7	3.6	4.1	5.5	7.3	9.1	
Clear-Sky Solar Irradiance	taub	0.314	0.329	0.355	0.395	0.430	0.424	0.437	0.428	0.398	0.369	0.344	0.318	
	taud	2.517	2.480	2.420	2.329	2.287	2.342	2.342	2.353	2.384	2.450	2.462	2.510	
	Ebn at Noon	918	934	928	897	864	863	851	857	872	877	873	893	
	Edh at Noon	87	99	112	128	134	127	126	123	115	101	91	83	
All-Sky Solar Radiation	RadAvg	3.01	3.51	4.55	5.47	5.80	6.63	6.73	6.27	5.22	4.20	3.17	2.66	
	RadStd	0.32	0.59	0.40	0.50	0.53	0.51	0.51	0.36	0.45	0.62	0.38	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (45 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+71

Nomenclature: See separate page