

KILLEEN REGIONAL, TX, USA

WMO: 722576

Lat: 31.067N

Lon: 97.833W

Elev: 1015

StdP: 14.16

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03902

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.4	29.3	10.8	9.9	35.7	15.3	12.4	40.1	26.9	51.5	24.6	54.1	10.4	0	0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.6	100.4	73.0	99.0	73.2	96.8	73.2	77.7	89.7	76.9	88.7	76.1	87.7	10.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.0	136.5	80.8	73.9	131.1	80.0	73.1	127.8	79.7	41.8	89.3	40.9	88.3	40.1	87.3	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	20.8	18.9	19.9	104.6	4.2	3.2	16.9	106.9	14.5	108.8	12.1	110.6	9.1	113.0
			17.8	80.1	3.9	2.0	15.0	81.5	12.7	82.7	10.6	83.9	7.7	85.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	49.8	53.6	60.1	67.9	75.1	81.2	84.9	85.2	79.1	69.5	58.7	50.8
	DBStd	14.82	10.33	10.80	9.23	7.40	5.99	4.00	3.66	3.74	5.91	7.84	9.36	9.65
	HDD50	379	132	78	27	2	0	0	0	0	2	31	107	
	HDD65	1805	478	339	202	54	6	0	0	0	2	48	227	449
	CDD50	6977	127	179	339	538	779	937	1082	1092	872	607	292	133
	CDD65	2929	8	20	49	140	321	487	617	627	424	188	38	10
	CDH74	32239	55	149	358	1110	2914	5353	7876	8088	4494	1553	236	53
	CDH80	15893	5	39	72	329	1159	2603	4385	4563	2168	534	32	4
Wind	WSAvg	9.6	10.0	10.3	10.9	11.4	10.6	9.8	9.0	8.2	7.7	8.7	9.3	9.4
Precipitation	PrecAvg	32.5	2.0	2.2	2.9	2.6	4.3	3.3	2.0	2.1	2.8	3.6	2.7	2.1
	PrecMax	48.3	4.8	8.2	10.0	6.1	10.3	8.6	7.2	7.0	7.4	10.6	10.9	8.2
	PrecMin	16.7	0.0	0.0	0.0	0.4	1.1	0.3	0.0	0.2	0.3	0.2	0.2	0.1
	PrecStd	8.1	1.4	1.9	2.0	1.6	2.3	2.2	1.8	1.9	1.9	2.7	2.3	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.8	84.7	85.9	92.6	97.2	100.4	103.8	103.8	100.6	92.4	84.0	79.7
		MCWB	60.1	60.2	64.7	69.0	71.9	74.1	72.5	72.7	72.4	69.8	67.4	63.0
	2%	DB	74.4	78.5	81.7	87.6	92.8	96.9	100.3	100.5	96.9	88.8	80.1	74.7
		MCWB	59.9	59.9	64.0	68.3	72.7	74.6	73.1	72.9	72.6	69.1	65.6	62.1
	5%	DB	70.2	73.3	78.3	83.6	89.9	93.9	98.7	99.1	93.5	86.0	76.8	70.4
		MCWB	58.7	60.1	63.3	67.6	72.2	73.8	73.3	73.0	71.9	68.6	64.7	60.3
	10%	DB	66.3	69.8	74.3	80.7	86.4	91.3	96.3	96.9	90.7	82.4	73.0	66.4
		MCWB	57.5	59.8	62.1	66.2	71.4	73.8	73.5	73.2	71.8	67.3	63.4	58.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.8	68.2	70.0	75.1	78.4	78.8	78.3	78.2	78.3	76.1	72.3	69.0
		MCDB	71.5	72.9	78.4	83.9	88.5	91.2	91.5	91.1	89.5	83.2	78.8	72.8
	2%	WB	65.1	66.4	68.2	73.0	76.2	77.3	77.3	77.0	76.8	74.2	70.1	66.3
		MCDB	70.0	71.1	75.1	81.6	85.5	89.4	90.5	89.6	86.8	81.3	75.3	71.2
	5%	WB	62.7	64.6	66.9	71.3	74.8	76.3	76.4	76.1	75.5	72.9	68.1	63.4
		MCDB	67.5	69.4	73.0	78.6	83.8	87.7	89.3	88.7	85.2	80.0	72.8	68.0
	10%	WB	58.9	62.2	65.4	69.7	73.4	75.4	75.5	75.3	74.6	71.4	66.0	60.1
		MCDB	64.2	68.0	71.1	76.3	82.5	86.1	88.0	87.9	84.2	78.4	71.4	64.7
Mean Daily Temperature Range	5% DB	MDBR	20.6	20.7	20.9	20.9	19.7	19.4	21.0	21.6	20.5	20.4	19.8	19.8
		MCDBR	25.8	24.9	24.5	24.1	23.1	22.3	24.4	24.5	23.5	23.1	22.4	24.0
	5% WB	MCWBR	14.9	14.1	12.6	11.7	8.8	6.2	6.1	6.0	7.1	10.0	12.1	14.6
		MCWBR	21.1	19.7	19.2	19.4	19.2	19.0	20.7	20.8	18.8	17.9	18.0	20.0
Clear-Sky Solar Irradiance	taub		0.312	0.325	0.351	0.391	0.425	0.420	0.432	0.423	0.394	0.366	0.340	0.315
		taud	2.521	2.488	2.428	2.338	2.297	2.352	2.355	2.363	2.393	2.457	2.471	2.515
	Ebn at Noon		292	298	296	286	275	275	271	273	278	279	279	285
		Edh at Noon	27	31	35	40	42	40	40	39	36	32	29	26
All-Sky Solar Radiation	RadAvg		961	1125	1453	1748	1850	2113	2139	1993	1656	1336	1012	849
	RadStd		102	186	129	160	173	161	165	115	144	197	123	115

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-373	-299
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+131

Nomenclature: See separate page