

DRAUGHON-MILLER CENTRAL TEXAS, TX, USA

WMO: 722577

Lat: 31.150N

Lon: 97.417W

Elev: 208

StdP: 98.85

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93984

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.3	-12.0	1.4	-0.1	-9.1	1.8	2.9	12.5	14.4	11.5	14.7	3.7	0	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.5	37.8	23.4	37.2	23.5	36.0	23.6	25.8	32.3	25.4	32.1	25.0	31.7	4.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	19.5	27.5	23.7	19.1	27.4	23.0	18.2	27.2	80.5	32.7	78.5	32.0	76.9	31.8	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	10.0	9.0	-7.7	40.1	2.2	2.7	-9.3	42.0	-10.6	43.6	-11.9	45.1	-13.5	47.0		
(5)			-8.7	26.6	2.1	0.9	-10.2	27.3	-11.5	27.8	-12.7	28.3	-14.2	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	9.3	11.3	15.1	19.4	23.6	27.3	29.0	29.2	25.8	20.5	14.5	9.9		
	DBStd	8.31	5.47	5.80	5.21	4.08	3.37	2.22	1.80	1.98	3.30	4.38	5.16	5.32		
	HDD10.0	231	80	48	16	1	0	0	0	0	0	1	18	67		
	HDD18.3	1085	284	204	125	36	4	0	0	0	2	29	136	266		
	CDD10.0	3747	57	85	175	284	422	519	591	597	474	326	152	66		
	CDD18.3	1559	3	8	25	69	168	269	332	338	226	96	19	5		
	CDH23.3	17298	21	62	171	557	1548	3034	4176	4328	2378	864	132	27		
	CDH26.7	8612	2	12	27	149	608	1510	2340	2472	1163	303	22	2		
(14) Wind	WSAvg	4.4	4.4	4.7	5.0	5.2	4.9	4.6	4.3	3.9	3.5	4.0	4.2	4.2		
(15) Precipitation	PrecAvg	929	61	63	80	66	121	87	53	60	84	96	73	65		
	PrecMax	1332	169	164	215	201	293	273	150	273	240	294	241	238		
	PrecMin	547	0	1	0	11	11	9	0	0	13	12	7	5		
	PrecStd	241	44	43	49	43	60	58	40	66	63	80	59	53		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	28.0	29.0	32.7	35.4	37.9	39.2	39.2	37.8	33.6	28.9	26.3		
		MCWB	15.7	17.1	18.7	20.8	23.0	23.8	23.3	23.6	23.0	21.7	20.5	17.5		
	2%	DB	22.9	25.1	27.3	30.1	33.0	36.2	37.8	37.9	36.0	32.1	27.1	23.2		
		MCWB	15.7	16.6	18.5	20.2	23.3	23.9	23.4	23.4	23.1	21.6	19.0	17.0		
	5%	DB	21.1	22.7	25.3	28.0	32.0	34.3	37.0	37.3	34.0	30.1	24.4	21.3		
		MCWB	15.2	16.2	17.9	20.1	22.9	23.8	23.5	23.5	22.9	21.0	18.0	16.3		
	10%	DB	18.6	20.9	23.0	27.0	30.2	33.0	35.7	36.1	32.6	27.9	22.6	18.9		
		MCWB	14.6	16.2	16.8	19.4	22.6	23.9	23.8	23.6	22.7	19.9	17.6	15.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	20.7	21.5	23.9	25.7	26.7	26.4	26.0	25.8	24.7	22.7	20.7		
		MCDB	22.2	23.5	26.2	29.1	31.4	32.1	33.1	32.9	31.6	29.0	26.4	22.9		
	2%	WB	18.2	19.4	20.4	22.7	24.8	25.7	25.6	25.5	25.1	23.7	21.2	19.1		
		MCDB	20.7	22.1	24.3	27.6	30.3	32.0	32.5	32.8	30.9	28.2	24.2	21.9		
	5%	WB	17.0	18.2	19.5	21.7	24.0	25.2	25.2	25.1	24.5	22.9	19.9	17.6		
		MCDB	19.4	20.9	23.1	26.4	29.1	31.8	32.1	32.5	30.2	27.2	23.1	20.2		
	10%	WB	14.9	16.7	18.6	20.8	23.3	24.7	24.7	24.6	23.9	22.0	18.7	15.7		
		MCDB	18.2	20.2	21.9	24.7	28.4	30.8	31.7	32.0	29.5	26.1	21.9	18.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	12.0	12.0	12.3	11.2	11.2	12.2	12.5	12.2	12.6	12.1	11.9		
		MCDBR	15.5	14.5	13.2	13.3	12.6	12.6	14.1	14.2	13.7	13.7	13.3	14.2		
	5% WB	MCWBR	9.5	8.8	7.3	6.7	5.1	3.8	3.5	3.7	4.3	6.2	7.6	9.2		
		MCWBR	11.4	11.4	10.9	10.4	10.5	10.7	11.7	12.0	11.1	10.6	10.7	11.4		
(40) Clear-Sky Solar Irradiance	taub		0.316	0.332	0.357	0.399	0.432	0.429	0.442	0.432	0.401	0.371	0.349	0.321		
	taud		2.514	2.473	2.415	2.322	2.281	2.330	2.327	2.340	2.376	2.445	2.451	2.502		
	Ebn at Noon		916	930	925	894	861	859	846	852	869	874	866	888		
	Edh at Noon		87	99	113	129	135	128	128	125	116	101	92	84		
(44) All-Sky Solar Radiation	RadAvg		2.98	3.44	4.50	5.42	5.77	6.58	6.71	6.25	5.21	4.19	3.15	2.62		
	RadStd		0.31	0.60	0.40	0.49	0.51	0.51	0.50	0.36	0.45	0.61	0.38	0.35		

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (48 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+76

Nomenclature: See separate page