

DALLAS HENSLEY FIELD, TX, USAWMO: **722585**Lat: **32.733N**Lon: **96.967W**Elev: **150**StdP: **99.54**Time Zone: **-6.00 (NAC)**Period: **86-96**WBAN: **93901****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.8	-2.7	-14.3	1.1	-2.5	-11.2	1.5	0.1	11.5	12.9	10.6	12.0	4.7	0	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	37.6	24.2	36.4	24.1	35.1	23.9	26.1	33.4	25.5	32.9	25.0	32.3	3.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.1	19.4	29.8	23.4	18.6	29.0	22.9	18.0	28.5	81.6	33.2	78.8	33.0	76.5	32.4	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
Min	Max			Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 9.2	8.4	7.6		-7.7	39.5	4.2	1.5	-10.7	40.5	-13.2	41.4	-15.5	42.2	-18.6	43.3	(4)
(5)				-9.0	27.9	4.1	1.3	-12.0	28.8	-14.3	29.6	-16.6	30.3	-19.6	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	8.4	10.6	14.3	18.8	23.3	27.4	29.5	29.2	25.6	19.9	13.5	9.0	(6)	
	DBStd	8.67	4.83	5.95	5.23	4.14	3.37	2.35	1.87	2.64	3.75	4.34	5.41	5.55	(7)	
	HDD10.0	277	87	58	22	1	0	0	0	0	0	2	25	82	(8)	
	HDD18.3	1206	307	219	141	44	5	0	0	0	3	33	161	291	(9)	
	CDD10.0	3627	39	77	155	265	412	521	603	596	468	311	131	51	(10)	
	CDD18.3	1513	1	4	16	58	158	271	345	337	221	83	16	2	(11)	
	CDH23.3	16737	6	52	116	438	1308	3031	4453	4265	2277	683	103	6	(12)	
	CDH26.7	7921	0	13	19	108	447	1410	2379	2304	1002	219	21	0	(13)	
(14) Wind	WSAvg	3.5	3.5	3.5	4.1	4.1	4.0	3.4	3.6	3.0	2.9	3.3	3.6	3.2	(14)	
(15) Precipitation	PrecAvg	841	47	56	66	87	117	81	57	58	83	84	49	53	(15)	
	PrecMax	1157	98	127	199	251	260	216	217	179	176	233	122	190	(16)	
	PrecMin	471	0	2	4	3	16	1	2	0	11	0	8	5	(17)	
	PrecStd	182	28	34	47	60	79	66	48	46	50	64	33	48	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	28.5	29.1	32.5	34.1	37.2	39.1	39.1	36.5	33.3	29.4	24.0	(19)	
		MCWB	14.7	15.3	17.0	19.3	22.6	25.3	24.4	23.9	23.4	20.4	18.9	16.3	(20)	
	2%	DB	21.1	24.5	26.2	29.6	32.2	35.4	37.4	37.9	34.8	31.0	26.1	21.3	(21)	
		MCWB	13.6	14.6	16.2	19.4	22.7	24.8	24.1	24.1	23.0	20.0	17.9	15.2	(22)	
	5%	DB	18.8	21.8	24.2	27.4	30.8	34.1	36.3	36.7	33.4	29.2	23.9	19.6	(23)	
		MCWB	12.8	14.1	16.3	19.0	22.4	24.3	24.2	24.0	23.0	19.9	17.4	15.0	(24)	
	10%	DB	16.6	19.2	22.3	25.8	29.3	32.9	35.0	35.3	31.9	27.2	22.0	17.4	(25)	
		MCWB	12.0	13.1	15.8	18.6	21.7	23.9	24.1	23.7	22.8	18.8	16.3	12.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	17.9	20.6	23.3	26.0	27.0	27.0	26.3	25.6	24.1	21.2	19.0	(27)	
		MCDB	20.7	22.4	24.6	27.6	31.1	34.0	34.4	34.4	32.2	29.2	25.3	21.4	(28)	
	2%	WB	15.7	16.7	19.4	21.9	24.5	26.1	26.0	25.5	24.9	22.4	20.0	17.7	(29)	
		MCDB	18.9	21.3	23.1	26.4	29.6	33.2	33.5	34.0	31.3	27.6	24.1	20.5	(30)	
	5%	WB	14.2	15.4	18.1	20.8	23.7	25.4	25.3	24.9	24.3	20.8	18.8	15.5	(31)	
		MCDB	17.2	20.4	22.0	25.0	28.4	32.2	33.1	33.4	30.5	26.4	22.6	18.3	(32)	
	10%	WB	12.2	13.8	16.7	19.9	22.7	24.8	24.8	24.4	23.8	19.9	17.4	13.2	(33)	
		MCDB	16.0	18.2	21.0	24.4	27.6	31.1	32.5	32.7	29.7	25.8	21.2	16.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	10.7	11.1	11.1	9.6	10.2	10.7	10.6	10.7	11.6	10.8	9.7	(35)	
		MCDBR	14.6	15.2	13.4	13.0	11.0	11.5	12.4	12.1	11.7	13.6	12.6	13.1	(36)	
	5% WB	MCWBR	9.5	8.5	7.4	6.9	5.1	4.7	4.3	3.7	4.2	6.5	7.0	8.6	(37)	
		MCWBR	10.8	12.5	9.8	9.9	9.4	10.5	10.9	11.0	9.6	10.6	10.0	10.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.316	0.330	0.360	0.398	0.429	0.441	0.443	0.444	0.403	0.361	0.340	0.321	(40)	
		taud	2.498	2.467	2.401	2.316	2.292	2.291	2.323	2.303	2.367	2.470	2.469	2.486	(41)	
	Ebn at Noon		905	926	918	892	863	848	844	840	862	879	868	877	(42)	
		Edh at Noon	86	98	113	129	133	133	128	129	116	97	88	83	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.88	3.37	4.46	5.41	5.83	6.57	6.70	6.15	5.17	4.06	3.06	2.54	(44)	
	RadStd		0.28	0.53	0.35	0.42	0.53	0.62	0.46	0.40	0.44	0.60	0.39	0.33	(45)	

Historical Trends

	DBAvg	Heating	
--	-------	---------	--