

COX FIELD, TX, USA

WMO: 722587

Lat: 33.633N

Lon: 95.450W

Elev: 547

StdP: 14.41

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93955

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	25.1	8.7	8.7	25.0	12.0	10.3	30.3	28.2	46.0	25.7	50.2	10.2	350	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.9	99.5	76.0	97.2	75.8	94.1	75.5	79.3	92.4	78.3	91.3	77.5	90.4	8.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.5	136.1	85.1	74.8	133.2	84.5	73.4	127.0	83.3	43.0	93.3	42.2	91.8	41.2	90.2	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.1	20.7	18.7	13.9	101.1	4.2	4.0	10.9	103.9	8.5	106.3	6.2	108.5	3.2	111.4	
			DB												
			WB	12.5	80.5	3.7	1.2	9.9	81.3	7.7	82.0	5.7	82.7	3.0	83.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	43.9	48.0	55.8	63.1	71.3	79.3	82.7	83.1	76.2	65.4	54.1	45.8
	DBStd	15.87	10.03	10.34	9.15	7.27	6.22	4.27	3.91	4.57	6.32	8.00	9.07	9.40
	HDD50	700	241	148	48	5	0	0	0	0	0	3	59	196
	HDD65	2621	655	481	306	117	20	0	0	0	6	95	343	598
	CDD50	5856	52	90	226	399	659	878	1013	1027	785	480	181	66
	CDD65	2308	1	4	20	62	215	429	548	562	341	108	15	3
	CDH74	23942	4	28	128	451	1657	4361	6380	6669	3287	885	81	11
	CDH80	11280	0	4	12	59	484	1994	3329	3612	1511	265	10	0
Wind	WSAvg	9.2	10.0	10.4	10.9	10.8	9.3	8.4	7.4	7.2	7.8	8.7	9.6	9.6
Precipitation	PrecAvg	49.3	3.3	3.3	4.6	4.7	5.6	3.8	3.2	2.5	4.1	4.7	4.4	4.4
	PrecMax	75.9	6.7	8.8	11.8	14.3	13.3	8.8	9.1	7.0	9.3	15.3	14.5	11.4
	PrecMin	28.7	0.1	0.5	0.6	1.6	1.6	0.9	0.0	0.2	0.9	0.2	0.9	0.2
	PrecStd	11.4	1.7	1.9	2.5	2.8	2.9	2.1	2.5	1.7	2.1	3.6	3.4	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.2	77.6	81.6	84.5	90.7	98.6	101.7	103.7	99.6	90.1	81.4	75.2
		MCWB	59.8	62.6	66.0	69.2	74.3	76.2	76.0	75.3	73.6	71.8	67.7	64.5
	2%	DB	69.8	72.6	78.5	81.6	88.1	94.6	99.1	100.0	94.9	86.5	75.3	70.3
		MCWB	60.4	60.5	64.0	68.2	74.2	76.0	76.3	76.0	73.8	70.8	64.6	61.7
	5%	DB	64.4	69.6	73.4	79.4	84.5	91.5	96.9	98.6	91.2	82.3	72.4	65.8
		MCWB	57.2	60.0	61.7	66.2	72.8	75.8	76.7	75.9	73.3	68.4	63.2	59.3
	10%	DB	61.3	64.4	70.5	76.6	82.1	90.2	93.1	94.9	89.5	79.2	69.6	62.7
		MCWB	53.6	56.7	60.5	64.8	71.2	75.7	76.2	75.7	72.9	66.6	61.9	55.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.4	66.7	68.8	73.3	77.4	80.3	80.5	80.4	78.3	75.9	70.2	66.8
		MCDB	69.7	72.9	78.2	81.6	86.7	92.1	92.8	94.6	90.0	85.2	77.6	72.9
	2%	WB	62.8	64.3	66.7	71.1	75.7	78.4	79.2	79.1	76.9	73.7	67.5	63.7
		MCDB	66.8	69.4	74.5	79.2	84.8	90.3	92.3	93.1	88.8	82.4	73.5	67.9
	5%	WB	59.2	61.8	64.8	69.0	74.3	77.4	78.2	78.1	75.7	71.5	65.3	60.3
		MCDB	63.6	67.3	71.2	76.9	83.0	89.1	91.4	92.0	87.0	78.7	71.0	65.0
	10%	WB	54.3	58.2	62.4	67.2	72.7	76.4	77.4	77.3	74.4	69.1	62.4	56.4
		MCDB	59.9	63.9	68.9	74.4	80.8	87.2	90.5	90.8	84.8	76.2	67.1	60.9
Mean Daily Temperature Range	5% DB	MDBR	19.5	19.9	20.6	21.0	18.2	18.9	19.9	20.9	20.6	21.4	20.2	19.0
		MCDBR	25.3	25.0	23.3	22.7	20.0	21.3	23.6	24.9	23.9	24.2	23.2	24.3
		MCWBR	17.6	17.1	14.3	13.2	10.2	8.6	7.9	7.8	9.2	12.1	15.0	17.4
	5% WB	MCDBR	21.0	21.9	19.8	18.7	18.1	18.9	20.1	20.9	19.6	19.9	19.9	21.1
		MCWBR	17.1	16.9	14.0	12.5	10.1	8.8	8.1	7.5	8.3	11.6	15.4	17.1
Clear-Sky Solar Irradiance	taub	0.314	0.326	0.356	0.389	0.425	0.436	0.449	0.447	0.399	0.354	0.336	0.315	
	taud	2.490	2.470	2.408	2.323	2.285	2.291	2.292	2.282	2.373	2.478	2.477	2.496	
	Ebn at Noon	286	294	292	285	274	270	266	265	274	280	275	279	
	Edh at Noon	27	31	36	40	43	42	42	42	36	30	28	26	
All-Sky Solar Radiation	RadAvg	853	982	1346	1650	1802	2021	2049	1899	1587	1245	912	747	
	RadStd	81	146	107	117	168	208	208	128	137	149	180	115	98

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page