

COX FIELD, TX, USA

WMO: 722587

Lat: 33.633N

Lon: 95.450W

Elev: 167

StdP: 99.34

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93955

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.3	(c) -3.8	(d) -13.0	(e) 1.2	(f) -3.9	(g) -11.1	(h) 1.5	(i) -1.0	(j) 12.6	(k) 7.8	(l) 11.5	(m) 10.1	(n) 4.6	(o) 350	(p) 0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 11.6	(c) 37.5	(d) 24.4	(e) 36.2	(f) 24.3	(g) 34.5	(h) 24.2	(i) 26.3	(j) 33.5	(k) 25.7	(l) 32.9	(m) 25.3	(n) 32.4	(o) 3.7	(p) 190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.1	19.4	29.5	23.8	19.0	29.2	23.0	18.1	28.5	82.2	34.1	80.2	33.2	78.0	32.3	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.8	(b) 9.2	(c) 8.3	(e) -10.0	(f) 38.4	(g) 2.3	(h) 2.2	(i) -11.7	(j) 40.0	(k) -13.1	(l) 41.3	(m) -14.4	(n) 42.5	(o) -16.0	(p) 44.1		
(a) 10.8	(b) 9.2	(c) 8.3	(e) -10.8	(f) 26.9	(g) 2.0	(h) 0.7	(i) -12.3	(j) 27.4	(k) -13.5	(l) 27.8	(m) -14.6	(n) 28.2	(o) -16.1	(p) 28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	6.6	8.9	13.2	17.3	21.8	26.3	28.2	28.4	24.5	18.6	12.3	7.7
	DBStd	8.82	5.57	5.75	5.08	4.04	3.46	2.37	2.17	2.54	3.51	4.44	5.04	5.22
	HDD10.0	389	134	82	27	3	0	0	0	0	0	2	33	109
	HDD18.3	1456	364	267	170	65	11	0	0	0	3	53	191	332
	CDD10.0	3253	29	50	126	222	366	488	563	571	436	267	101	37
	CDD18.3	1282	1	2	11	34	119	238	304	312	189	60	8	2
	CDH23.3	13301	2	16	71	251	921	2423	3544	3705	1826	492	45	6
	CDH26.7	6267	0	2	7	33	269	1108	1849	2007	839	147	6	0
Wind	WSAvg	4.1	4.5	4.6	4.9	4.8	4.2	3.8	3.3	3.2	3.5	3.9	4.3	4.3
Precipitation	PrecAvg	1253	83	84	118	119	142	96	81	63	104	120	112	111
	PrecMax	1928	169	224	299	363	339	223	232	178	235	388	369	289
	PrecMin	728	3	12	16	41	41	23	0	4	22	4	22	5
	PrecStd	290	43	49	63	71	74	53	64	43	53	92	87	65
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	25.3	27.5	29.1	32.6	37.0	38.7	39.9	37.6	32.3	27.5	24.0
		MCWB	15.4	17.0	18.9	20.7	23.5	24.6	24.4	24.1	23.1	22.1	19.8	18.1
	2%	DB	21.0	22.5	25.8	27.5	31.2	34.8	37.3	37.8	34.9	30.3	24.1	21.3
		MCWB	15.8	15.8	17.8	20.1	23.4	24.4	24.6	24.4	23.2	21.6	18.1	16.5
	5%	DB	18.0	20.9	23.0	26.3	29.2	33.0	36.0	37.0	32.9	27.9	22.4	18.8
		MCWB	14.0	15.5	16.5	19.0	22.6	24.3	24.8	24.4	22.9	20.2	17.4	15.2
	10%	DB	16.3	18.0	21.4	24.8	27.8	32.3	34.0	35.0	31.9	26.2	20.9	17.0
		MCWB	12.0	13.7	15.8	18.2	21.8	24.3	24.6	24.3	22.7	19.2	16.6	13.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.5	19.3	20.5	23.0	25.2	26.8	26.9	26.9	25.7	24.4	21.2	19.4
		MCDB	20.9	22.7	25.7	27.6	30.4	33.4	33.8	34.8	32.2	29.6	25.3	22.7
	2%	WB	17.1	17.9	19.3	21.7	24.3	25.8	26.2	26.2	25.0	23.2	19.7	17.6
		MCDB	19.3	20.8	23.6	26.2	29.4	32.4	33.5	33.9	31.5	28.0	23.1	19.9
	5%	WB	15.1	16.5	18.2	20.5	23.5	25.2	25.7	25.6	24.3	21.9	18.5	15.7
		MCDB	17.6	19.6	21.8	24.9	28.3	31.7	33.0	33.4	30.6	25.9	21.7	18.3
	10%	WB	12.4	14.5	16.9	19.5	22.6	24.7	25.2	25.1	23.5	20.6	16.9	13.6
		MCDB	15.5	17.7	20.5	23.5	27.1	30.7	32.5	32.7	29.3	24.5	19.5	16.1
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.0	11.4	11.6	10.1	10.5	11.0	11.6	11.5	11.9	11.2	10.6
		MCDBR	14.1	13.9	13.0	12.6	11.1	11.8	13.1	13.8	13.3	13.4	12.9	13.5
		MCWBR	9.8	9.5	7.9	7.3	5.7	4.8	4.4	4.3	5.1	6.7	8.3	9.6
	5% WB	MCDBR	11.7	12.1	11.0	10.4	10.0	10.5	11.2	11.6	10.9	11.1	11.1	11.7
		MCWBR	9.5	9.4	7.8	6.9	5.6	4.9	4.5	4.1	4.6	6.5	8.6	9.5
Clear-Sky Solar Irradiance	taub	0.314	0.326	0.356	0.389	0.425	0.436	0.449	0.447	0.399	0.354	0.336	0.315	
	taud	2.490	2.470	2.408	2.323	2.285	2.291	2.292	2.282	2.373	2.478	2.477	2.496	
	Ebn at Noon	902	926	919	899	865	852	838	835	864	882	867	878	
	Edh at Noon	86	97	112	127	134	133	132	131	115	95	87	81	
All-Sky Solar Radiation	RadAvg	2.69	3.10	4.24	5.20	5.68	6.37	6.46	5.99	5.00	3.92	2.88	2.36	
	RadStd	0.26	0.46	0.34	0.37	0.53	0.66	0.40	0.43	0.47	0.57	0.36	0.31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page