

GREENVILLE MAJORS, TX, USA

WMO: 722588

Lat: 33.068N

Lon: 96.065W

Elev: 535

StdP: 14.41

Time Zone: -6.00 (NAC)

Period: 03-19

WBAN: 13926

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.2	27.6	11.5	10.1	32.7	15.8	12.5	36.8	24.7	56.1	22.5	56.1	6.2	0	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.3	100.2	73.2	98.9	73.3	96.7	73.6	78.3	88.0	77.5	88.0	76.8	87.5	8.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.7	142.1	81.7	74.9	133.4	81.2	73.3	126.3	80.6	42.3	87.0	41.2	87.3	40.4	88.1	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.8	18.7	16.9	DB	16.7	103.6	3.6	2.9	14.1	105.6	12.0	107.3	10.0	109.0	7.4	111.1
			WB	15.4	79.8	3.5	2.1	12.9	81.2	10.8	82.5	8.9	83.6	6.4	85.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.7	45.6	48.9	57.6	64.4	72.8	80.9	84.0	84.5	77.6	66.7	56.3	47.7
	DBStd	15.80	9.61	10.15	9.29	7.51	6.60	4.15	4.31	4.80	6.08	8.26	9.40	9.25
	HDD50	577	201	131	37	4	0	0	0	0	0	2	44	158
	HDD65	2349	605	457	261	100	17	0	0	0	2	78	288	541
	CDD50	6295	64	101	272	436	708	926	1054	1069	827	520	232	86
	CDD65	2592	2	6	31	83	259	476	589	604	379	132	27	4
	CDH74	28667	10	37	192	634	2285	5210	7253	7526	4055	1289	152	24
	CDH80	13943	0	3	17	112	789	2509	3931	4194	1936	430	21	1
Wind	WSAvg	6.9	7.4	7.9	8.5	8.5	7.4	6.7	6.0	5.5	5.0	6.1	7.1	7.1
Precipitation	PrecAvg	46.7	3.0	3.3	4.1	3.8	4.9	3.8	2.6	2.3	3.2	5.1	3.9	3.7
	PrecMax	63.0	6.1	8.6	8.7	7.1	8.9	9.9	6.9	5.0	7.5	14.5	9.5	8.0
	PrecMin	33.9	0.3	0.6	0.6	1.3	2.0	0.8	0.2	0.0	0.6	0.6	0.5	0.4
	PrecStd	7.3	1.7	2.0	2.0	2.0	2.4	2.6	2.1	1.3	1.9	3.5	2.6	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.0	79.0	81.8	87.7	94.6	99.2	103.9	105.7	99.5	91.3	82.2	77.3
		MCWB	59.7	63.0	64.6	69.7	73.6	73.4	73.3	72.0	70.3	70.4	66.9	63.6
	2%	DB	71.5	73.2	79.1	82.3	90.2	96.8	99.8	101.7	96.6	88.4	78.6	72.2
		MCWB	59.6	60.9	63.6	67.5	72.5	73.6	73.4	73.6	72.1	70.1	65.4	61.9
	5%	DB	67.5	70.3	76.1	80.9	87.9	93.8	98.5	99.4	93.1	85.6	74.6	68.1
		MCWB	58.3	60.4	62.6	66.5	72.2	73.6	73.8	73.4	71.9	68.2	63.7	59.9
	10%	DB	63.1	66.3	72.4	78.5	84.5	90.9	95.3	97.0	90.5	81.3	71.9	63.7
		MCWB	55.1	58.1	62.0	65.1	71.4	74.1	74.5	73.5	71.3	66.6	63.7	56.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.9	67.9	69.0	73.7	77.6	79.6	79.2	79.4	78.5	75.7	71.4	68.4
		MCDB	70.8	73.8	75.3	81.7	85.6	88.8	89.7	86.8	84.8	84.0	77.0	72.3
	2%	WB	63.2	65.7	67.2	71.3	75.8	77.8	78.1	78.2	76.9	74.0	69.0	64.5
		MCDB	66.3	71.8	75.0	78.8	84.6	87.9	89.0	88.0	85.4	82.5	74.2	69.4
	5%	WB	60.4	62.9	65.8	69.5	74.3	76.8	77.3	77.3	75.7	72.4	66.8	62.0
		MCDB	65.2	67.0	72.9	76.4	83.2	87.2	88.5	88.5	85.0	80.5	73.0	66.3
	10%	WB	55.6	59.4	64.1	67.9	73.1	75.8	76.4	76.5	74.5	70.6	64.6	58.5
		MCDB	62.0	65.2	70.1	75.3	81.8	86.4	87.9	87.7	84.1	77.6	69.9	63.4
Mean Daily Temperature Range	5% DB	MDBR	20.4	19.9	21.2	21.4	19.4	19.3	20.6	21.3	22.3	23.2	21.0	20.6
		MCDBR	26.5	25.1	23.1	22.5	21.2	22.1	23.4	24.7	24.6	25.5	22.8	26.1
		MCWBR	16.5	15.6	12.4	11.0	7.9	6.0	5.0	5.0	6.7	9.8	12.8	17.2
	5% WB	MCDBR	21.1	21.2	19.0	18.2	17.7	18.1	19.1	19.4	18.8	19.5	18.6	21.8
		MCWBR	16.8	16.6	11.9	11.2	8.4	6.5	6.0	5.5	6.3	9.4	13.7	17.7
Clear-Sky Solar Irradiance	taub		0.315	0.331	0.358	0.393	0.427	0.439	0.446	0.446	0.400	0.357	0.338	0.319
	taud		2.493	2.461	2.404	2.322	2.288	2.288	2.307	2.291	2.373	2.474	2.472	2.486
	Ebn at Noon		287	293	292	284	274	270	267	265	274	279	275	278
	Edh at Noon		27	31	36	41	43	42	41	41	36	30	28	26
All-Sky Solar Radiation	RadAvg		878	1015	1372	1680	1820	2041	2080	1922	1613	1271	939	773
	RadStd		85	156	111	119	158	199	136	132	147	185	119	99

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page