

GREENVILLE MAJORS, TX, USA

WMO: 722588

Lat: 33.068N

Lon: 96.065W

Elev: 163

StdP: 99.38

Time Zone: -6.00 (NAC)

Period: 03-19

WBAN: 13926

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.9	-2.4	-11.4	1.4	0.4	-9.0	1.8	2.6	11.0	13.4	10.1	13.4	2.8	0	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	37.9	22.9	37.2	22.9	35.9	23.1	25.7	31.1	25.3	31.1	24.9	30.8	3.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.3	27.6	23.8	19.1	27.3	22.9	18.0	27.0	80.4	30.5	78.1	30.7	76.1	31.2	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	8.4	7.5	-8.5	39.8	2.0	1.6	-9.9	40.9	-11.1	41.9	-12.2	42.8	-13.7	43.9		
			-9.2	26.5	1.9	1.1	-10.6	27.4	-11.8	28.0	-12.8	28.7	-14.2	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	7.5	9.4	14.2	18.0	22.7	27.1	28.9	29.2	25.3	19.3	13.5	8.7	(6)
		DBStd	8.78	5.34	5.64	5.16	4.17	3.67	2.30	2.40	2.67	3.38	4.59	5.22	5.14	
		HDD10.0	321	112	73	21	2	0	0	0	0	1	24	88		
		HDD18.3	1305	336	254	145	56	9	0	0	1	43	160	301		
		CDD10.0	3497	36	56	151	242	393	514	586	459	289	129	48		
		CDD18.3	1440	1	3	17	46	144	264	327	336	211	73	15	2	
		CDH23.3	15926	6	21	107	352	1269	2894	4029	4181	2253	716	84	13	
		CDH26.7	7746	0	2	9	62	438	1394	2184	2330	1076	239	12	1	
(14)	Wind	WSAvg	3.1	3.3	3.5	3.8	3.8	3.3	3.0	2.7	2.4	2.2	2.7	3.2	3.2	(14)
(15)	Precipitation	PrecAvg	1186	77	85	103	97	124	97	66	58	81	129	99	95	(15)
(16)		PrecMax	1599	156	219	220	181	226	251	175	126	191	369	242	204	(16)
(17)		PrecMin	862	8	14	14	33	50	20	4	0	16	15	13	9	(17)
(18)		PrecStd	185	42	52	50	50	61	67	54	34	47	89	65	58	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	23.9	26.1	27.7	30.9	34.8	37.4	40.0	41.0	37.5	33.0	27.9	25.1		(19)
(20)		MCWB	15.4	17.2	18.1	21.0	23.1	23.0	23.0	22.2	21.3	21.4	19.4	17.5		(20)
(21)		DB	22.0	22.9	26.2	27.9	32.3	36.0	37.7	38.7	35.9	31.3	25.9	22.3		(21)
(22)		MCWB	15.3	16.0	17.6	19.7	22.5	23.1	23.0	23.1	22.3	21.2	18.6	16.6		(22)
(23)		DB	19.7	21.3	24.5	27.2	31.0	34.3	37.0	37.4	33.9	29.8	23.7	20.1		(23)
(24)		MCWB	14.6	15.8	17.0	19.1	22.3	23.1	23.2	23.0	22.2	20.1	17.6	15.5		(24)
(25)		DB	17.3	19.0	22.4	25.8	29.1	32.7	35.2	36.1	32.5	27.4	22.2	17.6		(25)
(26)		MCWB	12.9	14.5	16.7	18.4	21.9	23.4	23.6	23.1	21.9	19.2	17.6	13.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	18.8	19.9	20.6	23.2	25.3	26.5	26.2	26.3	25.8	24.3	21.9	20.2		(27)
(28)		MCDB	21.5	23.2	24.1	27.6	29.8	31.5	32.1	30.5	29.3	28.9	25.0	22.4		(28)
(29)		WB	17.4	18.7	19.6	21.8	24.3	25.4	25.6	25.6	24.9	23.3	20.5	18.1		(29)
(30)		MCDB	19.0	22.1	23.9	26.0	29.2	31.0	31.7	31.1	29.6	28.1	23.5	20.8		(30)
(31)		WB	15.8	17.2	18.8	20.8	23.5	24.9	25.2	25.2	24.3	22.4	19.3	16.7		(31)
(32)		MCDB	18.5	19.5	22.7	24.7	28.4	30.7	31.4	31.4	29.4	27.0	22.8	19.0		(32)
(33)		WB	13.1	15.2	17.8	19.9	22.8	24.4	24.7	24.7	23.6	21.4	18.1	14.7		(33)
(34)		MCDB	16.7	18.4	21.1	24.1	27.7	30.2	31.0	30.9	28.9	25.3	21.1	17.5		(34)
(35)	Mean Daily Temperature Range	MDBR	11.3	11.0	11.8	11.9	10.8	10.7	11.5	11.8	12.4	12.9	11.7	11.4		(35)
(36)		5% DB	14.7	14.0	12.8	12.5	11.8	12.3	13.0	13.7	13.7	14.2	12.7	14.5		(36)
(37)		MCWBR	9.1	8.6	6.9	6.1	4.4	3.3	2.8	2.8	3.7	5.4	7.1	9.6		(37)
(38)		5% WB	11.7	11.8	10.6	10.1	9.9	10.0	10.6	10.8	10.4	10.8	10.3	12.1		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.315	0.331	0.358	0.393	0.427	0.439	0.446	0.446	0.400	0.357	0.338	0.319		(40)
(41)		taud	2.493	2.461	2.404	2.322	2.288	2.288	2.307	2.291	2.373	2.474	2.472	2.486		(41)
(42)		Ebn at Noon	904	923	919	896	864	850	841	836	864	881	868	876		(42)
(43)		Edh at Noon	86	99	113	128	134	133	130	130	115	96	88	83		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.77	3.20	4.32	5.29	5.74	6.43	6.56	6.06	5.08	4.01	2.96	2.44		(44)
(45)		RadStd	0.27	0.49	0.35	0.37	0.50	0.63	0.43	0.42	0.46	0.58	0.38	0.31		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page