

FORT WORTH NAS, TX, USA

WMO: 722595

Lat: 32.767N

Lon: 97.450W

Elev: 185

StdP: 99.12

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13911

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.0	-13.8	1.2	-0.1	-11.4	1.4	2.6	12.5	9.8	11.4	10.8	4.6	0	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	39.3	22.8	38.0	23.1	36.8	23.2	25.7	33.5	25.2	32.9	24.7	32.3	4.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.7	19.0	28.5	23.0	18.2	28.1	22.7	17.8	28.0	80.0	33.5	77.7	32.9	75.7	32.4	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.9	8.9	DB	-7.5	40.7	2.3	1.5	-9.2	41.8	-10.6	42.7	-11.9	43.6	-13.6	44.7	
			WB	-9.0	27.1	2.0	1.3	-10.4	28.0	-11.6	28.8	-12.7	29.5	-14.2	30.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	8.6	11.0	15.2	19.1	24.0	28.5	30.6	30.5	27.0	20.5	14.5	9.7
	DBStd	8.96	5.53	5.88	5.50	4.30	3.58	2.65	2.28	2.58	3.52	4.77	5.10	5.25
	HDD10.0	255	91	53	20	2	0	0	0	0	1	18	70	
	HDD18.3	1122	303	212	124	41	4	0	0	0	1	33	133	271
	CDD10.0	3901	48	82	181	276	435	556	638	636	510	326	153	61
	CDD18.3	1727	2	7	27	65	181	306	379	377	261	99	18	4
	CDH23.3	21281	24	73	216	554	1777	3902	5371	5241	3060	917	118	29
	CDH26.7	11167	2	18	46	149	713	2073	3167	3082	1559	331	22	4
Wind	WSAvg	4.3	4.3	4.5	5.1	5.2	4.9	4.6	4.0	3.6	3.4	4.0	4.2	4.0
Precipitation	PrecAvg	897	54	54	73	95	113	85	55	58	74	102	74	61
	PrecMax	1443	144	179	157	197	343	314	127	184	266	275	242	252
	PrecMin	369	4	0	0	16	12	10	0	0	16	12	2	9
	PrecStd	243	34	46	44	45	68	71	39	45	55	72	61	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	29.1	30.4	32.4	36.0	38.8	40.9	41.2	38.7	34.6	29.1	26.9
		MCWB	15.2	15.9	17.5	20.9	22.4	23.0	22.5	22.4	22.7	21.4	18.9	17.0
	2%	DB	23.0	25.3	27.8	30.0	33.9	37.3	39.2	39.5	36.9	32.1	26.4	23.2
		MCWB	14.5	16.1	18.0	20.1	22.7	23.3	22.8	22.8	22.8	21.4	18.0	15.7
	5%	DB	20.3	22.8	25.8	28.3	32.3	35.9	37.9	38.2	35.3	30.2	24.3	21.0
		MCWB	13.4	14.9	17.1	19.3	21.9	23.4	23.3	23.2	22.2	20.5	17.7	14.9
	10%	DB	17.8	20.5	23.7	26.6	30.7	34.6	36.6	36.7	33.8	28.4	22.4	18.5
		MCWB	12.4	14.1	16.3	18.6	21.5	23.3	23.4	23.2	22.2	19.4	16.4	13.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.5	19.9	20.9	23.1	25.7	26.3	26.3	26.3	25.6	24.0	22.0	19.6
		MCDB	22.4	25.0	26.8	28.8	31.6	34.5	34.6	34.0	34.0	29.5	25.9	23.5
	2%	WB	16.9	18.4	19.7	21.9	24.3	25.5	25.5	25.5	24.6	23.2	20.1	18.1
		MCDB	20.1	22.4	25.0	27.9	30.3	33.0	33.9	33.2	32.0	28.4	23.8	21.8
	5%	WB	15.0	16.9	18.8	21.0	23.5	24.9	25.0	25.0	24.0	22.4	18.9	15.8
		MCDB	19.0	21.1	23.4	26.1	29.5	32.2	33.2	32.7	30.8	27.5	22.7	19.4
	10%	WB	12.7	14.9	17.8	20.1	22.8	24.2	24.6	24.5	23.5	21.6	17.8	13.9
		MCDB	17.1	19.5	22.2	25.0	28.7	31.4	32.4	32.0	30.1	26.6	21.6	17.9
Mean Daily Temperature Range	5% DB	MDBR	11.8	11.4	11.6	11.3	10.4	10.5	10.9	10.7	10.6	11.3	11.0	10.7
		MCDBR	15.7	15.0	13.9	13.0	12.0	11.9	12.4	12.3	12.4	12.4	13.0	14.2
		MCWBR	9.1	8.5	7.1	6.8	4.7	3.1	3.1	3.0	3.5	5.2	7.2	8.4
	5% WB	MCDBR	12.9	13.0	11.1	10.6	10.3	10.5	10.6	10.6	10.1	10.2	10.5	11.8
		MCWBR	9.1	8.9	7.1	6.6	5.1	3.7	3.4	3.4	3.5	5.1	7.7	8.8
Clear-Sky Solar Irradiance	taub		0.312	0.324	0.356	0.394	0.426	0.436	0.439	0.436	0.401	0.359	0.336	0.318
	taud		2.499	2.473	2.404	2.323	2.296	2.302	2.331	2.323	2.367	2.469	2.471	2.485
	Ebn at Noon		910	932	922	896	866	852	848	847	864	880	872	881
	Edh at Noon		86	98	113	128	133	132	127	126	116	97	88	83
All-Sky Solar Radiation	RadAvg		2.94	3.47	4.54	5.50	5.92	6.65	6.77	6.19	5.19	4.08	3.10	2.58
	RadStd		0.29	0.55	0.34	0.46	0.59	0.63	0.46	0.39	0.44	0.61	0.40	0.33

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page