

DALLAS EXECUTIVE, TX, USA

WMO: 722599

Lat: 32.681N

Lon: 96.868W

Elev: 658

StdP: 14.35

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 03971

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	28.0	9.4	9.1	32.6	13.5	11.2	37.9	26.3	45.6	24.1	46.7	9.1	350	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.9	101.5	74.2	99.2	74.7	96.9	74.5	78.2	91.4	77.4	90.8	76.8	89.8	8.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.0	134.6	82.5	73.9	129.6	81.8	73.2	126.4	81.5	42.1	92.2	41.2	90.8	40.5	89.9	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	19.4	17.5	17.6	104.5	3.3	3.2	15.3	106.8	13.3	108.7	11.5	110.5	9.2	112.9
			15.6	79.9	2.9	1.4	13.5	80.8	11.8	81.6	10.1	82.4	8.0	83.4

DB
WB

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.1	47.8	51.1	58.5	66.1	74.0	81.7	85.5	86.1	79.1	68.2	57.5	48.9
	DBStd	15.71	10.05	10.63	9.33	7.16	6.18	4.37	4.19	4.65	6.10	8.18	9.31	9.57
	HDD50	476	162	106	32	2	0	0	0	0	0	2	35	137
	HDD65	2082	536	400	239	71	11	0	0	0	1	63	256	505
	CDD50	6733	95	136	297	486	744	952	1101	1119	874	566	259	104
	CDD65	2862	4	11	38	105	289	502	636	654	425	162	30	6
	CDH74	32943	24	62	236	732	2608	5807	8403	8816	4673	1375	177	30
	CDH80	16469	1	6	30	149	922	2843	4698	5077	2265	449	26	3
Wind	WSAvg	8.6	9.1	9.6	10.1	10.1	9.2	8.4	7.4	6.9	7.0	7.8	8.6	8.9
Precipitation	PrecAvg	37.0	2.6	2.5	3.4	3.8	4.8	3.8	2.2	2.3	2.7	4.2	3.0	2.8
	PrecMax	54.1	6.2	7.1	6.5	7.6	15.7	11.3	4.9	5.4	9.6	11.9	10.3	8.9
	PrecMin	21.9	0.0	0.0	0.0	1.4	0.2	0.6	0.0	0.0	0.3	0.0	0.3	0.1
	PrecStd	8.5	1.6	1.7	1.9	1.7	2.9	2.7	1.5	1.4	2.3	3.1	2.3	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	80.4	83.5	87.5	94.6	100.0	104.4	105.3	101.5	91.6	83.5	78.1
		MCWB	60.4	62.0	66.0	70.3	74.2	75.3	74.7	74.1	72.5	71.7	67.4	64.5
	2%	DB	72.4	75.2	79.9	83.7	90.6	97.2	101.1	101.9	96.8	88.4	78.9	72.5
		MCWB	58.9	60.7	64.9	67.7	72.4	74.9	74.6	74.0	73.0	70.8	65.2	61.3
	5%	DB	68.3	71.7	76.5	81.3	88.0	94.4	98.7	99.5	93.5	84.8	75.1	69.1
		MCWB	57.9	61.1	63.2	67.4	72.1	74.3	75.1	74.5	72.8	69.0	63.9	60.5
	10%	DB	64.3	68.1	73.0	78.6	85.1	91.7	96.0	97.3	91.0	81.7	72.1	64.8
		MCWB	56.1	59.4	61.9	66.0	71.1	74.5	75.0	74.3	72.5	67.8	62.6	57.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.4	68.0	69.5	74.0	77.4	79.8	79.2	78.8	77.9	76.0	71.2	68.3
		MCDB	71.2	74.5	77.8	82.2	88.3	93.1	92.8	91.1	89.8	84.4	77.6	73.2
	2%	WB	64.1	66.1	67.9	71.6	75.7	78.1	78.1	77.7	76.6	74.2	68.8	65.7
		MCDB	67.9	71.3	75.4	80.0	85.5	90.3	92.0	92.0	88.1	82.4	74.3	70.6
	5%	WB	61.2	63.9	66.3	70.1	74.5	77.1	77.4	77.0	75.6	72.8	66.8	62.4
		MCDB	66.3	68.5	73.3	77.3	83.9	88.7	91.3	91.4	86.5	80.7	72.7	66.8
	10%	WB	56.8	60.8	64.4	68.7	73.3	76.1	76.7	76.2	74.8	71.2	64.4	58.3
		MCDB	62.5	67.1	71.0	75.4	82.2	87.3	90.1	90.3	85.4	78.4	70.4	64.0
Mean Daily Temperature Range	5% DB	MDBR	19.0	19.0	19.3	19.3	18.2	18.1	19.2	19.9	19.9	20.0	19.0	18.3
		MCDBR	24.3	22.9	21.8	20.7	20.4	20.7	21.4	22.0	22.1	22.1	21.5	22.8
		MCWBR	14.9	14.3	11.8	10.8	8.1	6.0	5.4	5.7	6.6	9.6	12.1	14.7
	5% WB	MCDBR	19.6	19.5	18.3	16.7	17.3	17.8	19.0	19.6	18.6	18.0	18.0	19.2
		MCWBR	15.5	15.3	12.2	10.8	8.5	6.5	5.9	5.7	6.5	9.1	13.3	16.1
Clear-Sky Solar Irradiance	taub	0.314	0.328	0.357	0.395	0.425	0.437	0.440	0.441	0.399	0.358	0.338	0.319	
	taud	2.504	2.471	2.408	2.322	2.299	2.296	2.329	2.307	2.373	2.477	2.474	2.492	
	Ebn at Noon	288	294	292	284	275	270	269	267	275	280	276	279	
	Edh at Noon	27	31	36	41	42	42	41	41	36	30	28	26	
All-Sky Solar Radiation	RadAvg	911	1061	1408	1712	1846	2077	2122	1949	1638	1286	967	803	
	RadStd	89	168	112	130	165	195	145	128	139	191	123	104	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page