

TERRELL COUNTY AP, TX, USA

WMO: 722616

Lat: 30.048N

Lon: 102.213W

Elev: 708

StdP: 93.11

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 03032

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.0	(c) -0.1	(d) -16.6	(e) 1.0	(f) 10.3	(g) -14.2	(h) 1.2	(i) 11.5	(j) 11.8	(k) 14.4	(l) 10.8	(m) 16.2	(n) 3.0	(o) 30	(p) 0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 12.3	(c) 39.0	(d) 21.0	(e) 37.8	(f) 20.9	(g) 36.6	(h) 20.9	(i) 24.1	(j) 32.3	(k) 23.6	(l) 31.7	(m) 23.1	(n) 31.1	(o) 5.4	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	18.5	26.0	21.6	17.7	25.9	21.2	17.2	25.9	76.0	32.2	74.1	31.7	72.2	31.1	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.8	(b) 9.2	(c) 8.4	(e) -5.6	(f) 41.9	(g) 3.0	(h) 2.5	(i) -7.7	(j) 43.7	(k) -9.4	(l) 45.2	(m) -11.1	(n) 46.6	(o) -13.3	(p) 48.4		
(a) 10.8	(b) 9.2	(c) 8.4	(e) -7.4	(f) 25.0	(g) 2.5	(h) 1.1	(i) -9.2	(j) 25.7	(k) -10.7	(l) 26.4	(m) -12.0	(n) 27.0	(o) -13.8	(p) 27.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	10.1	12.7	17.2	21.5	25.3	28.7	28.9	29.2	26.0	21.0	15.0	10.5		
	DBStd	7.90	4.45	5.10	4.41	3.91	3.57	2.40	2.26	2.34	2.91	3.93	4.34	4.40		
	HDD10.0	144	53	27	6	1	0	0	0	0	0	1	10	47		
	HDD18.3	890	255	164	72	15	2	0	0	0	1	21	116	245		
	CDD10.0	3994	57	103	230	346	473	559	586	596	481	341	159	62		
	CDD18.3	1698	1	7	38	111	217	309	328	338	232	102	15	2		
	CDH23.3	20181	37	156	459	1220	2437	3922	4124	4302	2411	909	157	46		
(14) Wind	WSAvg	4.1	3.7	4.0	4.3	4.6	4.7	4.7	4.4	3.9	3.8	3.7	3.5	3.6		
	PrecAvg	369	14	19	21	19	39	45	50	48	49	38	20	10		
	PrecMax	498	46	61	87	47	146	106	240	132	131	115	94	53		
	PrecMin	238	0	3	1	0	4	1	4	3	3	1	0	0		
	PrecStd	76	15	15	23	14	36	34	56	36	42	35	23	13		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	31.2	33.3	36.8	39.4	41.3	39.6	40.1	38.3	34.5	30.1	27.7		
		MCWB	11.6	13.1	14.2	16.7	18.3	21.4	21.9	21.6	19.6	18.9	15.8	12.2		
	2%	DB	23.8	27.6	30.5	34.2	37.2	38.9	38.0	38.6	36.1	32.1	27.3	24.1		
		MCWB	11.2	12.5	14.2	16.2	19.0	21.2	21.6	21.6	20.4	19.2	15.4	11.7		
	5%	DB	21.0	24.9	28.2	32.2	35.2	37.0	36.9	37.3	34.1	30.4	25.0	21.1		
		MCWB	10.4	12.1	14.6	16.2	18.4	21.4	21.4	21.4	20.2	18.5	14.7	11.1		
	10%	DB	18.0	21.7	25.7	29.8	33.1	35.2	35.6	35.9	32.7	28.4	22.7	18.0		
		MCWB	9.8	11.8	14.1	16.3	19.3	21.5	21.4	21.4	20.3	18.4	14.0	10.1		
	0.4%	WB	16.0	17.4	19.6	21.5	24.0	24.8	24.7	24.2	24.0	23.1	20.3	16.6		
		MCDB	18.9	22.3	25.5	28.9	31.2	34.4	32.2	32.9	31.3	28.6	24.1	19.9		
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	14.3	16.1	18.6	20.6	23.0	24.0	23.9	23.5	23.2	22.0	19.1	14.9		
		MCDB	19.1	20.3	24.1	27.8	29.8	32.6	32.3	32.4	30.3	27.3	22.4	18.0		
	5%	WB	12.4	14.7	17.7	19.9	22.4	23.5	23.3	23.0	22.6	21.2	17.4	13.4		
		MCDB	17.3	20.3	22.8	26.2	29.0	31.8	31.4	32.1	29.4	26.3	21.0	17.9		
	10%	WB	10.8	13.0	16.7	19.2	21.7	23.0	22.8	22.6	22.0	20.3	15.9	11.6		
		MCDB	16.9	20.3	21.9	25.0	28.2	30.9	30.7	31.5	28.4	25.3	20.8	17.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	14.1	14.4	14.4	13.4	12.7	11.9	12.3	11.8	12.6	13.0	12.9		
		MCDBR	17.6	18.6	17.9	17.4	16.6	15.2	14.0	14.0	14.0	14.7	15.7	17.2		
		MCWBR	8.8	8.4	7.1	7.0	6.3	4.5	4.3	4.2	4.7	5.5	7.2	8.5		
	5% WB	MCDBR	13.9	13.9	12.1	13.0	12.5	12.2	11.6	12.1	11.1	11.0	11.3	12.2		
		MCWBR	8.1	7.8	5.9	5.9	5.3	4.3	3.8	3.9	3.8	4.6	6.2	7.3		
(40) Clear-Sky Solar Irradiance	taub		0.271	0.279	0.297	0.333	0.359	0.377	0.392	0.368	0.359	0.315	0.291	0.272		
	taud		2.616	2.587	2.534	2.428	2.396	2.411	2.406	2.494	2.448	2.581	2.571	2.603		
	Ebn at Noon		981	998	993	959	928	906	892	914	914	943	946	961		
	Edh at Noon		79	89	100	116	121	118	119	107	108	89	82	76		
(44) All-Sky Solar Radiation	RadAvg		3.58	4.46	5.65	6.65	7.01	7.33	6.99	6.57	5.55	4.66	3.79	3.27		
	RadStd		0.36	0.47	0.34	0.46	0.44	0.37	0.46	0.37	0.38	0.51	0.40	0.30		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page