

FORT STOCKTON, TX, USA

WMO: 722618

Lat: 30.912N

Lon: 102.917W

Elev: 3010

StdP: 13.17

Time Zone: -6.00 (NAC)

Period: 98-19

WBAN: 23091

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.7	28.1	0.2	6.2	52.8	3.4	7.3	54.7	28.9	61.0	25.7	59.1	8.1	40	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.4	101.5	65.7	99.3	66.4	97.2	66.4	72.5	88.1	71.5	87.4	70.8	86.5	10.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.9	118.9	76.5	67.6	113.7	75.8	66.4	108.6	75.9	38.2	87.7	37.2	87.5	36.5	86.8	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.7	23.0	20.1	18.1	106.1	3.9	2.3	15.3	107.8	13.0	109.1	10.8	110.4	7.9	112.1		
			16.1	74.3	3.9	1.4	13.2	75.4	10.9	76.2	8.7	77.0	5.9	78.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	49.5	53.8	60.6	68.9	76.3	82.6	82.7	82.5	76.5	68.1	57.3	49.8
	DBStd	14.56	9.82	10.23	9.07	7.98	7.16	4.80	4.06	3.99	5.62	7.96	9.21	9.39
	HDD50	391	131	72	22	2	0	0	0	0	0	4	39	121
	HDD65	1856	484	327	188	54	11	0	0	0	3	61	253	475
	CDD50	6763	116	177	352	568	816	979	1014	1007	796	565	259	114
	CDD65	2753	4	12	53	170	362	529	549	542	349	157	23	3
	CDH74	33038	100	270	843	2143	4394	6616	6688	6508	3486	1554	350	86
	CDH80	17082	11	64	277	977	2380	3778	3685	3565	1651	607	79	8
Wind	WSAvg	10.8	10.0	11.0	11.6	12.3	12.1	12.4	11.0	9.8	9.7	10.1	9.7	9.8
Precipitation	PrecAvg	13.7	0.5	0.6	0.4	0.7	1.5	1.7	1.6	1.8	2.5	1.4	0.7	0.6
	PrecMax	25.1	1.7	2.6	1.7	4.6	5.8	4.2	4.3	5.5	10.1	8.3	3.6	2.9
	PrecMin	6.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.6	0.5	0.7	0.4	0.9	1.3	1.2	1.2	1.2	2.2	1.7	0.9	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.4	86.5	90.4	96.6	102.2	106.2	102.3	102.1	99.3	93.1	87.0	81.1
		MCWB	52.9	54.6	56.2	59.0	62.9	64.6	68.3	67.9	65.9	63.5	58.3	53.2
	2%	DB	76.9	81.4	86.9	92.8	99.3	102.2	99.5	99.3	95.3	90.2	81.8	76.2
		MCWB	51.7	52.6	55.0	57.7	62.6	65.2	68.4	68.0	66.2	63.4	56.6	51.6
	5%	DB	72.2	77.1	82.6	90.1	96.4	99.4	97.4	97.1	92.4	87.2	78.6	71.6
		MCWB	49.9	51.5	54.7	57.6	60.9	65.8	68.3	68.2	66.1	62.3	55.4	50.4
	10%	DB	65.9	72.1	79.2	86.2	92.5	96.6	95.0	94.7	89.7	82.9	73.3	65.5
		MCWB	47.6	49.8	53.4	56.9	61.2	66.4	68.1	68.1	66.4	61.4	54.4	48.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.9	59.3	64.3	67.8	71.4	73.9	74.1	73.3	72.4	70.8	64.6	58.1
		MCDB	70.0	71.9	75.9	80.8	85.9	90.0	88.4	88.1	85.7	83.4	73.7	69.0
	2%	WB	54.1	56.2	61.6	65.6	69.5	72.4	72.2	71.9	71.1	68.9	61.2	54.4
		MCDB	68.9	70.5	72.0	77.5	82.3	88.6	88.3	88.1	84.8	80.0	70.8	68.4
	5%	WB	51.5	53.8	59.5	63.6	68.3	71.2	71.2	71.0	70.0	67.3	59.0	52.0
		MCDB	67.8	71.4	70.9	75.8	81.2	87.1	87.5	87.6	83.0	77.7	71.1	67.4
	10%	WB	49.0	51.5	57.0	61.5	66.9	70.2	70.4	70.2	69.0	65.7	56.8	49.4
		MCDB	65.4	70.0	71.1	76.0	80.5	85.9	86.5	86.7	81.5	76.0	70.1	64.8
Mean Daily Temperature Range	5% DB	MDBR	24.4	26.0	27.0	27.8	26.3	24.7	22.4	22.6	21.9	23.7	24.2	23.9
		MCDBR	31.4	32.8	32.4	32.0	30.8	28.8	25.9	25.6	26.2	27.9	30.3	30.5
		MCWBR	15.0	14.9	13.2	12.9	11.8	8.2	7.0	6.6	7.9	10.1	12.8	14.4
	5% WB	MCDBR	28.0	29.2	27.2	27.1	26.1	24.3	21.7	22.0	21.0	21.7	25.4	27.4
		MCWBR	14.8	15.0	12.8	12.9	11.7	8.2	6.5	6.6	6.9	9.4	12.5	14.2
Clear-Sky Solar Irradiance	taub	0.261	0.269	0.289	0.324	0.344	0.370	0.389	0.365	0.347	0.302	0.283	0.263	
	taud	2.606	2.580	2.514	2.408	2.399	2.387	2.375	2.448	2.453	2.580	2.557	2.599	
	Ebn at Noon	314	319	317	306	299	289	283	290	293	303	302	307	
	Edh at Noon	25	28	32	37	38	38	39	36	34	28	26	24	
All-Sky Solar Radiation	RadAvg	1139	1422	1815	2175	2305	2368	2238	2088	1777	1489	1200	1039	
	RadStd	109	141	114	136	140	108	123	107	114	152	118	89	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	+275	+198

Nomenclature: See separate page