

CLINES CORNERS, NM, USA

WMO: 722677

Lat: 35.003N

Lon: 105.663W

Elev: 2160

StdP: 77.93

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 03027

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.6	-10.3	-21.3	0.7	0.7	-19.1	0.9	2.4	17.4	5.0	15.9	3.8	5.8	300	0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	31.4	13.5	30.2	13.4	28.9	13.4	16.5	25.0	16.0	24.5	15.5	24.0	5.6	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.1	13.1	17.6	13.6	12.7	17.6	12.9	12.1	17.6	54.3	25.2	52.6	24.3	50.9	24.0	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 15.5	14.0	12.2	DB	-17.2	33.7	3.1	1.3	-19.4	34.7	-21.2	35.4	-22.9	36.2	-25.1	37.2	(4)
(5)			WB	-17.7	17.8	3.0	1.0	-19.8	18.5	-21.6	19.1	-23.2	19.7	-25.4	20.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	0.0	2.0	5.8	9.4	14.3	19.9	21.3	20.3	17.0	10.8	4.8	-0.1
	DBStd	8.62	4.39	4.92	4.48	4.19	4.06	2.79	2.09	2.16	3.03	4.07	4.76	4.57
	HDD10.0	1263	312	224	141	59	12	0	0	0	1	39	162	312
	HDD18.3	3109	569	457	390	268	134	16	3	8	57	232	406	570
	CDD10.0	1447	0	1	9	42	144	296	350	319	212	66	7	0
	CDD18.3	251	0	0	0	0	8	62	95	68	17	0	0	0
	CDH23.3	3038	0	0	0	10	203	911	959	678	263	13	0	0
	CDH26.7	897	0	0	0	0	34	318	318	186	41	0	0	0
Wind	WSAvg	6.0	7.0	7.1	6.7	7.0	6.2	5.5	4.5	4.4	4.9	5.8	6.6	7.0
Precipitation	PrecAvg	432	19	17	22	21	36	36	71	77	45	35	20	25
	PrecMax	613	47	40	50	104	113	95	123	130	102	95	44	64
	PrecMin	337	3	4	4	0	7	7	18	34	4	5	1	2
	PrecStd	69	13	11	15	22	26	20	27	27	25	26	13	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	17.4	21.7	24.8	29.4	33.5	32.7	31.9	29.6	25.0	19.8	14.7
		MCWB	3.9	5.5	7.0	8.7	11.5	13.1	14.3	14.1	13.6	10.4	6.8	4.4
	2%	DB	11.7	15.2	19.1	22.4	27.5	31.7	31.3	30.2	27.8	22.9	17.7	12.0
		MCWB	3.1	4.5	6.1	7.7	10.6	12.5	14.2	14.3	12.9	9.9	6.2	3.3
	5%	DB	9.7	13.0	17.2	20.7	25.9	30.1	30.0	28.8	26.4	21.2	15.8	9.6
		MCWB	2.0	3.6	5.4	7.2	9.9	12.1	14.2	14.4	12.4	9.2	5.6	2.3
	10%	DB	7.4	10.6	15.0	18.9	23.8	28.6	28.5	27.4	24.8	19.1	13.0	7.3
		MCWB	0.9	2.5	4.4	6.5	9.1	11.9	14.4	14.6	12.3	8.5	4.2	1.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	6.6	8.1	10.4	13.6	16.1	17.3	17.2	15.7	13.9	8.4	5.7
		MCDB	11.9	15.3	18.1	19.1	23.0	25.5	25.7	25.4	22.7	19.4	16.0	11.7
	2%	WB	3.7	5.2	6.8	9.2	12.3	15.2	16.6	16.6	14.9	12.1	7.2	4.1
		MCDB	10.1	13.5	16.8	18.9	22.7	24.6	25.2	24.8	22.5	18.3	14.6	10.0
	5%	WB	2.4	4.0	5.9	8.0	11.3	14.4	16.1	16.1	14.2	10.8	6.1	2.9
		MCDB	8.3	11.5	15.5	18.0	21.7	24.0	24.8	24.3	21.9	17.4	13.9	8.7
	10%	WB	1.3	2.9	4.9	7.0	10.3	13.7	15.6	15.5	13.6	9.6	5.0	1.6
		MCDB	6.7	9.6	14.1	17.2	20.5	23.5	24.3	23.8	21.2	16.5	12.2	6.9
Mean Daily Temperature Range	5% DB	MDBR	11.5	12.6	14.5	15.3	15.2	15.9	14.2	13.5	13.8	13.7	13.0	11.1
		MCDBR	14.3	15.8	17.1	17.5	17.3	17.6	16.4	15.5	15.8	15.9	15.5	13.7
		MCWBR	8.1	8.4	8.2	8.2	7.5	6.5	5.2	5.0	5.8	7.3	7.7	7.8
	5% WB	MCDBR	12.9	14.4	15.8	16.3	15.5	15.0	13.5	13.1	13.3	13.2	13.9	12.3
		MCWBR	7.7	7.9	7.9	7.9	6.9	5.7	4.6	4.6	5.1	6.6	7.4	7.5
Clear-Sky Solar Irradiance	taub	0.224	0.233	0.255	0.270	0.288	0.313	0.344	0.325	0.292	0.267	0.240	0.229	
	taud	2.675	2.653	2.578	2.529	2.524	2.440	2.438	2.466	2.553	2.599	2.622	2.647	
	Ebn at Noon	1020	1038	1029	1017	993	963	931	947	972	980	986	993	
	Edh at Noon	68	78	93	103	105	114	114	108	94	82	71	66	
All-Sky Solar Radiation	RadAvg	3.30	4.25	5.58	6.80	7.55	7.79	6.92	6.46	5.71	4.62	3.56	2.89	
	RadStd	0.24	0.34	0.38	0.38	0.39	0.40	0.35	0.29	0.28	0.39	0.23	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+72	+46

Nomenclature: See separate page