

CLOVIS, NM, USA

WMO: 722689

Lat: 34.433N

Lon: 103.083W

Elev: 4216

StdP: 12.59

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23077

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	17.6	-0.1	6.4	25.0	2.9	7.4	30.3	35.8	50.5	32.5	49.5	9.8	10	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.0	97.4	64.4	94.8	64.2	91.8	64.2	69.7	85.1	68.7	84.5	67.9	83.9	13.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	111.3	73.8	64.2	105.3	72.7	63.4	102.4	72.3	36.5	85.2	35.6	84.0	34.8	84.4	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.0	27.4	24.4	4.9	101.5	6.3	2.4	0.4	103.2	-3.3	104.6	-6.8	106.0	-11.4	107.7
			3.8	72.0	5.7	1.4	-0.4	73.0	-3.7	73.9	-6.9	74.6	-11.1	75.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	38.3	41.8	48.8	56.2	65.5	74.6	77.1	75.7	69.1	57.9	47.0	38.3	(6)
(7)		DBStd	16.00	9.07	9.80	8.99	8.09	7.42	4.91	3.79	4.09	6.15	8.01	8.81	9.14	(7)
(8)		HDD50	1346	372	254	129	36	3	0	0	0	0	26	154	372	(8)
(9)		HDD65	3984	827	650	503	275	84	3	0	1	32	241	541	827	(9)
(10)		CDD50	4118	9	24	91	221	483	737	840	796	574	270	63	10	(10)
(11)		CDD65	1281	0	0	0	10	99	290	375	331	156	20	0	0	(11)
(12)		CDH74	15967	0	14	128	484	1703	3625	4320	3493	1718	445	37	0	(12)
(13)		CDH80	7650	0	1	19	117	746	1916	2284	1747	704	115	1	0	(13)
(14)	Wind	WSAvg	11.7	12.3	12.7	13.1	13.7	12.6	11.8	9.8	9.1	9.9	11.1	11.9	12.2	(14)
(15)	Precipitation	PrecAvg	18.5	0.6	0.4	1.1	1.4	1.6	2.2	2.2	3.1	2.2	1.9	0.7	0.9	(15)
(16)		PrecMax	31.2	1.5	1.5	3.3	5.1	4.6	5.1	7.6	7.1	5.3	6.8	3.2	3.5	(16)
(17)		PrecMin	11.9	0.0	0.0	0.0	0.4	0.1	0.1	0.0	0.8	0.2	0.4	0.0	0.1	(17)
(18)		PrecStd	4.8	0.5	0.4	0.8	1.2	1.4	1.5	1.6	1.5	1.2	1.8	0.7	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.4	75.4	82.1	88.1	96.2	100.8	99.8	99.1	94.5	88.0	78.9	70.3	(19)
(20)		MCWB	47.3	49.6	53.0	56.0	60.2	63.2	64.9	65.6	63.1	59.7	52.4	47.5	(20)	
(21)		2%	DB	65.6	71.6	77.9	82.9	91.3	97.6	97.1	95.0	90.8	82.4	73.3	64.4	(21)
(22)		MCWB	45.6	47.7	51.2	53.6	58.5	62.8	65.8	65.9	62.8	57.9	51.2	45.6	(22)	
(23)		5%	DB	61.1	65.9	73.1	80.5	88.4	94.1	93.4	91.7	88.1	79.4	69.7	61.0	(23)
(24)		MCWB	43.0	46.2	49.3	52.9	58.0	62.8	65.8	66.1	63.1	56.7	49.9	43.6	(24)	
(25)		10%	DB	55.1	61.1	68.7	75.2	83.8	90.8	91.1	90.0	83.9	74.5	63.7	54.9	(25)
(26)		MCWB	40.4	43.3	48.1	51.6	57.5	63.1	66.0	66.0	63.0	55.4	47.5	41.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	52.2	57.3	60.6	66.3	70.0	71.2	71.3	69.2	66.5	56.7	50.6	(27)
(28)		MADB	65.7	69.3	70.0	72.8	80.0	86.3	86.2	84.7	81.9	74.9	68.5	62.8	(28)	
(29)		2%	WB	46.3	49.2	53.4	57.9	64.1	68.4	69.5	69.9	67.6	63.6	53.5	47.4	(29)
(30)		MADB	63.2	67.1	69.5	71.5	78.5	84.8	86.1	84.6	81.2	71.4	66.0	62.6	(30)	
(31)		5%	WB	43.9	46.8	51.1	55.5	62.3	67.2	68.5	68.8	66.2	60.5	51.1	44.5	(31)
(32)		MADB	59.2	64.8	70.3	71.2	76.7	83.7	85.5	84.1	79.6	70.9	65.9	58.7	(32)	
(33)		10%	WB	41.3	44.3	49.0	53.4	60.5	65.9	67.7	67.9	64.9	58.1	48.7	41.7	(33)
(34)		MADB	54.9	59.5	66.3	72.1	75.8	82.7	85.0	83.4	77.9	70.5	62.5	54.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	27.5	28.9	30.5	30.6	29.4	29.0	27.0	25.8	25.7	27.1	27.5	26.1	(35)	
(36)		5% DB	MADB	34.7	37.2	38.2	37.3	36.2	34.6	31.1	30.2	31.2	33.7	35.0	33.6	(36)
(37)		MCWBR	19.4	19.7	18.4	16.8	14.7	11.4	9.7	9.8	11.2	14.8	17.4	18.5	(37)	
(38)		5% WB	MADB	32.8	35.3	34.9	31.8	29.5	28.0	26.6	25.2	24.9	25.5	30.8	31.4	(38)
(39)		MCWBR	18.8	19.3	17.8	16.3	13.5	10.3	9.3	9.3	10.2	13.5	16.5	18.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.248	0.257	0.285	0.309	0.324	0.364	0.375	0.361	0.330	0.299	0.271	0.255	(40)	
(41)		taud	2.598	2.588	2.508	2.436	2.456	2.378	2.397	2.414	2.472	2.535	2.543	2.574	(41)	
(42)		Ebn at Noon	313	320	316	310	304	290	286	290	296	299	300	303	(42)	
(43)		Edh at Noon	24	27	32	36	36	38	38	36	33	28	25	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1058	1332	1732	2142	2352	2471	2338	2124	1809	1418	1112	914	(44)	
(45)		RadStd	84	107	124	128	147	123	105	99	108	140	97	57	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+198	+113

Nomenclature: See separate page