

CLOVIS, NM, USA

WMO: 722689

Lat: 34.433N

Lon: 103.083W

Elev: 1285

StdP: 86.81

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23077

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.0	-8.0	-17.8	0.9	-3.9	-16.2	1.1	-0.9	16.0	10.3	14.5	9.7	4.4	10	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	36.3	18.0	34.9	17.9	33.2	17.9	21.0	29.5	20.4	29.2	19.9	28.9	6.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	15.9	23.2	17.9	15.0	22.6	17.5	14.6	22.4	67.1	29.5	64.9	28.9	63.0	29.1	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
14.3	12.2	10.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-15.0	38.6	3.5	1.3	-17.6	39.6	-19.6	40.3	-21.6	41.1	-24.1	42.0		
			-15.7	22.2	3.2	0.8	-18.0	22.8	-19.8	23.3	-21.6	23.7	-23.9	24.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	3.5	5.4	9.3	13.4	18.6	23.6	25.1	24.3	20.6	14.4	8.3	3.5
	DBStd	8.89	5.04	5.45	4.99	4.49	4.12	2.73	2.11	2.27	3.42	4.45	4.90	5.08
	HDD10.0	748	207	141	72	20	2	0	0	0	0	14	86	207
	HDD18.3	2213	459	361	279	153	47	2	0	1	18	134	301	459
	CDD10.0	2288	5	13	51	123	268	409	467	442	319	150	35	6
	CDD18.3	712	0	0	0	6	55	161	208	184	87	11	0	0
	CDH23.3	8871	0	8	71	269	946	2014	2400	1941	954	247	21	0
	CDH26.7	4250	0	1	11	65	414	1064	1269	971	391	64	1	0
Wind	WSAvg	5.2	5.5	5.7	5.9	6.1	5.6	5.3	4.4	4.1	4.4	4.9	5.3	5.5
Precipitation	PrecAvg	471	14	9	27	35	40	57	57	79	55	49	18	22
	PrecMax	793	38	38	84	130	118	129	194	181	134	173	81	90
	PrecMin	301	0	0	0	10	2	3	0	21	4	10	0	3
	PrecStd	122	13	10	21	30	36	38	41	39	31	45	19	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.4	24.1	27.8	31.2	35.7	38.2	37.7	37.3	34.7	31.1	26.0	21.3
		MCWB	8.5	9.8	11.7	13.3	15.7	17.3	18.3	18.7	17.3	15.4	11.4	8.6
	2%	DB	18.7	22.0	25.5	28.3	32.9	36.4	36.2	35.0	32.7	28.0	22.9	18.0
		MCWB	7.5	8.7	10.7	12.0	14.7	17.1	18.8	18.8	17.1	14.4	10.7	7.6
	5%	DB	16.1	18.9	22.8	27.0	31.3	34.5	34.1	33.2	31.2	26.3	20.9	16.1
		MCWB	6.1	7.9	9.6	11.6	14.4	17.1	18.8	18.9	17.3	13.7	9.9	6.4
	10%	DB	12.9	16.2	20.4	24.0	28.8	32.6	32.8	32.2	28.8	23.6	17.6	12.7
		MCWB	4.7	6.3	8.9	10.9	14.2	17.3	18.9	18.9	17.2	13.0	8.6	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	11.2	14.1	15.9	19.0	21.1	21.8	21.8	20.7	19.2	13.7	10.3
		MCDB	18.7	20.7	21.1	22.6	26.7	30.2	30.1	29.3	27.7	23.8	20.3	17.1
	2%	WB	7.9	9.6	11.9	14.4	17.8	20.2	20.8	21.0	19.8	17.6	11.9	8.6
		MCDB	17.3	19.5	20.8	21.9	25.8	29.3	30.1	29.2	27.3	21.9	18.9	17.0
	5%	WB	6.6	8.2	10.6	13.0	16.8	19.5	20.3	20.5	19.0	15.8	10.6	7.0
		MCDB	15.1	18.2	21.3	21.8	24.8	28.7	29.7	28.9	26.4	21.6	18.8	14.8
	10%	WB	5.2	6.8	9.5	11.9	15.8	18.9	19.9	19.9	18.3	14.5	9.3	5.4
		MCDB	12.7	15.3	19.1	22.3	24.3	28.2	29.4	28.5	25.5	21.4	17.0	12.6
Mean Daily Temperature Range	5% DB	MDBR	15.3	16.0	16.9	17.0	16.3	16.1	15.0	14.4	14.3	15.0	15.3	14.5
		MCDBR	19.3	20.7	21.2	20.7	20.1	19.2	17.3	16.8	17.4	18.7	19.4	18.7
		MCWBR	10.8	10.9	10.2	9.4	8.2	6.3	5.4	5.4	6.2	8.2	9.7	10.3
	5% WB	MCDBR	18.2	19.6	19.4	17.7	16.4	15.6	14.8	14.0	13.8	14.2	17.1	17.4
		MCWBR	10.5	10.7	9.9	9.0	7.5	5.7	5.1	5.2	5.7	7.5	9.2	10.1
Clear-Sky Solar Irradiance	taub	0.248	0.257	0.285	0.309	0.324	0.364	0.375	0.361	0.330	0.299	0.271	0.255	
	taud	2.598	2.588	2.508	2.436	2.456	2.378	2.397	2.414	2.472	2.535	2.543	2.574	
	Ebn at Noon	986	1008	995	976	959	915	903	913	932	942	945	956	
	Edh at Noon	75	84	100	113	113	121	119	114	103	88	78	72	
All-Sky Solar Radiation	RadAvg	3.34	4.20	5.46	6.75	7.42	7.79	7.37	6.70	5.70	4.47	3.51	2.88	
	RadStd	0.27	0.34	0.39	0.40	0.46	0.39	0.33	0.31	0.34	0.44	0.31	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)		+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	+63

Nomenclature: See separate page