

LAS CRUCES, NM, USA

WMO: 722695

Lat: 32.283N

Lon: 106.917W

Elev: 1358

StdP: 86.04

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 93041

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.0	-2.9	-22.5	0.6	10.6	-19.8	0.8	9.2	13.6	10.5	11.7	10.9	1.7	320	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	16.1	37.6	16.5	36.6	16.4	35.2	16.4	21.7	27.1	20.9	27.0	20.1	26.6	3.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	18.4	23.5	19.0	16.3	22.7	18.0	15.3	22.7	70.4	27.4	67.5	27.9	64.0	26.4	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.1	8.4	DB	-9.3	40.1	2.5	1.1	-11.1	40.9	-12.6	41.5	-14.0	42.1	-15.9	42.8	(4)
(5)			WB	-10.8	21.6	2.6	1.4	-12.7	22.6	-14.2	23.4	-15.7	24.2	-17.6	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	6.8	9.0	13.1	17.0	21.3	27.1	27.6	26.5	23.3	17.7	11.1	6.6	
	DBStd	8.25	3.42	4.03	3.79	3.39	3.43	2.37	2.19	2.07	2.49	3.66	3.93	3.72	
	HDD10.0	333	108	58	15	1	0	0	0	0	0	2	32	117	
	HDD18.3	1496	358	260	165	63	13	0	0	0	1	56	217	364	
	CDD10.0	2994	8	32	111	210	350	513	544	511	399	239	66	11	
	CDD18.3	1116	0	0	3	22	104	263	286	252	150	35	1	0	
	CDH23.3	14401	0	11	128	497	1596	3717	3509	2877	1574	463	29	0	
CDH26.7	7217	0	0	14	113	717	2178	1931	1472	669	122	1	0		
Wind	WSAvg	3.4	3.1	3.6	4.0	4.6	4.1	3.8	3.0	2.7	2.7	2.9	2.9	3.0	
Precipitation	PrecAvg	234	11	11	5	7	10	17	49	43	33	20	10	15	
	PrecMax	387	44	59	24	48	57	104	135	145	99	75	41	74	
	PrecMin	122	0	0	0	0	0	0	14	15	0	0	0	0	
	PrecStd	66	13	14	5	11	14	23	27	32	25	19	10	18	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	25.1	28.2	31.3	36.4	39.3	38.9	37.5	35.0	31.3	26.2	21.3	
		MCWB	7.8	9.3	11.0	11.9	14.5	16.0	17.1	17.8	16.5	15.7	11.0	8.9	
	2%	DB	18.6	22.4	26.5	29.1	34.1	37.9	37.5	36.2	33.5	29.5	23.8	18.7	
		MCWB	7.4	8.5	10.0	11.3	13.5	15.7	17.6	17.5	16.5	14.2	10.7	8.3	
	5%	DB	17.0	20.2	24.8	27.8	32.5	37.1	36.3	34.8	32.3	27.8	22.2	17.0	
		MCWB	6.5	7.8	9.3	10.7	12.9	15.5	17.4	17.7	16.2	13.5	10.2	7.4	
	10%	DB	14.8	17.7	22.7	26.7	31.0	35.7	34.8	33.0	31.0	26.2	19.5	14.1	
		MCWB	5.5	6.7	8.7	10.3	12.5	15.2	17.5	18.0	16.1	13.1	9.1	6.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	11.8	12.9	15.0	18.0	19.8	22.4	22.9	21.2	19.6	14.0	11.3
			MCDB	15.8	18.9	22.5	22.7	25.3	30.4	27.1	26.9	26.3	24.5	19.0	16.3
2%		WB	8.9	10.2	11.4	12.9	16.1	18.7	21.4	22.1	20.0	17.9	12.5	9.5	
		MCDB	15.1	19.2	22.8	24.8	24.8	29.1	26.7	27.5	25.0	24.0	18.9	16.0	
5%		WB	7.5	8.9	10.3	11.9	14.9	18.0	20.7	21.2	19.3	16.4	11.3	8.4	
		MCDB	14.7	18.5	22.2	24.6	26.5	29.3	27.0	27.3	24.5	22.1	18.9	14.9	
10%		WB	6.2	7.7	9.3	10.9	13.8	17.3	20.0	20.4	18.6	15.0	10.2	7.2	
		MCDB	13.4	17.5	21.5	24.8	26.6	29.7	27.0	26.8	24.2	22.2	18.8	13.3	
Mean Daily Temperature Range	5% DB	MDBR	14.1	15.0	16.0	16.5	16.7	16.1	13.5	13.2	13.5	14.7	14.9	13.6	
		MCDBR	17.0	18.3	18.8	18.2	18.3	17.7	15.3	15.1	15.8	16.6	17.4	16.1	
		MCWBR	9.0	9.0	8.9	8.2	7.7	6.4	4.2	3.8	4.8	7.0	8.1	8.2	
	5% WB	MCDBR	14.2	16.4	17.0	17.1	15.6	14.5	11.7	11.2	11.3	12.5	14.7	13.3	
		MCWBR	8.0	8.2	8.0	7.4	6.3	4.8	3.4	3.4	4.0	5.9	7.4	7.0	
Clear-Sky Solar Irradiance	taub	0.240	0.245	0.261	0.284	0.304	0.325	0.362	0.342	0.314	0.272	0.252	0.242		
	taud	2.676	2.663	2.578	2.474	2.466	2.432	2.415	2.453	2.511	2.637	2.643	2.663		
	Ebn at Noon	1012	1033	1029	1006	980	954	917	935	954	985	987	993		
	Edh at Noon	71	80	94	110	112	115	117	111	100	81	73	69		
All-Sky Solar Radiation	RadAvg	3.60	4.62	5.98	7.30	8.00	8.00	7.16	6.63	5.90	4.92	3.89	3.28		
	RadStd	0.26	0.35	0.32	0.30	0.26	0.34	0.33	0.23	0.27	0.36	0.23	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-91	+144	+82

Nomenclature: See separate page