

EL PASO, TX, USA

WMO: 722700

Lat: 31.811N

Lon: 106.376W

Elev: 3918

StdP: 12.73

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23044

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.7	28.8	-2.6	5.5	52.1	1.2	6.7	53.1	32.8	56.2	28.3	52.8	4.8	10	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	24.9	101.2	63.6	99.1	63.4	96.9	63.3	69.8	85.6	69.0	85.0	68.2	84.5	9.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	112.0	73.6	64.9	106.6	74.0	63.6	101.8	74.8	36.3	85.4	35.5	84.5	34.7	84.0	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	24.1	20.0	DB	18.6	105.6	5.3	2.5	14.8	107.3	11.8	108.8	8.8	110.2	5.0	111.9	(4)
(5)			WB	15.3	71.3	4.9	1.2	11.7	72.2	8.8	72.9	6.1	73.6	2.5	74.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	46.5	51.5	58.8	66.4	75.4	83.9	84.0	82.4	76.8	66.7	54.7	46.2		
	DBStd	15.15	6.54	7.58	7.41	7.07	6.00	4.92	4.26	4.15	4.96	6.98	7.13	7.06		
	HDD50	422	145	63	15	2	0	0	0	0	0	3	36	158		
	HDD65	2203	573	379	214	69	6	0	0	0	2	64	314	582		
	CDD50	6326	37	106	289	492	788	1018	1053	1003	804	519	176	41		
	CDD65	2631	0	2	22	110	329	568	588	538	355	115	4	0		
	CDH74	33427	1	38	362	1371	4234	8191	7599	6562	3781	1210	78	0		
	CDH80	17218	0	2	52	410	2030	4912	4276	3475	1698	360	3	0		
(14) Wind	WSAvg	8.5	7.7	8.9	9.9	11.2	10.4	9.1	8.0	7.4	7.2	7.4	7.3	7.5		
(15) Precipitation	PrecAvg	8.7	0.4	0.4	0.3	0.2	0.3	0.7	1.5	1.6	1.5	0.7	0.4	0.7		
	PrecMax	16.2	1.3	1.9	1.0	1.4	4.2	3.2	5.5	5.6	6.7	3.1	2.0	3.3		
	PrecMin	4.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	3.0	0.4	0.4	0.3	0.3	0.7	0.9	1.1	1.3	1.4	0.7	0.5	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.9	78.4	84.8	91.2	98.7	105.6	103.6	101.1	96.6	90.1	79.8	71.3		
		MCWB	48.3	50.2	52.6	56.6	61.1	62.9	64.9	66.0	63.8	61.0	54.2	49.4		
	2%	DB	67.4	74.2	81.1	87.3	95.4	102.2	100.5	98.4	93.7	86.9	76.4	67.5		
		MCWB	46.7	49.0	51.5	54.5	59.0	62.3	64.8	65.5	63.9	59.4	53.2	48.2		
	5%	DB	64.1	70.7	78.2	84.7	92.8	99.8	98.2	96.1	91.5	84.2	73.0	64.0		
		MCWB	45.5	47.7	50.5	53.6	58.3	61.8	65.0	65.8	63.2	58.3	52.1	46.4		
	10%	DB	60.8	67.1	75.1	82.0	90.0	97.5	95.7	93.8	89.1	81.2	69.5	60.3		
		MCWB	43.9	46.4	49.5	52.7	56.9	61.4	65.0	65.7	63.1	57.4	50.4	44.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.4	53.6	56.2	60.4	65.6	69.8	71.3	71.0	69.7	67.4	58.3	52.6		
		MCDB	63.2	68.9	76.0	81.8	89.2	92.1	86.7	86.6	83.8	78.2	70.6	63.6		
	2%	WB	49.1	51.3	53.8	57.6	63.0	67.9	70.0	69.5	68.3	64.2	56.0	50.1		
		MCDB	62.4	67.2	74.3	80.1	87.1	88.8	85.3	85.2	82.5	77.4	69.3	63.0		
	5%	WB	47.0	49.6	52.1	55.8	61.2	66.4	69.1	68.8	67.3	62.1	53.9	47.9		
		MCDB	61.0	66.5	72.9	78.4	84.0	87.3	84.6	85.0	81.5	77.1	68.5	61.5		
	10%	WB	45.0	47.7	50.5	54.0	59.7	65.1	68.3	68.1	66.2	60.1	52.0	45.9		
		MCDB	59.1	64.7	71.5	77.3	82.0	86.7	84.2	84.7	80.6	75.5	67.0	58.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.8	24.7	25.7	25.7	25.3	24.9	21.7	21.3	21.7	24.0	24.3	22.7		
		MCDBR	28.5	29.9	29.6	28.4	28.0	27.0	24.1	23.6	24.7	26.8	28.6	27.2		
		MCWBR	15.0	14.4	13.0	12.3	11.5	9.2	6.9	6.2	8.0	10.6	13.7	14.2		
	5% WB	MCDBR	24.9	25.8	26.9	27.1	26.7	24.6	21.0	20.8	20.1	22.0	24.2	22.8		
		MCWBR	13.9	12.9	12.4	12.8	11.4	8.5	5.7	5.8	6.6	9.1	12.2	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.245	0.250	0.264	0.296	0.317	0.335	0.371	0.348	0.325	0.278	0.259	0.247		
	taud		2.656	2.637	2.566	2.432	2.423	2.412	2.382	2.440	2.468	2.621	2.608	2.638		
	Ebn at Noon		320	326	325	315	307	300	288	295	299	311	310	313		
	Edh at Noon		23	26	30	36	37	37	38	36	33	26	24	23		
(44) All-Sky Solar Radiation	RadAvg		1163	1484	1914	2317	2537	2533	2276	2113	1880	1579	1251	1059		
	RadStd		81	105	104	105	88	102	101	79	79	111	76	55		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.03	+1.01	N/A	+1.10	N/A	N/A	N/A	-176	+351	+196
(47) Regional (9 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-164	+259	+148

Nomenclature: See separate page