

TRUTH OR CONSEQUENCES, NM, USA

WMO: 722710

Lat: 33.237N

Lon: 107.268W

Elev: 4850

StdP: 12.30

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 93045

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.0	25.5	-6.6	4.6	48.9	-2.9	5.6	48.1	28.3	48.4	24.9	47.1	6.6	310	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.7	98.5	61.3	96.3	60.7	93.7	60.6	67.1	83.0	66.1	82.2	65.3	81.6	10.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	105.2	69.4	62.5	101.5	70.1	60.8	95.6	71.2	34.2	82.3	33.5	81.4	32.8	81.0	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.8	22.1	19.0	DB	15.9	102.8	5.1	2.1	12.2	104.3	9.3	105.5	6.4	106.7	2.7	108.3	(4)
(5)			WB	12.7	68.8	4.7	1.6	9.4	69.9	6.6	70.8	4.0	71.7	0.6	72.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	42.8	47.4	54.4	61.1	70.2	79.5	80.5	78.4	72.7	62.4	50.6	42.0		
	DBStd	15.10	6.40	7.47	7.19	6.81	6.27	4.92	4.12	3.90	4.88	6.97	7.27	6.95		
	HDD50	750	235	123	40	6	0	0	0	0	0	7	79	260		
	HDD65	2968	688	492	332	150	25	0	0	0	6	129	434	712		
	CDD50	5094	11	51	178	338	626	885	945	879	681	391	96	13		
	CDD65	1839	0	0	4	33	186	436	480	414	237	49	0	0		
	CDH74	21837	0	8	119	600	2422	5774	5563	4377	2378	581	15	0		
	CDH80	10431	0	0	10	121	998	3223	2926	2093	933	127	0	0		
(14) Wind	WSAvg	8.2	7.1	8.4	9.4	10.4	10.1	9.1	7.6	7.1	7.1	7.7	7.4	6.9		
(15) Precipitation	PrecAvg	9.4	0.3	0.2	0.2	0.2	0.2	0.7	1.6	1.6	2.1	1.1	0.4	0.6		
	PrecMax	14.6	0.9	1.0	0.8	1.0	1.0	2.9	3.4	4.7	5.1	5.6	1.9	1.7		
	PrecMin	5.1	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.1	0.2	0.0	0.0	0.0		
	PrecStd	3.1	0.3	0.3	0.2	0.2	0.3	0.8	0.9	1.2	1.3	1.5	0.5	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.3	74.8	81.5	87.3	96.0	102.2	100.4	98.0	93.4	87.2	76.1	67.7		
		MCWB	45.4	47.5	50.8	53.6	58.3	61.6	63.0	63.0	61.5	57.3	50.6	46.6		
	2%	DB	63.5	70.2	77.4	83.4	91.8	99.2	98.0	95.3	90.7	83.4	72.6	63.2		
		MCWB	43.7	46.3	48.8	51.5	56.1	60.5	62.3	63.0	60.6	56.1	49.7	44.9		
	5%	DB	60.0	66.1	73.8	80.7	89.0	96.9	95.5	92.8	88.5	80.7	69.0	58.9		
		MCWB	42.3	44.5	47.4	50.9	55.1	59.2	62.1	63.0	60.2	55.0	48.0	42.7		
	10%	DB	56.0	62.4	70.3	77.5	85.9	94.2	92.9	90.4	85.9	77.0	64.8	54.9		
		MCWB	40.4	43.0	46.3	49.2	53.8	58.4	62.5	63.0	59.8	53.7	46.4	40.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	50.1	52.8	56.1	61.7	67.5	68.7	68.1	66.1	63.7	54.0	48.7		
		MCDB	62.7	67.0	74.2	80.5	89.5	93.0	86.1	81.5	79.2	72.5	67.6	62.0		
	2%	WB	45.4	47.8	50.4	53.9	59.2	64.7	67.3	66.8	64.6	60.0	51.6	46.4		
		MCDB	60.0	65.8	72.5	77.3	84.7	86.9	83.0	82.0	78.1	75.0	65.3	59.6		
	5%	WB	43.4	46.0	48.7	52.0	57.4	63.1	66.3	66.0	63.7	58.0	49.8	44.1		
		MCDB	57.5	62.7	70.2	75.6	81.4	85.4	82.1	81.9	77.9	73.4	64.8	56.4		
	10%	WB	41.4	44.1	47.1	50.3	55.8	61.7	65.5	65.2	62.6	56.0	47.9	41.9		
		MCDB	54.3	60.6	68.1	74.3	79.6	85.2	81.4	81.7	77.6	71.3	63.3	53.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	24.1	25.4	26.7	27.7	27.4	27.4	23.7	23.0	23.8	24.8	24.4	22.8		
		MCDBR	29.1	29.9	30.5	30.6	29.9	29.3	26.6	25.7	26.9	28.2	28.9	26.6		
		MCWBR	15.7	15.1	14.4	14.0	13.1	11.9	8.2	7.7	9.6	12.2	14.6	14.4		
	5% WB	MCDBR	26.5	26.9	28.4	29.0	28.0	26.3	22.3	22.3	21.6	23.8	25.2	24.2		
		MCWBR	14.9	13.8	13.9	14.0	13.0	10.7	6.7	6.7	8.0	11.0	13.5	13.6		
(40) Clear-Sky Solar Irradiance	taub		0.238	0.242	0.261	0.282	0.300	0.323	0.365	0.342	0.312	0.272	0.249	0.239		
	taud		2.701	2.696	2.602	2.517	2.516	2.456	2.441	2.477	2.553	2.654	2.674	2.690		
	Ebn at Noon		321	328	325	319	312	303	290	296	303	312	313	315		
	Edh at Noon		22	24	29	33	34	36	36	34	30	25	22	21		
(44) All-Sky Solar Radiation	RadAvg		1118	1440	1868	2283	2489	2469	2164	2017	1828	1537	1211	1011		
	RadStd		86	119	106	105	122	148	119	73	86	122	71	52		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-202	+302	+173
(47) Regional (11 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-160	+263	+149

Nomenclature: See separate page