

DEMING, NM, USA

WMO: 722725

Lat: 32.262N

Lon: 107.721W

Elev: 4301

StdP: 12.55

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 23078

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	19.6	23.2	-5.4	4.8	46.8	-1.3	6.0	47.0	28.8	48.9	26.2	50.3	4.0	310	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.9	100.1	62.3	98.4	62.3	96.1	61.9	68.4	83.3	67.6	82.9	66.8	82.5	10.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	109.1	70.7	64.0	104.9	70.6	62.9	100.9	71.2	35.1	82.2	34.4	82.3	33.7	82.4	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.5	23.3	19.7	DB	12.5	104.3	4.3	1.4	9.5	105.3	7.0	106.2	4.6	106.9	1.5	108.0	(4)
(5)			WB	10.0	70.1	4.1	1.0	7.0	70.8	4.6	71.4	2.3	71.9	-0.7	72.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	42.4	46.7	53.9	61.0	69.0	79.4	81.2	79.0	73.1	62.6	50.7	42.5
	DBStd	15.01	5.77	6.80	6.42	5.80	5.81	4.26	3.81	3.67	4.49	6.26	6.90	6.37
	HDD50	724	239	127	36	2	0	0	0	0	0	4	74	242
	HDD65	2972	699	512	344	143	28	0	0	0	3	117	430	696
	CDD50	5059	5	35	158	332	590	883	966	898	693	395	94	10
	CDD65	1831	0	0	1	22	152	433	501	433	245	44	0	0
	CDH74	25561	0	20	221	887	2892	6595	6157	4966	2913	856	54	0
	CDH80	13238	0	0	23	209	1328	3989	3506	2627	1320	234	2	0
Wind	WSAvg	8.5	8.1	9.1	9.8	10.9	10.0	9.2	8.0	7.2	7.4	7.5	7.7	7.8
Precipitation	PrecAvg	8.9	0.6	0.4	0.3	0.1	0.2	0.3	1.9	1.6	1.3	0.8	0.4	0.8
	PrecMax	13.9	1.3	1.5	2.0	0.6	0.7	1.0	6.3	3.9	3.5	2.9	2.2	1.9
	PrecMin	4.9	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.2	0.0	0.0	0.0	0.0
	PrecStd	2.9	0.4	0.4	0.5	0.2	0.2	0.3	1.4	1.0	1.0	0.9	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.3	77.2	82.8	88.3	97.2	103.4	102.1	99.9	96.1	88.8	79.1	70.3
		MCWB	46.5	49.4	51.8	53.9	59.7	60.5	63.9	64.2	62.1	59.2	52.3	47.8
	2%	DB	65.0	72.6	79.4	84.7	93.3	100.9	99.7	97.5	92.9	85.6	75.2	65.9
		MCWB	45.0	47.3	50.1	52.4	56.9	60.6	63.9	64.3	61.6	57.7	51.6	46.5
	5%	DB	62.0	68.4	76.4	82.2	90.5	98.9	97.5	95.0	90.6	82.4	72.0	62.1
		MCWB	43.9	45.9	48.9	51.8	55.9	60.6	63.9	64.3	61.3	56.6	50.4	44.7
	10%	DB	58.2	64.0	72.7	79.7	87.8	96.6	94.9	92.2	88.2	79.2	67.5	57.5
		MCWB	42.2	44.4	47.6	50.8	54.9	59.8	63.7	64.4	61.1	55.5	48.5	43.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.7	52.2	54.1	57.4	62.1	66.8	69.5	69.4	67.9	64.9	56.7	51.3
		MCDB	59.8	66.5	74.8	79.9	88.5	89.4	83.3	84.5	79.6	74.9	68.7	63.6
	2%	WB	47.7	49.9	51.7	55.0	60.0	65.4	68.5	68.4	66.5	62.2	54.2	48.6
		MCDB	59.1	65.8	73.8	78.8	84.6	88.6	83.1	83.8	79.0	76.1	67.9	61.4
	5%	WB	45.5	48.0	50.1	53.2	58.6	64.1	67.8	67.7	65.5	60.0	52.2	46.3
		MCDB	59.0	63.9	72.5	77.5	82.8	87.7	82.9	83.3	78.3	75.2	67.7	58.7
	10%	WB	43.4	45.7	48.5	51.4	56.7	62.7	66.9	66.8	64.3	58.3	50.0	44.1
		MCDB	56.6	62.3	70.3	76.4	81.6	87.3	82.7	82.7	78.1	72.8	66.1	55.9
Mean Daily Temperature Range	5% DB	MDBR	28.4	30.2	32.1	33.0	33.3	32.7	25.9	25.6	27.2	29.2	29.6	27.7
		MCDBR	35.2	38.0	38.0	36.9	36.6	35.5	30.0	29.4	31.6	33.7	35.2	33.8
		MCWBR	19.8	19.5	17.8	16.9	16.0	13.8	8.8	8.1	11.1	14.4	17.8	18.4
	5% WB	MCDBR	29.4	31.6	34.2	33.3	32.0	29.6	24.3	24.2	23.2	25.9	29.7	28.6
		MCWBR	17.4	16.6	16.2	15.9	14.2	10.7	6.4	6.5	8.0	11.6	15.9	16.2
Clear-Sky Solar Irradiance	taub		0.242	0.246	0.262	0.287	0.306	0.330	0.374	0.353	0.321	0.275	0.252	0.243
	taud		2.681	2.670	2.583	2.475	2.467	2.412	2.396	2.427	2.511	2.633	2.653	2.663
	Ebn at Noon		320	327	326	318	310	301	287	293	300	312	313	314
	Edh at Noon		23	25	30	35	36	37	38	36	32	26	23	22
All-Sky Solar Radiation	RadAvg		1147	1473	1918	2343	2565	2554	2264	2104	1874	1575	1251	1053
	RadStd		88	120	107	93	89	120	100	66	90	118	69	56

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	-135	+162	N/A

Nomenclature: See separate page