

PEASON RIDGE, LA, USA

WMO: 722820

Lat: 31.400N

Lon: 93.283W

Elev: 111

StdP: 100.00

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 03949

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.9	-1.3	-9.7	1.7	1.9	-7.3	2.1	4.3	6.1	12.3	5.6	11.7	1.0	0	0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.0	36.7	24.2	35.3	24.3	34.1	24.3	26.2	31.5	25.8	31.0	25.5	30.7	2.0	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.5	27.8	24.6	19.9	27.5	24.3	19.4	27.2	81.8	31.4	80.1	31.2	78.7	30.6	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.5	4.8	4.3	-5.9	38.1	2.0	1.8	-7.4	39.3	-8.6	40.4	-9.7	41.4	-11.2	42.6		
			-6.9	27.2	1.8	0.5	-8.2	27.6	-9.2	27.9	-10.2	28.2	-11.5	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	9.6	11.4	15.6	19.3	23.3	27.1	28.0	28.4	25.5	19.7	14.4	10.8
	DBStd	7.90	5.38	5.86	5.05	3.95	3.32	2.01	1.78	2.03	2.71	4.44	5.18	5.42
	HDD10.0	209	74	48	12	1	0	0	0	0	0	1	17	56
	HDD18.3	1053	275	203	114	35	6	0	0	0	0	38	140	241
	CDD10.0	3664	62	88	185	280	412	512	559	571	466	301	148	82
	CDD18.3	1465	3	9	28	64	159	262	301	313	216	81	21	8
	CDH23.3	14123	5	38	172	501	1399	2655	3144	3344	1974	740	127	23
	CDH26.7	6366	0	3	21	97	522	1276	1542	1714	921	246	22	1
Wind	WSAvg	1.5	1.7	1.9	1.9	2.0	1.6	1.2	1.1	1.1	1.1	1.3	1.5	1.7
Precipitation	PrecAvg	1382	141	121	121	126	109	98	111	87	104	99	130	130
	PrecMax	1941	370	281	305	270	309	304	221	165	270	376	341	251
	PrecMin	759	25	26	18	28	1	7	25	10	25	0	10	39
	PrecStd	283	84	73	64	60	75	67	53	37	52	101	84	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	26.9	28.7	30.7	33.7	37.3	37.4	38.8	36.5	32.9	28.9	25.7
		MCWB	17.6	18.9	19.3	21.5	22.5	23.8	24.3	24.4	23.4	21.8	21.3	20.7
	2%	DB	22.5	24.3	27.1	29.0	32.2	35.5	35.8	37.2	34.7	31.2	26.6	23.6
		MCWB	17.2	17.8	19.1	20.5	22.4	23.9	24.5	24.4	23.2	22.1	20.4	19.9
	5%	DB	20.7	22.3	25.4	27.7	31.0	33.9	34.6	35.4	33.2	29.5	24.5	22.0
		MCWB	16.9	17.8	18.2	19.9	22.3	24.3	24.5	24.8	23.3	21.1	18.6	18.9
	10%	DB	18.9	20.6	23.6	26.4	29.8	32.7	33.5	34.0	31.8	27.8	22.7	20.3
		MCWB	15.2	17.1	17.7	19.0	22.0	24.1	24.7	24.6	22.9	20.3	18.5	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.1	20.6	21.5	23.3	24.9	26.4	26.7	26.9	25.8	25.3	22.9	22.2
		MCDB	22.1	23.8	25.0	26.9	29.3	31.4	32.0	32.1	30.2	28.9	26.9	23.8
	2%	WB	19.1	19.8	20.6	22.4	24.1	25.7	26.1	26.3	25.3	24.5	21.7	20.7
		MCDB	21.2	22.7	24.5	26.3	28.7	30.9	31.4	31.7	30.0	28.1	24.6	23.0
	5%	WB	17.9	18.9	20.0	21.7	23.6	25.3	25.7	25.9	24.8	23.6	20.7	19.9
		MCDB	20.0	21.6	23.4	25.6	28.2	30.5	31.1	31.2	29.5	26.9	23.6	21.8
	10%	WB	16.3	17.6	19.1	21.0	23.0	25.0	25.4	25.6	24.3	22.4	19.3	18.3
		MCDB	18.2	20.0	22.6	24.6	27.6	30.0	30.8	30.8	28.9	25.5	22.0	20.0
Mean Daily Temperature Range	5% DB	MDBR	11.6	11.3	12.1	12.1	11.6	11.0	10.5	11.0	11.8	13.3	12.6	10.8
		MCDBR	12.5	11.9	12.5	12.2	12.3	12.5	12.1	12.8	13.1	14.1	12.7	11.3
		MCWBR	8.1	6.9	5.9	5.2	4.3	3.5	3.1	3.0	4.5	5.9	7.2	7.5
	5% WB	MCDBR	10.2	10.1	10.4	10.1	10.2	10.6	10.4	10.9	10.9	10.6	11.0	9.7
	MCWBR	8.1	7.6	6.4	5.6	4.3	3.7	3.4	3.3	4.2	5.7	7.2	7.2	
Clear-Sky Solar Irradiance	taub	0.327	0.345	0.367	0.403	0.436	0.474	0.483	0.481	0.434	0.365	0.353	0.337	
	taud	2.527	2.481	2.417	2.324	2.276	2.207	2.221	2.220	2.320	2.488	2.473	2.499	
	Ebn at Noon	901	915	915	890	858	821	812	809	837	881	861	868	
	Edh at Noon	86	99	113	128	136	145	142	141	123	97	90	85	
All-Sky Solar Radiation	RadAvg	2.76	3.11	4.35	5.34	5.93	6.08	6.07	5.75	5.01	4.20	3.13	2.40	
	RadStd	0.26	0.54	0.36	0.38	0.41	0.46	0.48	0.50	0.47	0.58	0.33	0.28	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	+79

Nomenclature: See separate page