

PALM SPRINGS, CA, USA

WMO: 722868

Lat: 33.822N

Lon: 116.504W

Elev: 125

StdP: 99.84

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 93138

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.1	6.6	-17.8	0.8	18.1	-15.4	1.0	19.0	10.4	16.3	8.4	16.6	1.8	330	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	44.6	21.2	43.2	21.2	42.1	21.0	25.7	36.6	24.9	36.2	24.1	36.4	4.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	17.7	32.4	21.3	16.2	32.7	19.5	14.4	33.2	80.1	36.1	76.0	36.1	72.5	36.4	32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.9	8.0	DB	2.0	47.5	1.7	1.5	0.7	48.6	-0.3	49.4	-1.3	50.3	-2.5	51.4	(4)
(5)			WB	-1.7	27.4	1.4	2.1	-2.7	28.9	-3.5	30.1	-4.3	31.3	-5.4	32.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.1	15.1	16.2	19.7	22.4	26.4	31.1	34.4	34.0	30.9	25.1	19.0	14.2		
	DBStd	7.86	3.40	3.65	3.95	3.99	4.01	3.49	2.37	2.41	3.36	3.63	3.77	3.07		
	HDD10.0	7	3	1	0	0	0	0	0	0	0	0	0	3		
	HDD18.3	402	109	79	32	11	1	0	0	0	0	2	36	132		
	CDD10.0	5153	161	174	300	372	508	634	757	744	628	468	271	134		
	CDD18.3	2506	9	19	74	133	250	384	498	486	378	212	57	5		
	CDH23.3	37683	101	225	876	1642	3404	6061	8404	8117	5751	2488	563	52		
(13)	CDH26.7	24300	13	52	346	799	2002	4103	6007	5746	3739	1294	194	5		
(14)	Wind	WSAvg	2.9	2.2	2.4	2.9	3.6	4.0	3.6	3.2	2.9	2.7	2.3	2.2		
(15) Precipitation	PrecAvg	125	25	21	13	3	2	1	4	9	11	5	17	18		
	PrecMax	348	110	137	53	26	28	20	65	110	106	48	161	74		
	PrecMin	35	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	84	33	29	15	6	6	4	13	22	23	10	31	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	30.5	35.1	38.1	42.4	46.1	47.1	46.2	43.6	38.9	33.4	27.4		
		MCWB	12.5	13.6	16.1	17.7	20.7	20.0	23.3	21.9	20.4	18.5	15.2	12.9		
	2%	DB	26.1	28.2	32.5	35.8	39.8	43.6	44.8	44.1	42.0	37.1	31.2	24.8		
		MCWB	12.1	13.0	15.4	16.5	18.4	20.0	21.5	21.7	20.4	17.8	14.7	12.1		
	5%	DB	24.0	26.4	30.6	33.6	37.8	42.0	43.2	42.7	40.6	35.0	28.9	22.7		
		MCWB	11.3	12.6	14.6	15.8	18.8	19.7	21.8	21.6	19.9	16.9	14.0	11.1		
	10%	DB	22.3	23.9	28.3	31.4	35.9	40.3	42.0	41.4	38.9	33.0	26.9	21.0		
		MCWB	10.8	11.7	14.0	15.0	17.5	19.3	21.6	21.5	19.8	16.4	13.3	10.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	15.8	18.2	19.9	23.1	25.8	26.9	27.2	25.3	21.6	17.0	15.1		
		MCDB	23.0	24.1	29.3	33.3	36.6	36.8	37.9	38.0	34.5	30.4	27.9	22.3		
	2%	WB	13.9	14.4	16.7	17.8	21.2	23.3	25.7	25.9	24.3	20.2	15.7	13.8		
		MCDB	20.3	23.2	28.5	32.5	36.1	37.1	36.4	37.1	34.8	32.2	27.5	20.5		
	5%	WB	12.9	13.5	15.7	16.7	19.6	21.9	24.9	25.0	23.4	18.9	14.9	12.6		
		MCDB	20.1	22.8	27.7	30.8	34.5	37.6	36.3	36.6	34.9	31.7	26.6	19.5		
	10%	WB	11.9	12.7	14.8	15.8	18.6	20.9	24.0	24.0	22.3	17.7	14.0	11.6		
		MCDB	20.2	21.8	26.5	29.0	33.1	36.8	36.8	36.7	34.5	30.4	24.9	18.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.1	13.3	13.9	14.6	16.1	14.4	14.3	14.0	13.3	12.5	11.5		
		MCDBR	14.1	15.0	15.9	16.6	16.8	17.7	16.0	15.6	15.6	15.2	14.7	13.8		
		MCWBR	6.3	6.3	5.6	5.5	5.1	4.6	4.5	4.8	4.6	5.6	6.3	6.3		
	5% WB	MCDBR	11.5	12.9	14.9	15.5	15.9	16.1	12.3	11.6	11.6	13.3	13.2	11.6		
		MCWBR	5.4	5.7	5.6	5.6	5.5	6.1	5.8	6.5	5.4	5.3	6.0	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.307	0.312	0.331	0.350	0.365	0.368	0.401	0.391	0.359	0.349	0.313	0.315		
	taud		2.490	2.488	2.422	2.381	2.369	2.376	2.372	2.385	2.447	2.423	2.512	2.496		
	Ebn at Noon		909	941	945	937	920	912	880	886	904	884	895	877		
	Edh at Noon		85	95	110	120	123	122	122	118	106	100	83	81		
(44) All-Sky Solar Radiation	RadAvg		3.32	4.25	5.75	7.04	7.91	8.46	7.68	7.19	6.27	4.91	3.69	3.01		
	RadStd		0.22	0.37	0.27	0.23	0.32	0.32	0.36	0.31	0.23	0.25	0.16	0.18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.60	N/A	-2.05	+0.84	-0.82	N/A	N/A	-98	+268
(47) Regional (47 neighbors)		+0.58	N/A	-1.62	+0.62	N/A	N/A	N/A	-93	+204

Nomenclature: See separate page