

RIVERSIDE, CA, USA

WMO: 722869

Lat: 33.952N

Lon: 117.439W

Elev: 804

StdP: 14.27

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 03171

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	36.6	38.9	1.1	6.0	61.7	6.6	8.0	64.5	26.6	62.4	23.4	63.1	2.6	60	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	29.2	100.7	69.1	98.3	68.6	95.1	67.4	72.9	93.6	71.4	91.9	70.1	90.0	10.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	99.3	80.2	64.2	92.6	78.6	63.2	89.4	77.3	36.8	93.7	35.6	91.9	34.5	90.5	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.1	13.6	DB	32.2	107.8	2.4	3.8	30.4	110.5	29.0	112.7	27.7	114.9	25.9	117.6	(4)
(5)			WB	28.4	75.0	1.7	1.4	27.2	76.0	26.1	76.8	25.2	77.6	23.9	78.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.3	56.4	56.4	59.6	62.6	67.3	72.8	78.8	79.2	76.4	69.0	61.2	55.2	(6)	
	DBStd	10.34	6.35	6.37	6.15	6.14	5.37	5.16	4.81	4.73	6.01	6.14	6.36	5.58	(7)	
	HDD50	46	14	10	3	1	0	0	0	0	0	0	2	16	(8)	
	HDD65	1357	277	252	188	117	35	3	0	0	1	29	147	308	(9)	
	CDD50	5989	212	188	302	378	535	683	891	905	792	588	339	176	(10)	
	CDD65	1823	9	10	22	44	105	236	426	440	343	151	34	3	(11)	
	CDH74	20881	179	249	452	739	1227	2466	4581	4837	3697	1776	575	103	(12)	
	CDH80	10632	29	62	137	283	528	1209	2533	2759	2038	843	200	11	(13)	
(14) Wind	WSAvg	4.9	4.9	4.6	4.8	5.2	5.5	5.4	4.9	4.4	4.3	4.4	4.4	4.7	(14)	
(15) Precipitation	PrecAvg	11.6	2.4	3.0	1.6	0.7	0.2	0.1	0.2	0.1	0.2	0.4	1.0	1.7	(15)	
	PrecMax	22.2	11.3	11.2	6.6	2.4	2.0	0.7	1.5	0.4	1.5	5.5	2.1	8.5	(16)	
	PrecMin	4.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2	(17)	
	PrecStd	5.3	2.9	2.5	1.5	0.6	0.4	0.2	0.3	0.1	0.3	1.0	0.5	1.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.6	85.9	89.8	93.4	97.2	101.1	103.5	104.4	104.4	98.9	91.0	81.4	(19)	
		MCWB	54.8	56.0	59.0	60.2	64.5	67.5	70.2	69.5	68.6	64.0	58.5	54.6	(20)	
	2%	DB	79.1	81.4	83.7	87.7	90.9	95.2	99.2	100.1	99.8	93.7	85.8	77.0	(21)	
		MCWB	53.4	54.7	57.2	59.0	63.1	67.3	70.5	69.8	68.6	61.2	57.0	52.5	(22)	
	5%	DB	74.9	76.4	79.2	82.2	86.3	91.0	95.9	97.2	95.9	89.7	81.0	72.5	(23)	
		MCWB	52.1	53.6	56.4	57.9	62.5	66.4	69.4	69.0	67.6	60.6	55.4	50.9	(24)	
	10%	DB	70.9	70.3	74.0	77.4	81.2	87.7	92.6	93.3	91.4	84.2	75.5	68.0	(25)	
		MCWB	51.0	51.7	55.2	57.0	61.8	65.6	68.6	68.1	66.7	59.9	53.7	50.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.9	60.4	63.3	64.8	69.2	71.1	74.8	75.4	74.3	68.8	62.0	59.3	(27)	
		MCDB	71.9	73.0	80.9	85.7	90.7	94.2	97.0	94.7	95.4	84.5	75.2	68.0	(28)	
	2%	WB	57.3	57.8	60.8	62.1	66.7	69.3	72.8	72.7	72.1	66.3	59.9	57.3	(29)	
		MCDB	66.5	70.7	77.2	80.7	85.6	91.3	93.7	93.1	91.8	83.9	75.1	65.3	(30)	
	5%	WB	55.4	56.0	59.0	60.0	64.6	67.9	71.3	71.1	70.2	64.4	58.3	55.3	(31)	
		MCDB	66.0	68.7	73.5	77.3	81.8	87.9	91.4	92.0	89.5	81.1	72.4	64.3	(32)	
	10%	WB	53.7	54.4	57.2	58.4	62.6	66.4	69.8	69.5	68.4	62.6	57.0	53.4	(33)	
		MCDB	64.9	65.3	69.9	73.5	77.8	84.3	88.7	89.9	86.7	77.3	69.8	62.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.3	22.6	24.0	24.5	24.1	26.6	28.1	29.2	28.3	26.0	25.2	22.8	(35)	
		MCDBR	31.0	33.4	32.7	34.3	34.0	33.1	31.0	32.5	33.9	35.4	33.7	31.7	(36)	
	5% WB	MCWBR	13.8	14.0	13.4	13.1	12.7	11.2	10.2	11.3	11.3	13.1	13.7	14.7	(37)	
		MCWBR	23.8	25.6	27.9	29.9	29.9	30.5	28.4	29.7	29.8	28.9	26.0	22.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.303	0.313	0.335	0.349	0.356	0.362	0.383	0.367	0.350	0.340	0.305	0.305	(40)	
		taud	2.547	2.534	2.450	2.416	2.429	2.423	2.428	2.460	2.494	2.493	2.582	2.576	(41)	
	Ebn at Noon		290	299	298	297	294	291	284	288	290	284	288	283	(42)	
		Edh at Noon	26	29	34	37	37	37	36	35	32	30	24	24	(43)	
(44) All-Sky Solar Radiation	RadAvg		1027	1311	1763	2142	2344	2522	2427	2297	1956	1491	1143	931	(44)	
	RadStd		70	128	87	96	124	128	113	58	60	90	56	65	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+2.03	+2.61	N/A	+0.85	N/A	N/A	N/A	-409	+783	+443
(47) Regional (51 neighbors)		+1.13	N/A	-3.06	+1.30	N/A	N/A	N/A	-202	+401	+202

Nomenclature: See separate page