

LOS ANGELES USC, CA, USA

WMO: 722874

Lat: 34.024N

Lon: 118.291W

Elev: 179

StdP: 14.60

Time Zone: -8.00 (NAP)

Period: 99-19

WBAN: 93134

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	43.1	45.1	12.0	10.2	64.6	17.1	13.1	62.2	10.6	56.9	9.0	57.8	0.4	20	0.293

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.3	92.0	66.1	88.5	66.1	85.5	65.9	71.7	85.1	70.5	83.0	69.3	81.0	3.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.2	100.8	77.6	66.0	96.5	76.6	64.9	92.6	75.4	35.6	85.1	34.5	83.0	33.5	81.2	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.4	7.5	6.6	DB	38.6	99.9	2.0	4.4	37.2	103.0	36.1	105.6	35.0	108.1	33.5	111.3
			WB	33.0	74.3	1.9	1.5	31.6	75.3	30.4	76.2	29.3	77.1	27.9	78.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.7	58.8	58.7	61.4	63.3	65.9	69.3	73.4	74.0	73.1	69.2	63.2	57.8	(6)
	DBStd	7.41	5.26	5.36	5.02	4.90	4.20	3.39	3.91	3.62	4.83	5.27	5.38	4.47	(7)
	HDD50	4	2	1	0	0	0	0	0	0	0	0	0	1	(8)
	HDD65	985	204	188	135	87	33	2	0	0	0	16	94	226	(9)
	CDD50	5739	273	244	354	400	493	578	725	744	693	595	396	244	(10)
	CDD65	1246	10	11	24	37	62	130	260	279	243	146	40	4	(11)
	CDH74	7772	143	139	228	325	375	546	1468	1633	1519	981	355	60	(12)
	CDH80	2435	22	31	61	110	128	125	403	479	562	394	116	4	(13)
(14) Wind	WSAvg	1.9	1.4	1.9	2.1	2.4	2.3	2.1	2.1	2.0	1.8	1.5	1.3	1.4	(14)
(15) Precipitation	PrecAvg	15.9	3.6	4.2	2.2	0.9	0.4	0.1	0.0	0.0	0.2	0.7	1.1	2.4	(15)
	PrecMax	29.5	16.0	14.6	7.0	2.4	4.0	0.8	0.3	0.1	2.3	5.4	2.6	9.7	(16)
	PrecMin	6.5	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	7.3	3.9	3.7	2.1	0.7	0.8	0.2	0.1	0.0	0.5	1.1	0.8	2.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.1	84.8	86.8	90.5	91.3	90.2	92.8	92.7	97.4	95.3	89.4	79.8	(19)
		MCWB	55.4	56.5	59.9	61.5	61.6	69.2	71.8	70.2	68.1	62.2	59.7	54.3	(20)
	2%	DB	78.1	78.4	80.2	82.3	82.8	83.0	87.4	88.5	91.1	89.4	83.3	75.1	(21)
		MCWB	54.6	55.0	57.3	58.2	62.7	67.2	70.3	69.3	68.7	61.8	57.8	53.6	(22)
	5%	DB	73.9	73.1	75.1	76.8	77.4	79.5	84.3	85.1	86.4	84.3	77.5	70.9	(23)
		MCWB	53.3	54.7	56.7	57.8	62.7	66.5	69.5	68.8	67.4	61.4	56.1	52.8	(24)
	10%	DB	69.2	68.2	70.6	72.2	73.3	76.6	81.4	82.1	82.3	79.1	73.1	66.8	(25)
		MCWB	52.8	54.1	56.2	57.7	61.5	65.1	68.6	68.3	66.9	62.3	55.8	52.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.5	62.0	63.7	65.0	68.4	70.2	74.2	73.0	73.2	69.7	63.6	60.5	(27)
		MCDB	69.1	70.2	77.3	78.9	81.5	84.8	87.5	87.5	91.2	82.2	74.0	66.8	(28)
	2%	WB	58.7	59.4	61.3	62.2	65.8	68.4	71.8	71.2	71.0	67.3	61.9	59.0	(29)
		MCDB	66.1	68.5	73.0	74.6	77.4	81.0	84.0	84.2	85.4	79.4	71.7	65.4	(30)
	5%	WB	57.3	57.8	59.7	60.4	63.9	66.9	70.5	70.0	69.3	65.7	60.4	57.4	(31)
		MCDB	64.4	66.1	69.4	71.4	74.1	78.2	81.9	82.1	82.1	76.4	69.5	63.8	(32)
	10%	WB	56.0	56.4	58.3	59.0	62.3	65.7	69.2	68.9	68.1	64.2	59.4	55.9	(33)
		MCDB	63.5	64.3	66.2	68.8	71.3	75.8	79.7	80.2	79.5	73.2	67.9	62.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.8	17.4	17.0	16.5	14.8	14.7	16.5	17.3	17.6	17.8	18.7	18.1	(35)
		MCDBR	26.7	25.8	25.3	24.8	22.2	19.8	19.6	20.7	23.6	27.3	26.8	25.2	(36)
		MCWBR	11.8	11.2	10.5	10.2	9.1	8.2	7.7	7.8	8.4	10.3	11.6	12.4	(37)
	5% WB	MCDBR	18.4	19.2	19.1	19.3	18.2	18.0	18.2	18.8	19.9	19.2	18.8	17.4	(38)
		MCWBR	9.4	9.8	8.9	8.8	8.1	7.8	7.5	7.6	7.6	7.9	9.1	9.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.343	0.356	0.382	0.384	0.385	0.405	0.402	0.383	0.369	0.380	0.325	0.326	(40)
	taud		2.463	2.437	2.340	2.347	2.376	2.324	2.401	2.433	2.465	2.397	2.558	2.551	(41)
	Ebn at Noon		274	282	283	286	286	279	279	283	283	270	280	274	(42)
	Edh at Noon		28	32	38	39	39	41	37	36	33	33	25	24	(43)
(44) All-Sky Solar Radiation	RadAvg		1000	1281	1719	2104	2285	2402	2382	2262	1912	1450	1116	908	(44)
	RadStd		73	129	97	108	149	141	123	72	73	103	65	68	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.44	N/A	N/A	+2.75	N/A	N/A	N/A	-243	+556	+331	(46)
(47)	Regional (52 neighbors)	+1.15	N/A	-2.97	+1.31	N/A	N/A	N/A	-212	+405	+194	(47)

Nomenclature: See separate page