

SANTA MONICA, CA, USA

WMO: 722885

Lat: 34.016N

Lon: 118.451W

Elev: 174

StdP: 14.60

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 93197

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	43.3	45.3	8.8	8.7	63.1	14.5	11.6	61.2	16.9	57.8	14.9	57.2	3.2	40	0.349

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	85.7	62.0	82.1	62.5	79.3	63.0	70.3	77.4	69.0	76.1	67.8	74.9	6.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	102.4	74.1	66.2	97.1	73.2	64.8	92.3	71.7	34.3	77.6	33.2	76.4	32.2	74.9	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	12.5	11.2	DB	39.6	94.0	2.0	4.7	38.1	97.4	37.0	100.2	35.9	102.8	34.4	106.2	(4)
(5)			WB	32.6	71.5	2.3	2.1	30.9	73.0	29.6	74.2	28.3	75.4	26.6	76.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	57.8	57.0	59.0	60.4	62.8	65.6	69.0	69.5	69.2	66.1	61.6	56.9
	DBStd	6.42	5.48	5.06	4.56	4.51	3.92	2.72	3.39	3.41	4.61	5.10	5.32	4.53
	HDD50	7	3	2	0	0	0	0	0	0	0	0	0	2
	HDD65	1369	233	230	197	155	91	20	4	3	8	45	130	253
	CDD50	4731	245	198	280	311	395	469	590	603	575	499	349	217
	CDD65	620	11	7	12	16	22	39	129	141	133	79	28	3
	CDH74	2475	95	71	103	128	144	71	264	360	527	469	215	28
	CDH80	576	13	14	23	36	56	15	29	39	132	160	58	1
Wind	WSAvg	4.7	4.3	4.6	4.9	5.4	5.3	5.1	5.0	4.7	4.4	4.1	4.1	4.2
Precipitation	PrecAvg	15.9	3.6	4.2	2.2	0.9	0.4	0.1	0.0	0.0	0.2	0.7	1.1	2.4
	PrecMax	29.5	16.0	14.6	7.0	2.4	4.0	0.8	0.3	0.1	2.3	5.4	2.6	9.7
	PrecMin	6.5	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	7.3	3.9	3.7	2.1	0.7	0.8	0.2	0.1	0.0	0.5	1.1	0.8	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.7	82.2	83.0	85.0	87.5	81.8	83.3	83.8	90.1	91.2	86.4	78.0
		MCWB	55.8	55.8	57.7	57.3	57.8	66.6	69.4	68.2	67.2	62.1	58.0	53.4
	2%	DB	76.4	74.8	76.1	77.1	76.6	75.0	79.3	80.6	83.3	84.2	80.3	72.6
		MCWB	53.1	53.6	55.3	56.0	59.2	64.5	68.1	67.7	67.3	59.9	56.5	52.5
	5%	DB	72.3	69.9	70.9	71.8	71.6	72.4	76.7	77.9	79.4	79.1	75.0	68.5
		MCWB	52.5	53.3	54.6	55.4	60.4	63.5	67.3	67.3	66.6	60.5	54.9	52.2
	10%	DB	67.6	65.1	66.4	67.6	68.3	70.5	74.6	75.4	76.3	74.4	70.5	64.9
		MCWB	51.3	53.0	54.9	55.9	59.3	62.5	66.6	66.6	66.1	61.8	55.3	52.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.1	60.3	61.9	61.9	64.4	67.7	71.6	71.6	71.9	69.6	63.2	61.1
		MCDB	66.8	67.5	72.5	73.1	73.9	77.5	78.1	78.7	80.9	77.5	69.5	64.3
	2%	WB	58.4	58.5	59.9	59.8	62.6	65.7	69.9	69.8	69.8	66.9	61.5	59.1
		MCDB	64.3	64.4	68.1	67.9	70.7	73.5	76.0	77.1	77.9	75.2	68.3	64.0
	5%	WB	57.2	57.2	58.5	58.7	61.4	64.4	68.7	68.4	68.5	65.3	60.2	57.7
		MCDB	63.3	62.9	65.4	66.0	68.6	71.0	74.7	75.6	76.3	72.6	67.2	62.7
	10%	WB	55.9	56.0	57.4	57.6	60.2	63.4	67.4	67.2	67.1	63.9	59.1	56.3
		MCDB	62.1	62.1	63.2	64.6	66.7	69.2	73.5	74.1	74.5	69.9	66.2	61.4
Mean Daily Temperature Range	5% DB	MDBR	16.6	15.4	13.8	13.2	11.1	10.0	10.3	11.1	12.5	14.3	16.4	15.9
		MCDBR	24.2	23.7	21.8	21.0	16.6	13.0	12.8	13.7	17.4	23.3	23.9	21.7
		MCWBR	11.4	11.5	10.3	9.5	7.5	6.0	5.5	6.0	7.5	11.0	12.0	11.9
	5% WB	MCDBR	15.8	15.6	14.5	14.7	12.7	12.2	11.9	12.2	14.3	15.7	16.4	14.7
		MCWBR	9.3	8.9	7.8	7.3	6.2	5.8	5.2	5.8	6.5	8.6	9.7	9.6
Clear-Sky Solar Irradiance	taub	0.332	0.345	0.368	0.378	0.385	0.400	0.404	0.383	0.371	0.372	0.321	0.323	
	taud	2.504	2.480	2.395	2.367	2.378	2.342	2.393	2.433	2.461	2.430	2.570	2.562	
	Ebn at Noon	279	287	287	288	286	280	278	283	283	273	281	276	
	Edh at Noon	27	30	36	39	39	40	38	36	33	32	25	24	
All-Sky Solar Radiation	RadAvg	995	1276	1709	2096	2271	2372	2369	2252	1900	1441	1111	903	
	RadStd	73	129	99	110	155	145	126	75	76	107	67	69	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.49	N/A	-2.90	+2.05	+1.71	N/A	N/A	-277	+529	+290
Regional (52 neighbors)		+1.15	N/A	-2.97	+1.31	N/A	N/A	N/A	-212	+405	+194

Nomenclature: See separate page