

LOMPOC, CA, USA

WMO: 722895

Lat: 34.667N

Lon: 120.467W

Elev: 88

StdP: 14.65

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23243

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	32.3	35.5	22.5	17.0	46.9	25.8	19.9	44.1	20.8	57.8	18.6	58.3	4.4	80	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.7	82.1	62.0	78.7	61.4	74.8	60.8	66.0	76.7	64.3	74.1	62.9	72.0	10.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.5	81.8	70.1	60.5	79.1	69.2	58.8	74.1	67.2	30.6	76.9	29.4	74.2	28.4	71.9	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	18.5	17.0	DB	27.6	93.4	2.1	9.5	26.1	100.2	24.9	105.8	23.7	111.1	22.2	118.0	(4)
(5)			WB	25.3	70.8	1.9	6.0	23.9	75.2	22.8	78.7	21.7	82.0	20.3	86.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	52.7	52.7	54.7	55.8	57.9	60.2	62.3	63.0	62.9	60.5	56.8	51.9	(6)	
	DBStd	5.63	4.71	4.60	4.23	4.02	3.42	2.82	2.68	2.65	3.77	4.49	5.11	4.70	(7)	
	HDD50	100	27	22	9	3	0	0	0	0	0	0	6	33	(8)	
	HDD65	2761	381	345	320	278	224	148	93	74	85	155	253	405	(9)	
	CDD50	2891	111	98	155	177	244	305	381	404	387	326	209	94	(10)	
	CDD65	74	0	0	1	2	3	3	8	13	22	16	6	0	(11)	
	CDH74	968	25	26	42	64	70	33	38	62	206	278	118	6	(12)	
	CDH80	259	1	3	8	22	21	5	5	7	59	93	35	0	(13)	
(14) Wind	WSAvg	7.0	6.0	6.6	7.1	7.9	8.6	8.4	7.7	7.2	6.5	6.2	5.9	6.1	(14)	
(15) Precipitation	PrecAvg	17.3	3.9	4.2	2.6	1.1	0.4	0.1	0.0	0.0	0.0	0.8	1.3	2.8	(15)	
	PrecMax	32.2	16.7	15.8	12.6	3.9	2.3	0.7	0.2	0.1	0.4	3.9	4.1	9.1	(16)	
	PrecMin	5.8	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	6.7	4.0	3.6	3.1	1.2	0.6	0.2	0.0	0.0	0.1	1.0	1.1	2.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	78.3	79.3	82.2	81.5	78.6	78.8	80.6	88.0	89.8	84.5	73.4	(19)	
		MCWB	56.0	57.5	57.7	60.0	61.9	63.8	65.4	65.9	66.5	62.2	60.4	55.0	(20)	
	2%	DB	72.3	71.5	72.3	72.6	73.1	72.8	73.4	75.0	80.1	81.3	76.8	69.6	(21)	
		MCWB	54.9	55.3	56.9	58.1	60.6	61.7	63.3	63.9	63.9	61.2	58.2	54.9	(22)	
	5%	DB	66.3	64.7	67.7	68.4	69.7	70.2	71.8	72.4	74.8	75.2	71.8	64.3	(23)	
		MCWB	54.4	53.5	56.4	57.5	59.2	60.3	62.5	62.6	63.1	60.0	56.8	54.2	(24)	
	10%	DB	63.2	62.6	63.9	64.8	65.9	67.6	69.8	70.3	72.0	71.6	66.5	62.7	(25)	
		MCWB	53.8	53.2	55.1	55.8	57.5	59.1	61.3	61.7	62.0	59.5	56.4	54.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.9	60.3	61.6	62.4	64.5	65.3	66.8	67.0	69.3	67.0	63.8	61.0	(27)	
		MCDB	67.8	71.2	70.9	73.8	75.7	76.6	75.9	77.9	80.6	80.0	73.4	66.0	(28)	
	2%	WB	58.4	57.6	59.4	60.0	61.8	62.3	64.3	64.7	66.0	63.9	61.2	58.8	(29)	
		MCDB	65.5	65.6	68.4	69.5	71.7	71.9	73.2	73.9	76.4	74.8	70.9	63.9	(30)	
	5%	WB	56.7	55.9	57.8	58.3	59.5	60.8	62.4	63.1	64.0	62.0	59.3	56.9	(31)	
		MCDB	63.2	63.1	65.6	66.7	68.2	69.0	70.5	71.5	73.5	72.2	67.7	62.3	(32)	
	10%	WB	54.8	54.2	56.2	56.7	57.8	59.3	61.2	61.9	62.2	60.3	57.8	54.9	(33)	
		MCDB	61.2	60.6	63.4	64.2	65.1	66.3	68.6	69.8	70.8	69.3	65.3	60.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.1	21.1	21.0	20.3	17.7	16.2	15.1	15.7	19.3	23.3	24.3	22.4	(35)	
		MCDBR	30.9	28.1	29.3	27.4	25.4	20.9	18.3	19.1	25.7	32.8	32.2	26.5	(36)	
		MCWBR	17.6	16.3	16.7	15.5	14.5	12.2	10.6	10.7	14.1	17.5	17.5	16.4	(37)	
	5% WB	MCDBR	22.5	22.3	23.2	23.3	22.0	19.1	17.2	17.9	22.3	26.3	24.9	18.8	(38)	
		MCWBR	14.4	14.1	14.5	14.3	13.0	11.4	9.9	10.2	12.7	15.3	15.1	12.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.305	0.319	0.327	0.347	0.358	0.353	0.367	0.350	0.350	0.342	0.307	0.309	(40)	
	taud		2.596	2.565	2.544	2.469	2.460	2.471	2.487	2.505	2.509	2.534	2.604	2.595	(41)	
	Ebn at Noon		289	296	301	298	294	293	289	293	289	283	286	280	(42)	
	Edh at Noon		24	28	31	35	36	35	34	33	31	28	24	23	(43)	
(44) All-Sky Solar Radiation	RadAvg		960	1232	1675	2087	2305	2366	2243	2078	1801	1397	1072	857	(44)	
	RadStd		74	123	106	125	149	109	81	92	95	105	60	74	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		+1.19	N/A	-2.48	+1.48	N/A	N/A	N/A	-299	+437	+142

Nomenclature: See separate page