

LOMPOC, CA, USA

WMO: 722895

Lat: 34.667N

Lon: 120.467W

Elev: 27

StdP: 101.00

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23243

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 0.2	(c) 2.0	(d) -5.3	(e) 2.4	(f) 8.3	(g) -3.4	(h) 2.8	(i) 6.7	(j) 9.3	(k) 14.3	(l) 8.3	(m) 14.6	(n) 2.0	(o) 80	(p) 0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.7	(c) 27.8	(d) 16.7	(e) 25.9	(f) 16.3	(g) 23.8	(h) 16.0	(i) 18.9	(j) 24.8	(k) 18.0	(l) 23.4	(m) 17.2	(n) 22.2	(o) 4.6	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.4	11.7	21.2	15.9	11.3	20.7	14.9	10.6	19.6	53.4	25.0	50.5	23.4	48.3	22.2	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.0	8.3	7.6		-2.4	34.1	1.2	5.3	-3.3	37.9	-3.9	41.0	-4.6	44.0	-5.4	47.8	
				-3.7	21.6	1.1	3.3	-4.5	24.0	-5.1	25.9	-5.7	27.8	-6.5	30.2	
		DB														
		WB														

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	11.5	11.5	12.6	13.2	14.4	15.6	16.8	17.2	17.2	15.8	13.8	11.1
	DBStd	3.13	2.62	2.56	2.35	2.23	1.90	1.57	1.49	1.47	2.09	2.49	2.84	2.61
	HDD10.0	56	15	12	5	2	0	0	0	0	0	0	3	18
	HDD18.3	1534	212	192	178	154	124	82	52	41	47	86	141	225
	CDD10.0	1606	62	54	86	98	136	169	212	224	215	181	116	52
	CDD18.3	41	0	0	1	1	2	2	4	7	12	9	3	0
	CDH23.3	538	14	14	23	36	39	18	21	34	114	154	66	3
	CDH26.7	144	1	2	4	12	12	3	3	4	33	52	19	0
Wind	WSAvg	3.1	2.7	2.9	3.2	3.5	3.9	3.8	3.4	3.2	2.9	2.8	2.7	2.7
Precipitation	PrecAvg	439	98	106	66	29	10	2	1	0	1	20	34	71
	PrecMax	819	425	402	321	98	58	17	4	2	10	100	103	230
	PrecMin	147	0	0	0	2	0	0	0	0	0	0	0	1
	PrecStd	171	101	91	79	31	14	4	1	1	2	26	29	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	25.7	26.3	27.9	27.5	25.9	26.0	27.0	31.1	32.1	29.1	23.0
		MCWB	13.3	14.2	14.3	15.6	16.6	17.7	18.6	18.8	19.2	16.8	15.8	12.8
	2%	DB	22.4	21.9	22.4	22.6	22.8	22.7	23.0	23.9	26.7	27.4	24.9	20.9
		MCWB	12.7	12.9	13.9	14.5	15.9	16.5	17.4	17.7	17.7	16.2	14.5	12.7
	5%	DB	19.0	18.1	19.8	20.2	20.9	21.2	22.1	22.5	23.8	24.0	22.1	17.9
		MCWB	12.4	12.0	13.6	14.1	15.1	15.7	16.9	17.0	17.3	15.6	13.8	12.3
	10%	DB	17.3	17.0	17.7	18.2	18.8	19.8	21.0	21.3	22.2	22.0	19.2	17.1
		MCWB	12.1	11.8	12.8	13.2	14.1	15.0	16.3	16.5	16.7	15.3	13.6	12.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	15.7	16.5	16.9	18.1	18.5	19.4	19.4	20.7	19.4	17.7	16.1
		MCDB	19.9	21.8	21.6	23.2	24.3	24.8	24.4	25.5	27.0	26.6	23.0	18.9
	2%	WB	14.7	14.2	15.2	15.5	16.6	16.9	17.9	18.1	18.9	17.7	16.2	14.9
		MCDB	18.6	18.7	20.2	20.8	22.0	22.1	22.9	23.3	24.7	23.8	21.6	17.7
	5%	WB	13.7	13.3	14.3	14.6	15.3	16.0	16.9	17.3	17.8	16.7	15.2	13.8
		MCDB	17.3	17.3	18.7	19.3	20.1	20.5	21.4	22.0	23.1	22.3	19.8	16.8
	10%	WB	12.7	12.3	13.4	13.7	14.3	15.2	16.2	16.6	16.8	15.7	14.3	12.7
		MCDB	16.2	15.9	17.4	17.9	18.4	19.1	20.3	21.0	21.6	20.7	18.5	15.8
Mean Daily Temperature Range	5% DB	MDBR	12.8	11.7	11.6	11.3	9.9	9.0	8.4	8.7	10.7	13.0	13.5	12.5
		MCDBR	17.2	15.6	16.3	15.2	14.1	11.6	10.2	10.6	14.3	18.2	17.9	14.7
		MCWBR	9.8	9.1	9.3	8.6	8.0	6.8	5.9	5.9	7.8	9.7	9.7	9.1
	5% WB	MCDBR	12.5	12.4	12.9	12.9	12.2	10.6	9.5	9.9	12.4	14.6	13.8	10.4
		MCWBR	8.0	7.8	8.1	7.9	7.2	6.3	5.5	5.7	7.1	8.5	8.4	7.1
Clear-Sky Solar Irradiance	taub	0.305	0.319	0.327	0.347	0.358	0.353	0.367	0.350	0.350	0.342	0.307	0.309	
	taud	2.596	2.565	2.544	2.469	2.460	2.471	2.487	2.505	2.509	2.534	2.604	2.595	
	Ebn at Noon	912	933	949	938	926	925	910	924	911	893	902	884	
	Edh at Noon	76	88	97	110	112	111	108	104	99	89	75	73	
All-Sky Solar Radiation	RadAvg	3.03	3.88	5.28	6.58	7.27	7.46	7.07	6.55	5.68	4.40	3.38	2.70	
	RadStd	0.23	0.39	0.33	0.39	0.47	0.34	0.25	0.29	0.30	0.33	0.19	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)	+0.66	N/A	-1.38	+0.82	N/A	N/A	N/A	-166	+243	+79

Nomenclature: See separate page