

SAN LUIS OBISPO, CA, USA

WMO: 722897

Lat: 35.237N

Lon: 120.641W

Elev: 200

StdP: 14.59

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93206

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	34.2	36.5	19.9	15.0	53.5	24.4	18.7	52.9	21.9	57.2	19.0	58.0	1.9	100	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	23.6	89.9	64.0	85.3	63.3	81.8	62.9	67.5	83.2	66.0	80.8	64.6	78.5	10.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.9	83.5	71.5	60.6	79.6	70.2	59.1	75.3	68.4	31.8	83.2	30.6	80.8	29.7	78.5	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.2	20.9	18.9	DB	29.8	99.9	2.9	4.6	27.7	103.3	26.0	106.0	24.4	108.5	22.3	111.9	
			WB	27.7	70.7	3.1	2.7	25.4	72.6	23.6	74.3	21.9	75.8	19.7	77.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.0	53.9	54.1	56.3	57.4	60.3	63.2	66.2	66.8	66.6	63.9	58.2	53.1
	DBStd	6.98	5.02	5.61	5.37	5.29	4.71	3.97	3.37	3.27	4.81	5.85	5.86	4.78
	HDD50	79	20	19	8	4	0	0	0	0	0	0	5	23
	HDD65	2155	345	308	276	238	163	79	23	14	31	91	218	369
	CDD50	3737	140	133	202	225	319	395	501	521	498	433	251	119
	CDD65	341	1	3	6	9	17	24	60	70	79	58	14	0
	CDH74	3742	51	65	99	158	249	314	527	577	760	706	208	28
	CDH80	1194	8	13	19	53	86	97	124	151	290	292	59	2
(14) Wind	WSAvg	6.9	5.3	6.1	7.1	8.3	8.9	8.3	7.4	7.3	6.9	6.4	5.3	5.1
(15) Precipitation	PrecAvg	25.9	5.3	5.3	4.0	1.6	0.4	0.1	0.0	0.0	0.4	1.0	2.8	3.9
	PrecMax	49.9	24.6	15.2	16.5	6.9	3.4	0.8	0.5	1.4	3.9	5.2	7.8	10.9
	PrecMin	11.7	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	9.8	5.2	4.8	3.4	1.6	0.8	0.2	0.1	0.2	0.7	1.1	2.2	2.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.3	82.2	82.0	87.6	89.3	90.0	89.5	90.4	95.9	94.8	87.0	78.3
		MCWB	55.2	60.5	62.0	62.4	64.6	65.3	66.3	65.8	66.2	63.8	61.7	54.7
	2%	DB	73.5	74.6	76.1	78.6	80.8	82.2	83.2	83.8	88.1	87.8	80.1	71.9
		MCWB	55.7	57.8	58.5	59.5	62.2	63.6	65.1	65.8	64.5	61.7	58.6	54.1
	5%	DB	69.0	69.1	71.2	72.7	74.7	77.2	79.8	80.1	82.2	81.7	74.3	67.1
		MCWB	54.7	55.8	57.5	58.3	60.2	62.1	64.4	64.5	63.7	59.8	56.8	53.4
	10%	DB	64.0	63.9	66.5	68.1	70.3	73.3	76.3	76.7	77.7	76.0	69.8	63.3
		MCWB	53.8	53.9	56.2	56.9	58.8	61.0	63.2	63.5	62.8	59.0	55.8	52.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.4	62.5	64.2	64.5	66.4	67.5	69.0	69.0	70.2	68.0	63.9	61.3
		MCDB	66.4	73.0	77.3	80.6	83.0	85.4	83.3	83.5	83.2	85.0	77.6	65.8
	2%	WB	58.9	59.9	61.0	61.6	63.4	64.8	66.4	66.5	66.7	64.6	61.3	59.1
		MCDB	65.9	69.2	71.6	75.2	77.5	79.5	80.6	81.3	82.1	79.0	72.1	63.5
	5%	WB	57.1	57.8	58.9	59.5	61.1	62.9	64.9	65.0	65.0	62.6	59.6	56.9
		MCDB	63.8	65.7	67.9	70.4	72.6	76.0	78.6	79.0	78.8	75.3	69.9	62.1
	10%	WB	55.4	55.9	57.1	57.5	59.2	61.3	63.4	63.7	63.4	60.9	58.0	54.9
		MCDB	62.0	62.6	65.0	66.5	69.4	72.8	75.9	76.6	76.6	72.5	66.7	60.9
(35) Mean Daily Temperature Range	5% DB	MDBR	22.0	20.4	21.0	21.3	21.0	22.0	21.9	22.3	23.6	24.7	23.9	22.4
		MCDBR	31.0	29.3	28.8	29.8	29.5	28.5	27.4	27.7	31.0	34.3	31.8	30.0
	5% WB	MCWBR	16.5	15.7	15.2	15.0	14.1	13.2	12.0	11.9	13.0	14.7	14.7	16.4
		MCWBR	21.4	22.9	23.7	25.5	25.6	25.5	24.9	25.6	26.2	27.4	25.2	19.8
(40) Clear-Sky Solar Irradiance	taub		0.308	0.324	0.329	0.334	0.343	0.353	0.351	0.343	0.341	0.344	0.308	0.313
		taud	2.563	2.523	2.515	2.499	2.491	2.453	2.514	2.503	2.514	2.505	2.577	2.561
	Ebn at Noon		286	293	300	302	298	293	293	295	291	281	284	277
		Edh at Noon	25	29	31	34	35	36	33	33	31	29	24	23
(44) All-Sky Solar Radiation	RadAvg		924	1197	1650	2069	2358	2502	2357	2171	1865	1409	1047	821
	RadStd		75	128	119	141	134	98	79	74	74	88	56	79

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.37	N/A	N/A	N/A	-436	+463	N/A
(47) Regional (28 neighbors)	+1.03	N/A	-2.21	+1.26	N/A	N/A	N/A	-284	+373	+101

Nomenclature: See separate page