

SAN DIEGO INTL, CA, USA

WMO: 722900

Lat: 32.734N

Lon: 117.183W

Elev: 5

StdP: 101.27

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23188

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.4	8.5	-8.4	1.8	16.2	-5.6	2.3	16.4	9.0	15.4	8.0	15.4	0.8	340	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	29.3	18.0	27.5	18.7	26.1	18.8	21.9	25.8	21.3	25.0	20.7	24.2	3.8	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.2	24.0	19.9	14.6	23.6	19.3	14.1	23.1	64.0	25.9	61.8	25.1	59.7	24.3	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.5	5.7	DB	5.4	33.6	1.1	2.5	4.6	35.4	3.9	36.9	3.3	38.3	2.5	40.1	(4)
(5)			WB	1.3	22.9	1.2	1.0	0.4	23.6	-0.3	24.2	-1.0	24.8	-1.9	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	14.4	14.6	15.7	16.6	17.8	19.1	21.1	22.1	21.7	19.7	16.8	14.2	(6)	
	DBStd	3.46	2.27	2.17	2.07	2.19	1.91	1.62	1.78	1.82	2.21	2.26	2.38	2.01	(7)	
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	612	123	107	87	60	32	8	1	0	0	9	57	129	(9)	
	CDD10.0	2865	138	129	177	199	242	274	346	376	352	300	204	130	(10)	
	CDD18.3	436	2	2	5	9	15	32	88	117	102	51	12	1	(11)	
	CDH23.3	1342	21	22	40	61	58	37	151	304	341	214	86	7	(12)	
(13)	CDH26.7	261	1	3	8	15	20	6	12	39	70	63	23	0	(13)	
(14)	Wind	WSAvg	2.6	2.1	2.6	2.7	3.1	3.1	2.9	2.9	2.8	2.3	2.0	2.0	(14)	
(15) Precipitation	PrecAvg	220	42	41	40	18	4	1	0	0	6	7	31	34	(15)	
	PrecMax	505	154	175	161	74	32	17	3	7	36	52	146	142	(16)	
	PrecMin	65	0	0	0	0	0	0	0	0	0	0	0	5	(17)	
	PrecStd	98	43	44	40	21	7	3	1	1	10	11	33	30	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	26.6	27.6	28.9	29.4	26.9	28.0	29.9	31.6	31.6	29.8	24.2	(19)	
		MCWB	12.4	13.0	14.4	14.0	14.8	19.3	20.9	20.9	20.6	16.8	15.1	11.6	(20)	
	2%	DB	23.1	22.9	23.6	24.7	24.0	24.0	26.3	27.6	28.5	28.3	25.6	21.6	(21)	
		MCWB	11.8	12.4	13.2	14.1	16.6	18.8	20.4	20.9	20.4	16.3	13.6	12.1	(22)	
	5%	DB	20.9	20.3	21.0	22.0	21.6	22.5	24.9	26.1	26.7	25.5	22.9	19.6	(23)	
		MCWB	12.0	12.4	13.5	14.4	16.5	18.0	20.0	20.6	20.6	16.9	13.5	12.3	(24)	
	10%	DB	18.6	18.3	19.1	20.0	20.2	21.6	23.9	24.9	25.1	23.3	20.8	18.2	(25)	
		MCWB	12.1	12.6	13.6	14.6	15.9	17.4	19.5	20.2	20.2	17.3	14.3	12.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	16.2	16.8	17.4	18.9	20.2	22.2	22.7	22.9	21.3	18.3	16.8	(27)	
		MCDB	18.1	19.1	21.2	21.3	22.9	24.4	26.3	27.3	27.6	25.3	21.0	18.7	(28)	
	2%	WB	15.2	15.3	15.7	16.5	17.9	19.3	21.1	21.8	22.0	20.0	17.3	15.7	(29)	
		MCDB	17.5	18.1	19.5	20.5	21.5	23.1	24.8	25.7	25.9	23.7	20.1	17.9	(30)	
	5%	WB	14.5	14.6	15.1	15.7	17.1	18.6	20.5	21.2	21.4	19.0	16.5	14.9	(31)	
		MCDB	17.0	17.4	18.5	19.6	20.5	22.0	24.0	24.8	25.1	22.6	19.4	17.2	(32)	
	10%	WB	13.9	14.0	14.5	15.1	16.5	17.9	20.0	20.7	20.7	18.3	15.8	14.2	(33)	
		MCDB	16.6	16.8	17.7	18.8	19.7	21.1	23.3	24.1	24.2	21.7	18.9	16.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	7.1	6.3	5.8	4.4	4.2	4.4	4.8	5.3	6.4	7.7	8.0	(35)	
		MCDBR	12.3	11.5	10.7	10.4	7.1	5.9	5.7	6.3	7.9	11.3	12.3	11.2	(36)	
	5% WB	MCWBR	6.2	5.8	5.3	5.0	3.3	2.5	2.3	2.6	3.5	6.4	6.9	6.6	(37)	
		MCWBR	7.5	7.3	6.9	7.4	6.0	6.2	5.5	6.0	6.8	7.8	8.0	7.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.317	0.328	0.341	0.352	0.372	0.371	0.400	0.399	0.365	0.372	0.325	0.328	(40)	
		taud	2.550	2.532	2.479	2.453	2.418	2.424	2.426	2.408	2.479	2.432	2.555	2.545	(41)	
	Ebn at Noon	Ebn at Noon	907	930	939	937	914	910	882	880	901	866	889	872	(42)	
		Edh at Noon	82	92	105	112	117	116	116	116	104	101	81	79	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	3.31	4.17	5.46	6.58	6.87	7.12	7.00	6.76	5.85	4.57	3.58	2.99	(44)	
	RadStd	RadStd	0.20	0.35	0.31	0.36	0.52	0.46	0.47	0.30	0.33	0.34	0.24	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.53	N/A	-1.47	+0.94	N/A	N/A	N/A	-103	+188	+90
(47)	Regional (39 neighbors)	+0.64	N/A	-1.59	+0.76	N/A	N/A	N/A	-105	+230	+119

Nomenclature: See separate page